

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Τετάρτη, 10 Σεπτέμβριος 2025									
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000	
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)	
Τετάρτη, 10 Σεπτέμβριος 2025	00:00	40,84			1	1	1		1		1	1	5	
	01:00	37,97			1	1	1		1		1	1	4	
	02:00	36,22				1	1	1		1		1	1	2
	03:00	35,03				1	1	1		1		1	1	1
	04:00	34,30				1	1	1		1		1	1	1
	05:00	34,32				1	1	1		1		1	1	1
	06:00	35,72				1	1	1		1		1	1	4
	07:00	39,44				1	1	1		1		1	1	7
	08:00	44,32		1	1	1	1		1		1	1	6	
	09:00	47,70		1	1	1	1		1		1	1	10	
	10:00	50,42		1	1	1	1		1		1	1	11	
	11:00	51,18		1	1	1	1		1		1	1	11	
	12:00	48,73		1	1	1	1		1		1	1	12	
	13:00	52,75		1	1	1	1	1	1		1	1	12	
	14:00	52,97		1		1	1	1	1		1	1	12	
	15:00	52,51		1		1	1	1	1		1	1	11	
	16:00	52,08		1		1	1	1	1		1	1	11	
	17:00	51,53		1		1	1	1	1		1	1	10	
	18:00	52,36		1		1	1	1	1		1	1	10	
	19:00	52,57		1		1	1	1	1		1	1	11	
	20:00	53,60		1		1	1	1	1		1	1	12	
	21:00	52,31		1		1	1	1	1		1	1	10	
	22:00	49,36		1		1	1	1	1		1	1	7	
	23:00	44,61		1		1	1	1	1		1	1	4	

Μισθωμένη ισχύς 14 MW. Ένα φορητό βρίσκεται σε βλάβη. Μερική διακοπή από τις 12:34 - 13:04 & 23:36 - 23:46.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης