

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 11 Σεπτέμβριος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Πέμπτη, 11 Σεπτέμβριος 2025	00:00	41,35		1		1	1	1	1		1	1	
	01:00	38,30		1		1	1	1	1		1	1	
	02:00	37,04		1		1	1	1	1		1	1	
	03:00	35,74		1		1	1	1	1		1	1	
	04:00	35,41		1		1	1	1	1		1	1	
	05:00	35,54		1		1	1	1	1		1	1	
	06:00	36,30		1		1	1	1	1		1	1	
	07:00	40,71		1		1	1	1	1		1	1	5
	08:00	45,40		1		1	1	1	1		1	1	5
	09:00	47,95		1		1	1	1	1		1	1	9
	10:00	50,59		1		1	1	1	1		1	1	11
	11:00	51,32		1		1	1	1	1		1	1	12
	12:00	53,16		1		1	1	1	1		1	1	13
	13:00	54,67		1		1	1	1	1		1	1	13
	14:00	54,46		1		1	1	1	1		1	1	13
	15:00	54,13		1		1	1	1	1		1	1	13
	16:00	53,97		1		1	1	1	1		1	1	13
	17:00	53,96		1		1	1	1	1		1	1	13
	18:00	54,43		1		1	1	1	1		1	1	13
	19:00	53,86		1		1	1	1	1		1	1	13
	20:00	54,47		1		1	1	1	1		1	1	13
	21:00	53,29		1		1	1	1	1		1	1	13
	22:00	50,04		1		1	1	1	1		1	1	9
	23:00	46,33		1		1	1	1	1		1	1	6

Μισθωμένη ισχύς 14 MW. Ένα φορητό βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης