

| ΗΣ ΘΗΡΑΣ                   |                | Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα |       |       |       | Πέμπτη, 4 Σεπτεμβρίου 2025 |       |       |       |        |        |        |           |
|----------------------------|----------------|-----------------------------------------|-------|-------|-------|----------------------------|-------|-------|-------|--------|--------|--------|-----------|
| Αποδιδόμενη Ισχύς (MW)     |                |                                         | 7,300 | 7,300 | 3,500 | 3,500                      | 3,500 | 5,800 | 8,500 | 10,500 | 10,000 | 10,000 | 1,000     |
| Η<br>Ε<br>Π                | Χρονική στιγμή | Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)     | G1    | G2    | G3    | G4                         | G6    | G8    | G29   | G30    | G31    | G32    | H/Z (x30) |
| Πέμπτη, 4 Σεπτεμβρίου 2025 | 00:00          | 44,11                                   |       | 1     |       |                            | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 01:00          | 41,76                                   |       | 1     |       |                            | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 02:00          | 39,69                                   |       | 1     |       |                            | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 03:00          | 37,85                                   |       | 1     |       |                            | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 04:00          | 36,71                                   |       | 1     |       |                            | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 05:00          | 36,79                                   |       | 1     |       |                            | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 06:00          | 38,25                                   |       | 1     |       |                            | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 07:00          | 41,58                                   |       | 1     |       |                            | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 08:00          | 45,70                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      |           |
|                            | 09:00          | 48,90                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 3         |
|                            | 10:00          | 51,29                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 6         |
|                            | 11:00          | 52,62                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 8         |
|                            | 12:00          | 53,64                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 10        |
|                            | 13:00          | 54,21                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 10        |
|                            | 14:00          | 54,92                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 10        |
|                            | 15:00          | 54,54                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 10        |
|                            | 16:00          | 54,23                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 10        |
|                            | 17:00          | 53,97                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 10        |
|                            | 18:00          | 53,67                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 10        |
|                            | 19:00          | 52,78                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 8         |
|                            | 20:00          | 52,74                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 8         |
|                            | 21:00          | 52,28                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 8         |
|                            | 22:00          | 50,57                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 6         |
|                            | 23:00          | 46,57                                   |       | 1     |       | 1                          | 1     | 1     | 1     | 1      | 1      | 1      | 1         |

Μισθωμένη ισχύς 14 MW. Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

|  |                                          |
|--|------------------------------------------|
|  | Μη διαθεσιμότητα μονάδας λόγω συντήρησης |
|  | Μη διαθεσιμότητα μονάδας λόγω βλάβης     |