

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 14 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	0,650	
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	ΦΟΡΗΤΑ
Πέμπτη, 14 Αυγούστου 2025	00:00	1,048	1	1		1		1	1		
	01:00	1,013	1	1		1		1	1		
	02:00	0,955	1	1		1		1	1		
	03:00	0,916	1	1		1		1	1		
	04:00	0,877	1	1		1		1	1	1	
	05:00	0,857		1		1		1	1	1	
	06:00	0,850		1		1		1	1	1	
	07:00	0,863		1		1		1	1	1	
	08:00	0,908		1		1		1	1	1	
	09:00	0,983		1		1		1	1	1	
	10:00	1,028	1	1		1			1	1	
	11:00	1,080	1	1		1			1	1	
	12:00	1,098	1	1		1			1	1	
	13:00	1,126	1	1		1			1	1	
	14:00	1,136	1	1		1		1	1	1	
	15:00	1,167	1	1		1		1	1	1	
	16:00	1,199	1	1		1		1	1	1	
	17:00	1,154	1	1		1		1	1	1	
	18:00	1,173	1	1		1		1	1	1	
	19:00	1,170	1	1		1		1	1	1	
	20:00	1,124	1	1		1		1	1	1	
	21:00	1,046	1	1		1		1	1	1	
	22:00	0,970	1	1		1			1	1	
	23:00	0,958	1	1					1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 15 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	0,650
Η Ρ Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	ΦΟΡΗΤΑ
Παρασκευή, 15 Αυγούστου 2025	00:00	0,982	1	1					1	1	
	01:00	0,968	1	1					1	1	
	02:00	0,932	1	1					1	1	
	03:00	0,905	1	1					1	1	
	04:00	0,868	1	1					1	1	
	05:00	0,849	1	1					1	1	
	06:00	0,807	1	1					1	1	
	07:00	0,823	1	1					1	1	
	08:00	0,889	1	1					1	1	
	09:00	0,962	1	1					1	1	
	10:00	1,003	1	1				1	1	1	
	11:00	1,022	1	1				1	1	1	
	12:00	1,039	1	1				1	1	1	
	13:00	1,126	1	1				1	1	1	
	14:00	1,126	1	1				1	1	1	
	15:00	1,101	1	1				1	1	1	
	16:00	1,096	1	1				1	1	1	
	17:00	1,085	1	1				1	1	1	
	18:00	1,099	1	1				1	1	1	
	19:00	1,092	1	1				1	1	1	
	20:00	1,092	1	1				1	1	1	
	21:00	1,075	1	1				1	1	1	
	22:00	1,044	1	1				1	1	1	
	23:00	0,971	1	1				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 16 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	0,650	
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Θριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	ΦΟΡΗΤΑ
Σάββατο, 16 Αυγούστου 2025	00:00	0,963	1	1				1	1	1	
	01:00	1,019	1	1				1	1	1	
	02:00	0,987	1	1				1	1	1	
	03:00	0,945	1	1				1	1	1	
	04:00	0,927	1	1				1	1	1	
	05:00	0,890	1	1				1	1	1	
	06:00	0,870		1				1	1	1	
	07:00	0,909		1				1	1	1	
	08:00	0,995	1	1				1	1	1	
	09:00	1,073	1	1				1	1	1	
	10:00	1,042	1	1				1	1	1	
	11:00	1,027	1	1				1	1	1	
	12:00	1,038	1	1				1	1	1	
	13:00	1,087	1	1				1	1	1	
	14:00	1,138	1	1				1	1	1	
	15:00	1,106	1	1				1	1	1	
	16:00	1,109	1	1				1	1	1	
	17:00	1,111	1	1				1	1	1	
	18:00	1,218	1	1		1		1	1	1	
	19:00	1,273	1	1		1		1	1	1	
	20:00	1,296	1	1		1		1	1	1	
	21:00	1,252	1	1		1		1	1	1	
	22:00	1,172	1	1		1		1	1	1	
	23:00	1,112	1	1		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 17 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	0,650
Η Ρ Ε Τ Ε	Χρονική στιγμή	Πραγματικό Μέσο Θριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	ΦΟΡΗΤΑ
Κυριακή, 17 Αυγούστου 2025	00:00	1,062	1	1		1		1		1	
	01:00	1,024	1	1		1		1		1	
	02:00	0,989	1	1		1		1		1	
	03:00	0,960	1	1		1		1		1	
	04:00	0,918	1	1		1		1		1	
	05:00	0,907	1	1				1		1	
	06:00	0,885	1	1				1		1	
	07:00	0,902	1	1				1		1	
	08:00	0,974	1	1				1		1	
	09:00	1,089	1	1		1		1		1	
	10:00	1,088	1	1		1		1		1	
	11:00	1,005	1	1		1		1		1	
	12:00	1,019	1	1		1		1		1	
	13:00	1,176	1	1		1		1		1	
	14:00	1,187	1	1				1	1	1	
	15:00	1,147	1	1				1	1	1	
	16:00	1,151	1	1				1	1	1	
	17:00	1,147	1	1				1	1	1	
	18:00	1,189	1	1				1	1	1	
	19:00	1,184	1	1				1	1	1	
	20:00	1,150	1	1				1	1	1	
	21:00	1,088	1	1				1	1	1	
	22:00	1,041	1	1				1	1	1	
	23:00	0,993	1	1				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 18 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	0,650
Η Ρ Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	ΦΟΡΗΤΑ
Δευτέρα, 18 Αυγούστου 2025	00:00	0,945	1	1				1	1	1	
	01:00	0,916	1	1				1	1	1	
	02:00	0,854	1	1					1	1	
	03:00	0,833	1	1					1	1	
	04:00	0,812	1	1					1	1	
	05:00	0,810	1	1					1	1	
	06:00	0,790	1	1					1	1	
	07:00	0,810	1	1					1	1	
	08:00	0,870	1	1					1	1	
	09:00	0,911	1	1					1	1	
	10:00	0,832	1	1					1	1	
	11:00	0,831	1	1					1	1	
	12:00	0,844	1	1					1	1	
	13:00	1,017	1	1				1	1	1	
	14:00	1,063	1	1				1	1	1	
	15:00	1,036	1	1				1	1	1	
	16:00	1,015	1	1				1	1	1	
	17:00	0,999	1	1				1	1	1	
	18:00	1,024	1	1				1	1	1	
	19:00	1,027	1	1				1	1	1	
	20:00	1,067	1	1				1	1	1	
	21:00	1,059	1	1				1	1	1	
	22:00	0,988	1	1				1	1	1	
	23:00	0,929	1	1				1	1	1	

Μισθωμένη ισχύς 0,65MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 19 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	0,650	
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Θριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	ΦΟΡΗΤΑ
Τρίτη, 19 Αυγούστου 2025	00:00	0,882	1	1				1	1	1	
	01:00	0,843	1					1	1	1	
	02:00	0,795	1					1	1	1	
	03:00	0,745	1					1	1	1	
	04:00	0,738	1					1	1	1	
	05:00	0,740	1					1	1	1	
	06:00	0,749	1					1	1	1	
	07:00	0,747	1	1				1	1	1	
	08:00	0,778	1	1						1	
	09:00	0,856	1	1							1
	10:00	0,913	1	1							1
	11:00	1,010	1	1				1		1	1
	12:00	1,076	1	1				1		1	1
	13:00	1,023	1	1				1		1	1
	14:00	1,086	1	1				1		1	1
	15:00	1,065	1	1						1	1
	16:00	1,061	1	1						1	1
	17:00	1,056	1	1						1	1
	18:00	1,026	1	1						1	1
	19:00	0,996	1	1						1	1
	20:00	1,048	1	1						1	1
	21:00	1,020	1	1						1	1
	22:00	0,971	1	1				1		1	1
	23:00	0,925	1	1				1		1	1

Μισθωμένη ισχύς 0,65MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 20 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	0,650	
Α Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	ΦΟΡΗΤΑ
Τετάρτη, 20 Αυγούστου 2025	00:00	0,810	1	1				1		1	
	01:00	0,882	1	1				1		1	
	02:00	0,821	1	1				1		1	
	03:00	0,796	1	1				1		1	
	04:00	0,768	1	1				1		1	
	05:00	0,755	1	1				1		1	
	06:00	0,727	1	1				1		1	
	07:00	0,762	1	1				1		1	
	08:00	0,853	1	1				1		1	
	09:00	0,841	1							1	1
	10:00	0,888	1							1	1
	11:00	0,923	1					1		1	1
	12:00	0,985	1					1		1	1
	13:00	1,013	1					1		1	1
	14:00	1,021	1					1		1	1
	15:00	1,036	1					1		1	1
	16:00	0,997	1					1		1	1
	17:00	1,016	1					1		1	1
	18:00	1,033	1					1		1	1
	19:00	1,059	1					1		1	1
	20:00	1,048	1					1		1	1
	21:00	1,012	1					1		1	1
	22:00	0,943	1					1		1	1
	23:00	0,920	1					1		1	1

Μισθωμένη ισχύς 0,65MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης