

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 24 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Πέμπτη, 24 Ιουλίου 2025	00:00	0,971		1	1		1	1		1
	01:00	0,942		1	1		1	1		1
	02:00	0,888		1	1		1	1		1
	03:00	0,856		1	1		1	1		1
	04:00	0,818		1	1		1	1		1
	05:00	0,760		1	1		1	1		1
	06:00	0,738		1	1			1		1
	07:00	0,817		1	1	1		1		
	08:00	0,907		1	1	1		1		
	09:00	0,962	1	1		1		1		
	10:00	1,011	1	1		1		1		1
	11:00	1,051	1	1		1		1		1
	12:00	1,039	1	1		1		1		1
	13:00	1,095		1	1	1		1		1
	14:00	1,072		1	1	1		1		1
	15:00	1,071		1	1	1		1		1
	16:00	1,067		1	1	1		1		1
	17:00	1,067		1	1	1		1		1
	18:00	1,072		1	1	1	1	1		1
	19:00	1,040		1	1	1	1	1		1
	20:00	0,988		1	1	1	1	1		1
	21:00	0,975		1	1	1	1	1		1
	22:00	1,028		1	1	1	1	1		1
	23:00	1,104		1	1	1	1	1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 25 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Παρασκευή, 25 Ιουλίου 2025	00:00	1,061		1	1	1	1	1		1
	01:00	1,012		1	1	1	1	1		1
	02:00	0,974		1	1	1	1	1		1
	03:00	0,944		1	1	1	1			1
	04:00	0,921		1	1	1	1			1
	05:00	0,922		1	1	1	1			1
	06:00	0,950		1	1		1	1		1
	07:00	1,008		1	1		1	1		1
	08:00	1,113	1	1	1			1		1
	09:00	1,135	1	1	1		1	1		1
	10:00	1,027	1	1	1		1	1		1
	11:00	0,957	1	1	1		1	1		1
	12:00	0,975	1	1	1		1	1		1
	13:00	1,229	1	1	1		1	1		1
	14:00	1,312	1	1	1	1	1	1		1
	15:00	1,313	1	1	1	1	1	1		1
	16:00	1,315	1	1	1	1	1	1		1
	17:00	1,321	1	1	1	1	1	1		1
	18:00	1,266	1	1	1	1	1	1		1
	19:00	1,174	1	1	1	1	1	1		1
	20:00	1,299	1	1	1	1	1	1		1
	21:00	1,259	1	1	1	1	1	1		1
	22:00	1,152	1	1	1	1	1	1		1
	23:00	1,073	1	1	1	1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 26 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
α ρ ρ ε τ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Σάββατο, 26 Ιουλίου 2025	00:00	1,054	1	1	1	1	1			1
	01:00	1,076	1	1	1	1	1			1
	02:00	1,051	1	1	1	1				1
	03:00	0,955	1	1	1	1				1
	04:00	0,945	1	1	1	1				1
	05:00	0,893	1	1	1	1				1
	06:00	0,856	1	1	1	1				1
	07:00	0,880	1	1	1	1				1
	08:00	0,996	1	1	1	1				1
	09:00	1,038	1	1	1	1				1
	10:00	0,980	1	1	1	1				1
	11:00	1,063	1	1	1	1				1
	12:00	1,102	1	1	1	1				1
	13:00	1,125	1	1	1	1	1			1
	14:00	1,111	1	1	1	1	1			1
	15:00	1,105	1	1	1	1	1			1
	16:00	1,119	1	1	1	1	1			1
	17:00	1,140	1	1	1	1	1			1
	18:00	1,142	1	1	1	1	1			1
	19:00	1,151	1	1	1	1	1			1
	20:00	1,127	1	1	1	1	1			1
	21:00	1,067	1	1	1	1	1			1
	22:00	0,978	1	1		1	1			1
	23:00	0,965	1	1		1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 27 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Κυριακή, 27 Ιουλίου 2025	00:00	0,936	1	1		1				1
	01:00	0,882	1	1	1	1				1
	02:00	0,829	1	1	1	1				1
	03:00	0,790	1	1	1	1				1
	04:00	0,864	1	1		1				1
	05:00	0,837	1	1		1				1
	06:00	0,795	1	1		1				1
	07:00	0,848	1	1		1				1
	08:00	0,964	1	1		1				1
	09:00	1,053	1	1	1	1				1
	10:00	1,041	1	1	1	1				1
	11:00	0,969		1	1	1	1			1
	12:00	1,051		1	1	1	1			1
	13:00	1,043	1	1	1	1	1			
	14:00	1,037	1	1	1	1	1			
	15:00	1,003	1	1	1	1	1			
	16:00	1,003	1	1	1	1	1			
	17:00	1,001	1	1	1	1	1			
	18:00	1,007		1	1	1	1			1
	19:00	0,985		1	1	1	1			1
	20:00	0,979		1	1	1	1			1
	21:00	1,037		1	1	1	1			1
	22:00	1,046	1	1	1	1	1			1
	23:00	1,057	1	1	1	1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 28 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Δευτέρα, 28 Ιουλίου 2025	00:00	0,993		1	1	1	1			1
	01:00	0,940		1	1	1	1			1
	02:00	0,901		1	1	1	1			1
	03:00	0,854		1	1	1				1
	04:00	0,817		1	1	1				1
	05:00	0,789		1	1	1				1
	06:00	0,752	1		1	1				
	07:00	0,757	1		1	1				
	08:00	0,834	1		1	1				
	09:00	0,886	1		1	1	1			
	10:00	0,950	1		1	1	1			1
	11:00	0,949	1		1	1	1			1
	12:00	0,984	1		1	1	1			1
	13:00	1,023	1		1	1	1			1
	14:00	1,026	1		1	1	1			1
	15:00	1,017	1		1	1	1			1
	16:00	1,004	1		1	1	1			1
	17:00	0,989	1		1	1	1			1
	18:00	1,024	1		1	1	1			1
	19:00	1,021	1		1	1	1			1
	20:00	0,994	1		1	1	1			1
	21:00	0,965	1		1	1	1			1
	22:00	0,912	1		1	1	1			1
	23:00	0,851	1		1		1			1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 29 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τρίτη, 29 Ιουλίου 2025	00:00	0,820	1		1	1				1
	01:00	0,777	1		1	1				1
	02:00	0,751	1		1	1				1
	03:00	0,732	1		1					1
	04:00	0,730	1		1					1
	05:00	0,690	1		1					1
	06:00	0,670	1		1					1
	07:00	0,747	1		1					1
	08:00	0,819	1	1	1	1				1
	09:00	0,879	1	1	1	1				1
	10:00	0,920	1	1	1	1				1
	11:00	0,961	1	1	1	1				1
	12:00	0,978	1	1	1					1
	13:00	0,991	1	1	1					1
	14:00	1,001	1	1	1					1
	15:00	0,975	1	1	1					1
	16:00	0,944	1	1	1					1
	17:00	0,944	1	1	1					1
	18:00	1,006	1	1	1					1
	19:00	0,980	1	1	1					1
	20:00	0,943	1	1	1					1
	21:00	0,945	1	1	1					1
	22:00	0,901	1	1	1					1
	23:00	0,859	1	1	1					1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 30 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τετάρτη, 30 Ιουλίου 2025	00:00	0,807	1	1						1
	01:00	0,793	1	1		1				1
	02:00	0,845	1	1		1				1
	03:00	0,801	1	1		1				1
	04:00	0,779	1	1						1
	05:00	0,781	1	1						1
	06:00	0,767	1	1						1
	07:00	0,796	1	1						1
	08:00	0,876	1	1		1				1
	09:00	0,934	1	1		1				1
	10:00	1,022	1	1		1				1
	11:00	1,023	1	1	1	1				
	12:00	1,083	1	1	1	1				
	13:00	1,093	1	1	1	1				
	14:00	1,108	1	1	1	1				
	15:00	1,093	1	1	1	1				
	16:00	1,057	1	1	1	1				
	17:00	1,053	1	1	1	1				
	18:00	1,078	1	1	1	1				
	19:00	1,110	1	1	1	1				
	20:00	1,079	1	1	1	1				
	21:00	1,050	1	1	1	1				
	22:00	0,990	1	1	1	1				
	23:00	0,942	1	1	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης