

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 31 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Πέμπτη, 31 Ιουλίου 2025	00:00	0,900	1	1	1					
	01:00	0,861	1	1	1					
	02:00	0,820	1	1	1					
	03:00	0,791	1	1	1					
	04:00	0,773	1	1	1					
	05:00	0,752	1	1	1					
	06:00	0,733	1	1	1					
	07:00	0,806	1	1	1					
	08:00	0,906	1	1	1	1				
	09:00	0,924	1	1	1	1				
	10:00	0,985	1	1	1	1				
	11:00	0,984	1	1	1	1				
	12:00	0,993	1	1	1	1				
	13:00	1,048	1	1	1	1				
	14:00	1,068	1	1	1				1	
	15:00	1,061	1	1	1				1	
	16:00	1,042	1	1	1				1	
	17:00	1,043	1	1	1				1	
	18:00	1,059	1	1	1				1	
	19:00	1,048	1	1	1				1	
	20:00	1,069	1	1	1				1	
	21:00	1,037	1	1	1				1	
	22:00	0,991	1	1	1				1	
	23:00	0,951	1	1		1			1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 1 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Παρασκευή, 1 Αυγούστου 2025	00:00	0,901	1	1		1			1	
	01:00	0,848	1	1		1			1	
	02:00	0,798	1	1					1	
	03:00	0,763	1	1					1	
	04:00	0,738	1	1					1	
	05:00	0,730	1	1					1	
	06:00	0,725	1	1					1	
	07:00	0,796	1	1					1	
	08:00	0,861	1	1					1	
	09:00	0,929	1	1	1				1	
	10:00	0,983	1	1	1				1	
	11:00	1,023	1	1	1				1	
	12:00	0,910	1	1	1				1	
	13:00	0,937	1	1	1				1	
	14:00	1,085	1	1	1			1	1	
	15:00	1,159	1	1	1			1	1	
	16:00	1,124	1	1	1			1	1	
	17:00	1,147	1	1	1			1	1	
	18:00	1,170	1	1	1			1	1	
	19:00	1,150	1	1	1			1	1	
	20:00	1,115	1	1	1			1	1	
	21:00	1,072	1	1	1			1	1	
	22:00	1,040	1	1	1			1	1	
	23:00	1,023	1	1	1			1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 2 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Σάββατο, 2 Αυγούστου 2025	00:00	0,981	1	1	1			1	1	
	01:00	0,946	1	1	1			1	1	
	02:00	0,886	1	1	1				1	
	03:00	0,863	1	1	1				1	
	04:00	0,841	1	1	1				1	
	05:00	0,838	1		1	1			1	
	06:00	0,815	1		1	1			1	
	07:00	0,808	1		1	1			1	
	08:00	0,879	1		1	1			1	
	09:00	0,927	1		1	1			1	
	10:00	0,985	1		1	1		1		
	11:00	1,018	1	1	1			1		
	12:00	1,052	1	1	1			1		
	13:00	1,098	1	1	1			1		
	14:00	1,097	1	1	1			1		
	15:00	1,096	1	1	1			1		
	16:00	1,076	1	1	1			1		
	17:00	1,088	1	1	1			1		
	18:00	1,130	1	1	1			1		
	19:00	1,134	1	1		1	1	1		
	20:00	1,100	1	1		1	1	1		
	21:00	1,080	1	1		1		1	1	
	22:00	1,049	1	1		1		1	1	
	23:00	0,985	1	1		1		1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 3 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Κυριακή, 3 Αυγούστου 2025	00:00	0,925	1	1		1		1	1	
	01:00	0,901	1	1		1		1	1	
	02:00	0,882	1	1		1		1	1	
	03:00	0,872		1		1	1	1	1	
	04:00	0,852		1		1	1	1	1	
	05:00	0,834		1		1	1	1	1	
	06:00	0,811		1		1	1	1	1	
	07:00	0,824		1		1	1	1	1	
	08:00	0,877		1		1	1	1	1	
	09:00	0,978		1		1	1	1	1	
	10:00	1,045		1		1	1	1	1	1
	11:00	1,022		1		1	1	1	1	1
	12:00	1,078		1		1	1	1	1	1
	13:00	1,116		1		1	1	1	1	1
	14:00	1,094		1		1	1	1	1	1
	15:00	1,078		1		1	1	1	1	1
	16:00	1,094		1		1	1	1	1	1
	17:00	1,069		1		1	1	1	1	1
	18:00	1,113		1		1	1	1	1	1
	19:00	1,094		1		1	1	1	1	1
	20:00	1,084		1		1	1	1	1	1
	21:00	1,079		1		1	1	1	1	1
	22:00	1,046		1		1	1	1	1	1
	23:00	0,991		1		1	1	1	1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 4 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Δευτέρα, 4 Αυγούστου 2025	00:00	0,946		1		1	1	1	1	1
	01:00	0,910		1		1	1	1	1	1
	02:00	0,854		1		1	1	1	1	1
	03:00	0,831		1		1	1	1	1	1
	04:00	0,810		1		1	1	1	1	1
	05:00	0,793		1		1	1	1		1
	06:00	0,760		1		1	1	1		1
	07:00	0,819		1		1	1	1		1
	08:00	0,896		1		1	1	1		1
	09:00	0,969		1		1		1	1	1
	10:00	1,028		1		1		1	1	1
	11:00	1,000		1		1		1	1	1
	12:00	0,936		1		1		1	1	1
	13:00	1,009		1		1	1	1	1	1
	14:00	1,101		1		1	1	1	1	1
	15:00	1,106		1		1	1	1	1	1
	16:00	1,092		1		1	1	1	1	1
	17:00	1,072		1		1	1	1	1	1
	18:00	1,104		1		1	1	1	1	1
	19:00	1,091		1		1	1	1	1	1
	20:00	1,079		1		1	1	1	1	1
	21:00	1,069		1		1	1	1	1	1
	22:00	1,034		1		1	1	1	1	1
	23:00	0,984		1		1	1	1	1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 5 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)		0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400	
Η Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τρίτη, 5 Αυγούστου 2025	00:00	0,941		1		1	1	1	1	1
	01:00	0,885		1		1	1	1	1	1
	02:00	0,732		1		1		1	1	1
	03:00	0,702		1		1		1	1	1
	04:00	0,685		1		1		1	1	1
	05:00	0,668		1		1		1	1	1
	06:00	0,660		1		1		1	1	1
	07:00	0,715		1		1		1	1	1
	08:00	0,816		1		1		1	1	1
	09:00	0,867		1		1		1	1	1
	10:00	1,036		1		1	1	1	1	1
	11:00	1,068		1		1	1	1	1	1
	12:00	1,095		1		1	1	1	1	1
	13:00	1,145		1		1	1	1	1	1
	14:00	1,154	1	1		1		1	1	1
	15:00	1,117	1	1		1		1	1	1
	16:00	1,103	1	1		1			1	1
	17:00	1,127	1	1		1			1	1
	18:00	1,131	1	1		1			1	1
	19:00	1,096	1	1		1			1	1
	20:00	1,091	1	1		1			1	1
	21:00	1,119	1	1		1			1	1
	22:00	1,082	1	1		1			1	1
	23:00	1,077	1	1		1			1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 6 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τετάρτη, 6 Αυγούστου 2025	00:00	1,024	1	1		1			1	1
	01:00	0,958	1	1		1			1	1
	02:00	0,907	1	1		1			1	1
	03:00	0,868	1			1	1	1	1	1
	04:00	0,836	1			1	1	1	1	1
	05:00	0,821	1			1	1	1	1	1
	06:00	0,799	1					1	1	1
	07:00	0,836	1					1	1	1
	08:00	0,928	1				1	1	1	1
	09:00	0,992	1				1	1	1	1
	10:00	1,017	1				1	1	1	1
	11:00	1,066	1				1	1	1	1
	12:00	1,101	1			1	1	1	1	1
	13:00	1,128	1			1	1	1	1	1
	14:00	1,138	1			1	1	1	1	1
	15:00	1,144	1			1	1	1	1	1
	16:00	1,111	1			1	1	1	1	1
	17:00	1,108	1			1	1	1	1	1
	18:00	1,183	1			1	1	1	1	1
	19:00	1,169	1			1	1	1	1	1
	20:00	1,180	1			1	1	1	1	1
	21:00	1,140	1			1	1	1	1	1
	22:00	1,074	1			1	1	1	1	1
	23:00	1,021	1			1	1	1	1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης