

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 1 Αυγούστου 2025			
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Η Ρ Α Σ Κ Ε Υ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Παρασκευή, 1 Αυγούστου 2025	00:00	0,936	1		1		1	1	1	
	01:00	0,903	1		1		1	1	1	
	02:00	0,872	1		1		1	1	1	
	03:00	0,841	1		1		1	1	1	
	04:00	0,813	1		1		1	1	1	
	05:00	0,791	1		1		1	1	1	
	06:00	0,792	1		1		1	1	1	
	07:00	0,836	1		1		1	1	1	
	08:00	0,938	1		1		1	1	1	
	09:00	1,009	1		1		1	1	1	
	10:00	1,015	1		1		1	1	1	
	11:00	1,008	1		1		1	1	1	
	12:00	1,033	1		1		1	1	1	
	13:00	1,115	1		1		1	1	1	
	14:00	1,130	1	1	1		1	1	1	
	15:00	1,127	1	1	1		1	1	1	
	16:00	1,126	1	1	1		1	1	1	
	17:00	1,131	1	1	1		1	1	1	
	18:00	1,132	1	1	1		1	1	1	
	19:00	1,122	1	1	1		1	1	1	
	20:00	1,156	1	1	1		1	1	1	
	21:00	1,149	1	1	1		1	1	1	
	22:00	1,096	1	1	1		1	1	1	
	23:00	1,043	1		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 2 Αυγούστου 2025			
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Η Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Σάββατο, 2 Αυγούστου 2025	00:00	0,988	1		1		1	1	1	
	01:00	0,958	1		1		1	1	1	
	02:00	0,927	1		1		1	1	1	
	03:00	0,896	1		1		1	1	1	
	04:00	0,871	1		1		1	1	1	
	05:00	0,846	1		1		1	1	1	
	06:00	0,831	1		1		1	1	1	
	07:00	0,852	1		1		1	1	1	
	08:00	0,936	1		1		1	1	1	
	09:00	1,000	1		1		1	1	1	
	10:00	1,013	1		1		1	1	1	
	11:00	1,065	1	1	1		1	1	1	
	12:00	1,093	1	1	1		1	1	1	
	13:00	1,101	1	1	1		1	1	1	
	14:00	1,108	1	1	1		1	1	1	
	15:00	1,112	1	1	1		1	1	1	
	16:00	1,119	1	1	1		1	1	1	
	17:00	1,121	1	1	1		1	1	1	
	18:00	1,120	1	1	1		1	1	1	
	19:00	1,114	1	1	1		1	1	1	
	20:00	1,111	1	1	1		1	1	1	
	21:00	1,086	1	1	1		1	1	1	
	22:00	1,036	1		1		1	1	1	
	23:00	0,984	1		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 3 Αυγούστου 2025			
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Κυριακή, 3 Αυγούστου 2025	00:00	0,995	1		1		1	1	1	
	01:00	0,959	1		1		1	1	1	
	02:00	0,923	1		1		1	1	1	
	03:00	0,888	1		1		1	1	1	
	04:00	0,858	1		1		1	1	1	
	05:00	0,834	1		1		1	1	1	
	06:00	0,825	1		1		1	1	1	
	07:00	0,850	1		1		1	1	1	
	08:00	0,918	1		1		1	1	1	
	09:00	0,985	1		1		1	1	1	
	10:00	1,019	1		1		1	1	1	
	11:00	1,009	1		1		1	1	1	
	12:00	1,058	1		1		1	1	1	
	13:00	1,081	1	1	1		1	1	1	
	14:00	1,098	1	1	1		1	1	1	
	15:00	1,103	1	1	1		1	1	1	
	16:00	1,108	1	1	1		1	1	1	
	17:00	1,110	1	1	1		1	1	1	
	18:00	1,110	1	1	1		1	1	1	
	19:00	1,101	1	1	1		1	1	1	
	20:00	1,088	1	1	1		1	1	1	
	21:00	1,051	1		1		1	1	1	
	22:00	1,018	1		1		1	1	1	
	23:00	0,971	1		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 4 Αυγούστου 2025			
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Δευτέρα, 4 Αυγούστου 2025	00:00	0,956	1		1		1	1	1	
	01:00	0,913	1		1		1	1	1	
	02:00	0,872	1		1		1	1	1	
	03:00	0,833	1		1		1	1	1	
	04:00	0,801	1		1		1	1	1	
	05:00	0,783	1		1		1	1	1	
	06:00	0,791	1		1		1	1	1	
	07:00	0,833	1		1		1	1	1	
	08:00	0,893	1		1		1	1	1	
	09:00	0,929	1		1		1	1	1	
	10:00	0,968	1		1		1	1	1	
	11:00	1,012	1		1		1	1	1	
	12:00	1,047	1		1		1	1	1	
	13:00	1,081	1	1	1		1	1	1	
	14:00	1,098	1	1	1		1	1	1	
	15:00	1,105	1	1	1		1	1	1	
	16:00	1,109	1	1	1		1	1	1	
	17:00	1,110	1	1	1		1	1	1	
	18:00	1,102	1	1	1		1	1	1	
	19:00	1,094	1	1	1		1	1	1	
	20:00	1,075	1	1	1		1	1	1	
	21:00	1,044	1		1		1	1	1	
	22:00	0,998	1		1		1	1	1	
	23:00	0,947	1		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 5 Αυγούστου 2025			
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τρίτη, 5 Αυγούστου 2025	00:00	0,935	1		1		1	1	1	
	01:00	0,897	1		1		1	1	1	
	02:00	0,861	1		1		1	1	1	
	03:00	0,827	1		1		1	1	1	
	04:00	0,797	1		1		1	1	1	
	05:00	0,775	1		1		1	1	1	
	06:00	0,772	1		1		1	1	1	
	07:00	0,809	1		1		1	1	1	
	08:00	0,878	1		1		1	1	1	
	09:00	0,936	1		1		1	1	1	
	10:00	0,971	1		1		1	1	1	
	11:00	1,002	1		1		1	1	1	
	12:00	1,033	1		1		1	1	1	
	13:00	1,056	1		1		1	1	1	
	14:00	1,061	1		1		1	1	1	
	15:00	1,062	1		1		1	1	1	
	16:00	1,063	1		1		1	1	1	
	17:00	1,057	1		1		1	1	1	
	18:00	1,044	1		1		1	1	1	
	19:00	1,035	1		1		1	1	1	
	20:00	1,014	1		1		1	1	1	
	21:00	0,981	1		1		1	1	1	
	22:00	0,933	1		1		1	1	1	
	23:00	0,876	1		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 6 Αυγούστου 2025			
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τετάρτη, 6 Αυγούστου 2025	00:00	0,911	1		1		1	1	1	
	01:00	0,877	1		1		1	1	1	
	02:00	0,846	1		1		1	1	1	
	03:00	0,815	1		1		1	1	1	
	04:00	0,788	1		1		1	1	1	
	05:00	0,770	1		1		1	1	1	
	06:00	0,770	1		1		1	1	1	
	07:00	0,807	1		1		1	1	1	
	08:00	0,884	1		1		1	1	1	
	09:00	0,944	1		1		1	1	1	
	10:00	0,996	1		1		1	1	1	
	11:00	1,023	1		1		1	1	1	
	12:00	1,052	1		1		1	1	1	
	13:00	1,078	1	1	1		1	1	1	
	14:00	1,082	1	1	1		1	1	1	
	15:00	1,075	1	1	1		1	1	1	
	16:00	1,068	1	1	1		1	1	1	
	17:00	1,065	1	1	1		1	1	1	
	18:00	1,066	1	1	1		1	1	1	
	19:00	1,070	1	1	1		1	1	1	
	20:00	1,068	1	1	1		1	1	1	
	21:00	1,042	1		1		1	1	1	
	22:00	1,002	1		1		1	1	1	
	23:00	0,955	1		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 7 Αυγούστου 2025			
Αποδιδόμενη Ισχύς (MW)			0,320	0,320	0,320	0,250	0,180	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Πέμπτη, 7 Αυγούστου 2025	00:00	0,928	1		1		1	1	1	
	01:00	0,894	1		1		1	1	1	
	02:00	0,862	1		1		1	1	1	
	03:00	0,832	1		1		1	1	1	
	04:00	0,806	1		1		1	1	1	
	05:00	0,786	1		1		1	1	1	
	06:00	0,782	1		1		1	1	1	
	07:00	0,812	1		1		1	1	1	
	08:00	0,889	1		1		1	1	1	
	09:00	0,959	1		1		1	1	1	
	10:00	0,993	1		1		1	1	1	
	11:00	1,027	1		1		1	1	1	
	12:00	1,050	1		1		1	1	1	
	13:00	1,080	1	1	1		1	1	1	
	14:00	1,090	1	1	1		1	1	1	
	15:00	1,088	1	1	1		1	1	1	
	16:00	1,084	1	1	1		1	1	1	
	17:00	1,084	1	1	1		1	1	1	
	18:00	1,088	1	1	1		1	1	1	
	19:00	1,091	1	1	1		1	1	1	
	20:00	1,083	1	1	1		1	1	1	
	21:00	1,065	1	1	1		1	1	1	
	22:00	1,034	1		1		1	1	1	
	23:00	1,000	1		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης