

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 10 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Τετάρτη, 10 Σεπτεμβρίου 2025	00:00	1,312		1		1			
	01:00	1,215		1		1			
	02:00	1,176		1		1			
	03:00	1,113		1		1			
	04:00	1,103		1		1			
	05:00	1,116		1		1			
	06:00	1,143		1		1			
	07:00	1,260		1		1			
	08:00	1,424		1		1			
	09:00	1,528		1		1			
	10:00	1,608		1	1	1			
	11:00	1,676		1	1	1			
	12:00	1,644		1	1	1			
	13:00	1,628		1	1	1			
	14:00	1,635		1	1	1			
	15:00	1,647		1	1	1			
	16:00	1,638		1	1	1			
	17:00	1,652		1	1	1			
	18:00	1,820		1	1	1			
	19:00	1,926		1	1	1			
	20:00	1,991		1	1	1			
	21:00	1,900		1	1	1			
	22:00	1,729		1	1	1			
	23:00	1,549		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 11 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Πέμπτη, 11 Σεπτεμβρίου 2025	00:00	1,381		1		1			
	01:00	1,237		1		1			
	02:00	1,187		1		1			
	03:00	1,129		1		1			
	04:00	1,096		1		1			
	05:00	1,112		1		1			
	06:00	1,130		1		1			
	07:00	1,247		1		1			
	08:00	1,400		1		1			
	09:00	1,529		1		1			
	10:00	1,606		1		1	1		
	11:00	1,633		1		1	1		
	12:00	1,700		1		1	1		
	13:00	1,723		1	1	1			
	14:00	1,736		1	1	1			
	15:00	1,698		1	1	1			
	16:00	1,748		1	1	1			
	17:00	1,814		1	1	1			
	18:00	1,870		1	1	1			
	19:00	1,924		1	1	1			
	20:00	2,050		1	1	1			
	21:00	1,902		1	1	1			
	22:00	1,795		1	1	1			
	23:00	1,636		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 12 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Παρασκευή, 12 Σεπτεμβρίου 2025	00:00	1,457			1	1			
	01:00	1,367			1	1			
	02:00	1,310			1	1			
	03:00	1,242			1	1			
	04:00	1,189			1	1			
	05:00	1,239			1	1			
	06:00	1,273			1	1			
	07:00	1,338			1	1			
	08:00	1,466			1	1			
	09:00	1,604			1	1			
	10:00	1,727		1	1	1			
	11:00	1,773		1	1	1			
	12:00	1,764		1	1	1			
	13:00	1,809		1	1	1			
	14:00	1,863		1	1	1			
	15:00	1,783		1	1	1			
	16:00	1,794		1	1	1			
	17:00	1,876		1	1	1			
	18:00	2,000		1	1	1			
	19:00	2,113		1	1	1			
	20:00	2,194		1	1	1			
	21:00	2,068		1	1	1			
	22:00	1,899		1	1	1			
	23:00	1,772		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 13 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Σάββατο, 13 Σεπτεμβρίου 2025	00:00	1,583		1	1	1			
	01:00	1,455		1	1	1			
	02:00	1,401		1	1				
	03:00	1,344		1	1				
	04:00	1,282		1	1				
	05:00	1,285		1	1				
	06:00	1,308		1	1				
	07:00	1,381		1	1				
	08:00	1,526		1	1				
	09:00	1,643		1	1				
	10:00	1,653		1	1	1			
	11:00	1,691		1	1	1			
	12:00	1,748		1	1	1			
	13:00	1,822		1	1	1			
	14:00	1,827		1	1	1			
	15:00	1,779		1	1	1			
	16:00	1,788		1	1	1			
	17:00	1,783		1	1	1			
	18:00	1,826		1	1	1			
	19:00	1,949		1	1	1			
	20:00	2,068		1	1	1			
	21:00	1,970		1	1	1			
	22:00	1,800		1	1	1			
	23:00	1,644		1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 14 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ ρ ε π η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Κυριακή, 14 Σεπτεμβρίου 2025	00:00	1,481		1		1			
	01:00	1,368		1		1			
	02:00	1,316		1		1			
	03:00	1,268		1		1			
	04:00	1,223		1		1			
	05:00	1,262		1		1			
	06:00	1,253		1		1			
	07:00	1,321		1		1			
	08:00	1,466		1		1			
	09:00	1,532		1		1			
	10:00	1,608		1		1	1		
	11:00	1,614		1		1	1		
	12:00	1,642		1		1	1		
	13:00	1,657		1	1	1			
	14:00	1,645		1	1	1			
	15:00	1,633		1	1	1			
	16:00	1,642		1	1	1			
	17:00	1,650		1	1	1			
	18:00	1,677		1	1	1			
	19:00	1,809		1	1	1			
	20:00	1,885		1	1	1			
	21:00	1,708		1	1	1			
	22:00	1,577		1	1	1			
	23:00	1,444		1		1			

Το ΗΣ ΣΕΡΙΦΟΥ παρουσίαζε πρόβλημα επικοινωνίας κατά το διάστημα 9:02 με 9:

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 15 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Δευτέρα, 15 Σεπτεμβρίου 2025	00:00	1,278		1		1			
	01:00	1,167		1		1			
	02:00	1,122		1		1			
	03:00	1,086		1		1			
	04:00	1,040		1		1			
	05:00	1,104		1		1			
	06:00	1,146		1		1			
	07:00	1,195		1		1			
	08:00	1,370		1		1			
	09:00	1,496		1			1		
	10:00	1,512		1			1		
	11:00	1,517		1			1		
	12:00	1,521		1	1		1		
	13:00	1,544		1	1		1		
	14:00	1,555		1	1		1		
	15:00	1,483		1	1		1		
	16:00	1,507		1	1		1		
	17:00	1,554		1	1		1		
	18:00	1,608		1	1		1		
	19:00	1,796		1	1		1		
	20:00	1,851		1	1		1		
	21:00	1,718		1	1		1		
	22:00	1,555		1	1		1		
	23:00	1,383		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 16 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Τρίτη, 16 Σεπτεμβρίου 2025	00:00	1,257		1	1				
	01:00	1,172		1	1				
	02:00	1,136		1	1				
	03:00	1,087		1	1				
	04:00	1,064		1	1				
	05:00	1,104		1	1				
	06:00	1,158		1	1				
	07:00	1,243		1	1				
	08:00	1,403		1	1				
	09:00	1,457		1	1				
	10:00	1,473		1	1				
	11:00	1,449		1	1				
	12:00	1,517		1	1				
	13:00	1,493		1	1				
	14:00	1,477		1	1				
	15:00	1,419		1	1				
	16:00	1,458		1	1				
	17:00	1,544		1	1				
	18:00	1,637		1	1	1			
	19:00	1,739		1	1	1			
	20:00	1,800		1	1	1			
	21:00	1,652		1	1	1			
	22:00	1,460		1	1	1			
	23:00	1,351			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης