

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 16 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Τετάρτη, 16 Ιουλίου 2025	00:00	2,166		1	1	1				
	01:00	2,004		1	1	1				
	02:00	1,876		1	1	1				
	03:00	1,816		1	1	1				
	04:00	1,712		1	1	1				
	05:00	1,664		1	1	1				
	06:00	1,636		1	1	1				
	07:00	1,767		1	1	1				
	08:00	1,888		1	1	1				
	09:00	2,046		1	1					1
	10:00	2,104		1	1					1
	11:00	2,182		1	1					1
	12:00	2,171		1	1					1
	13:00	2,178		1	1					1
	14:00	2,195		1	1					1
	15:00	2,241		1	1					1
	16:00	2,234		1	1					1
	17:00	2,355		1	1			1		1
	18:00	2,435		1	1			1		1
	19:00	2,544		1	1			1		1
	20:00	2,523		1	1			1		1
	21:00	2,538		1	1			1		1
	22:00	2,445		1	1			1		1
	23:00	2,355		1	1			1		1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 17 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Ρ Ε Σ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Πέμπτη, 17 Ιουλίου 2025	00:00	2,244		1	1	1				
	01:00	2,057		1	1	1				
	02:00	1,927		1	1	1				
	03:00	1,813		1	1	1				
	04:00	1,714		1	1	1				
	05:00	1,643		1	1	1				
	06:00	1,634		1	1	1				
	07:00	1,760		1	1	1				
	08:00	1,903		1	1	1				
	09:00	2,086			1	1				1
	10:00	2,205			1	1				1
	11:00	2,275			1	1				1
	12:00	2,297			1	1				1
	13:00	2,278			1	1				1
	14:00	2,373			1	1				1
	15:00	2,382			1	1		1		1
	16:00	2,377			1	1		1		1
	17:00	2,494			1	1		1		1
	18:00	2,601			1	1		1		1
	19:00	2,718			1	1		1		1
	20:00	2,734			1	1		1		1
	21:00	2,738			1	1		1		1
	22:00	2,649			1	1		1		1
	23:00	2,461			1	1		1		1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 18 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Παρασκευή, 18 Ιουλίου 2025	00:00	2,278			1	1		1		
	01:00	2,101			1	1		1		
	02:00	1,959			1	1		1		
	03:00	1,857			1	1		1		
	04:00	1,753			1	1		1		
	05:00	1,741			1	1		1		
	06:00	1,667			1	1		1		
	07:00	1,791		1	1	1				
	08:00	2,023		1	1	1				
	09:00	2,282		1	1	1				
	10:00	2,383		1	1	1				
	11:00	2,387		1	1	1				1
	12:00	2,464		1	1	1				1
	13:00	2,484		1	1	1				1
	14:00	2,518		1	1	1				1
	15:00	2,564		1	1	1				1
	16:00	2,538		1	1	1				1
	17:00	2,558		1	1	1				1
	18:00	2,750		1	1	1				1
	19:00	2,879		1	1	1				1
	20:00	2,856		1	1	1				1
	21:00	2,899		1	1	1				1
	22:00	2,760		1	1	1				1
	23:00	2,596		1	1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 19 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Σάββατο, 19 Ιουλίου 2025	00:00	2,322		1	1	1				
	01:00	2,155		1	1	1				
	02:00	1,990		1	1	1				
	03:00	1,895		1	1	1				
	04:00	1,764		1	1	1				
	05:00	1,752		1	1	1				
	06:00	1,705		1	1	1				
	07:00	1,873		1	1	1				
	08:00	2,113		1	1	1				
	09:00	2,291		1	1	1				
	10:00	2,444		1	1	1				1
	11:00	2,493		1	1	1				1
	12:00	2,489		1	1	1				1
	13:00	2,497		1	1	1				1
	14:00	2,524		1	1	1				1
	15:00	2,523		1	1	1				1
	16:00	2,605		1	1	1				1
	17:00	2,676		1	1	1				1
	18:00	2,764		1	1	1				1
	19:00	2,918		1	1	1				1
	20:00	2,914		1	1	1				1
	21:00	2,966		1	1	1				1
	22:00	2,765		1	1	1				1
	23:00	2,601		1	1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 20 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Κυριακή, 20 Ιουλίου 2025	00:00	2,396		1	1	1			1	
	01:00	2,204		1		1			1	
	02:00	2,117		1		1			1	
	03:00	2,022		1		1			1	
	04:00	2,011		1		1			1	
	05:00	1,935		1		1			1	
	06:00	1,940		1		1			1	
	07:00	1,988		1		1			1	
	08:00	2,149		1		1			1	
	09:00	2,320		1		1			1	
	10:00	2,436		1		1			1	1
	11:00	2,478		1		1			1	1
	12:00	2,516		1		1			1	1
	13:00	2,502		1		1			1	1
	14:00	2,503		1		1			1	1
	15:00	2,507		1		1			1	1
	16:00	2,610		1		1			1	1
	17:00	2,644		1		1			1	1
	18:00	2,740		1		1			1	1
	19:00	2,842		1		1			1	1
	20:00	2,800		1		1			1	1
	21:00	2,815		1		1			1	1
	22:00	2,680		1		1			1	1
	23:00	2,589		1		1			1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 21 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Δευτέρα, 21 Ιουλίου 2025	00:00	2,373		1		1			1	
	01:00	2,119		1		1			1	
	02:00	2,020		1		1			1	
	03:00	1,885		1		1			1	
	04:00	1,807		1		1			1	
	05:00	1,815		1		1			1	
	06:00	1,761		1		1			1	
	07:00	1,910		1		1			1	
	08:00	2,130		1		1			1	
	09:00	2,325		1	1	1			1	
	10:00	2,510		1	1	1				1
	11:00	2,564		1	1	1				1
	12:00	2,546		1	1	1	1			1
	13:00	2,591		1	1	1	1			1
	14:00	2,694		1	1	1				1
	15:00	2,700		1	1	1				1
	16:00	2,762		1	1	1				1
	17:00	2,880		1	1	1				1
	18:00	2,924		1	1	1				1
	19:00	3,018		1	1	1				1
	20:00	2,992		1	1	1				1
	21:00	3,044		1	1	1				1
	22:00	2,971		1	1	1				1
	23:00	2,896		1	1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 22 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Τρίτη, 22 Ιουλίου 2025	00:00	2,669		1	1	1				1
	01:00	2,483		1	1	1				
	02:00	2,285		1	1	1				
	03:00	2,144		1	1	1				
	04:00	2,003		1	1	1				
	05:00	1,944		1	1	1				
	06:00	1,880		1	1	1				
	07:00	2,010		1	1	1				
	08:00	2,167		1	1	1				
	09:00	2,237		1	1	1				
	10:00	2,705		1	1	1	1			
	11:00	2,827		1	1	1	1			
	12:00	2,822		1	1	1	1			
	13:00	2,783		1	1	1	1			1
	14:00	2,872		1	1	1	1			1
	15:00	2,876		1	1	1	1			1
	16:00	2,938		1	1	1	1			1
	17:00	2,967		1	1	1	1			1
	18:00	3,097		1	1	1	1			1
	19:00	3,209		1	1	1	1			1
	20:00	3,148		1	1	1	1			1
	21:00	3,234		1	1	1	1			1
	22:00	3,180		1	1	1	1			1
	23:00	3,150		1	1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης