

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 27 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Τετάρτη, 27 Αυγούστου 2025	00:00	1,827		1	1	1				
	01:00	1,709		1	1	1				
	02:00	1,553		1	1	1				
	03:00	1,501		1	1	1				
	04:00	1,457		1	1	1				
	05:00	1,433		1	1	1				
	06:00	1,450		1	1	1				
	07:00	1,561		1	1	1				
	08:00	1,742		1	1	1				
	09:00	1,898		1	1	1				
	10:00	1,945		1		1				1
	11:00	1,979		1		1				1
	12:00	1,955		1		1				1
	13:00	2,031		1		1				1
	14:00	2,015		1		1				1
	15:00	1,977		1		1				1
	16:00	1,948		1		1				1
	17:00	2,017		1		1				1
	18:00	2,182		1		1				1
	19:00	2,300		1		1				1
	20:00	2,435		1	1	1				1
	21:00	2,330		1	1	1				1
	22:00	2,079		1	1	1				1
	23:00	1,920		1	1	1				

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 28 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Πέμπτη, 28 Αυγούστου 2025	00:00	1,720		1	1	1				
	01:00	1,583		1	1	1				
	02:00	1,486		1	1	1				
	03:00	1,403		1	1					
	04:00	1,382		1	1					
	05:00	1,330		1	1					
	06:00	1,364		1	1					
	07:00	1,468		1	1					
	08:00	1,648		1	1					
	09:00	1,875		1	1					1
	10:00	1,931		1	1					1
	11:00	1,980		1	1					1
	12:00	1,995		1	1					1
	13:00	2,032		1	1					1
	14:00	2,013		1	1					1
	15:00	1,957		1	1					1
	16:00	1,937		1	1					1
	17:00	2,064		1	1					1
	18:00	2,163		1	1					1
	19:00	2,353		1	1	1				1
	20:00	2,434		1	1	1				1
	21:00	2,247		1	1	1				1
	22:00	2,051		1	1	1				1
	23:00	1,879		1	1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 29 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η Ρ Ε Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Παρασκευή, 29 Αυγούστου 2025	00:00	1,648		1	1	1				
	01:00	1,519		1	1	1				
	02:00	1,404		1	1					
	03:00	1,321		1	1					
	04:00	1,280		1	1					
	05:00	1,268		1	1					
	06:00	1,286		1	1					
	07:00	1,387		1	1					
	08:00	1,575		1	1					
	09:00	1,717		1	1					1
	10:00	1,872		1	1					1
	11:00	1,895		1	1					1
	12:00	1,870		1	1					1
	13:00	1,870		1	1					1
	14:00	1,947		1	1					1
	15:00	1,909		1	1					1
	16:00	1,894		1	1					1
	17:00	1,978		1	1					1
	18:00	2,094		1	1					1
	19:00	2,290		1	1	1				1
	20:00	2,443		1	1	1				1
	21:00	2,319		1	1	1				1
	22:00	2,059		1	1	1				1
	23:00	1,846		1		1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 30 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Σάββατο, 30 Αυγούστου 2025	00:00	1,631		1		1				1
	01:00	1,440		1		1				
	02:00	1,361		1		1				
	03:00	1,282		1		1				
	04:00	1,275		1		1				
	05:00	1,268		1		1				
	06:00	1,287		1		1				
	07:00	1,378		1		1				
	08:00	1,611		1		1				
	09:00	1,830		1		1				1
	10:00	1,955		1		1				1
	11:00	2,054		1		1				1
	12:00	2,063		1		1				1
	13:00	2,110		1		1				1
	14:00	2,057		1		1				1
	15:00	2,008		1		1				1
	16:00	1,981		1		1				1
	17:00	2,095		1		1				1
	18:00	2,188		1		1				1
	19:00	2,366		1		1		1		1
	20:00	2,482		1		1		1		1
	21:00	2,342		1		1		1		1
	22:00	2,147		1		1		1		1
	23:00	1,989		1		1		1		1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 31 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Κυριακή, 31 Αυγούστου 2025	00:00	1,742		1		1		1		
	01:00	1,568		1		1		1		
	02:00	1,482		1		1				
	03:00	1,418		1		1				
	04:00	1,379		1		1				
	05:00	1,406		1		1				
	06:00	1,427		1		1				
	07:00	1,480		1		1				
	08:00	1,706		1		1				
	09:00	1,878		1		1				1
	10:00	1,996		1		1				1
	11:00	2,118		1		1				1
	12:00	2,098		1		1				1
	13:00	2,086		1		1				1
	14:00	2,094		1		1				1
	15:00	2,046		1		1				1
	16:00	2,065		1		1				1
	17:00	2,139		1		1				1
	18:00	2,259		1		1		1		1
	19:00	2,336		1		1		1		1
	20:00	2,463		1		1		1		1
	21:00	2,362		1		1		1		1
	22:00	2,147		1				1		1
	23:00	1,997		1				1		1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 1 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	
Δευτέρα, 1 Σεπτεμβρίου 2025	00:00	1,774		1	1			1		
	01:00	1,615		1	1			1		
	02:00	1,480		1				1		
	03:00	1,401		1				1		
	04:00	1,364		1				1		
	05:00	1,375		1				1		
	06:00	1,389		1				1		
	07:00	1,463		1				1		
	08:00	1,654		1				1		
	09:00	1,895		1	1			1		
	10:00	1,955		1	1			1		
	11:00	2,008		1	1			1		
	12:00	1,988		1	1			1		
	13:00	2,011		1	1			1		
	14:00	2,048		1	1			1		
	15:00	2,052		1	1			1		
	16:00	2,030		1	1			1		
	17:00	2,088		1	1			1		
	18:00	2,131		1	1			1		
	19:00	2,243		1	1			1		
	20:00	2,369		1	1			1		
	21:00	2,287		1	1			1		
	22:00	2,126		1	1			1		
	23:00	1,980		1	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 2 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	
Τρίτη, 2 Σεπτεμβρίου 2025	00:00	1,726		1	1			1		
	01:00	1,571		1	1			1		
	02:00	1,464			1			1		
	03:00	1,390			1			1		
	04:00	1,335			1			1		
	05:00	1,347			1			1		
	06:00	1,384			1			1		
	07:00	1,394			1			1		
	08:00	1,580			1			1		
	09:00	1,843		1	1			1		
	10:00	1,914		1	1			1		
	11:00	1,924		1	1			1		
	12:00	1,960		1	1			1		
	13:00	1,939		1	1			1		
	14:00	2,005		1	1			1		
	15:00	1,904		1	1			1		
	16:00	1,969		1	1			1		
	17:00	1,999		1	1			1		
	18:00	2,089		1	1			1		
	19:00	2,162		1	1			1		
	20:00	2,279		1	1			1		
	21:00	2,209		1	1			1		
	22:00	2,057		1	1			1		
	23:00	1,918		1	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης