

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 19 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)
Τρίτη, 19 Αυγούστου 2025	00:00	2,607	1			1					1	
	01:00	2,421	1			1					1	
	02:00	2,298	1			1					1	
	03:00	2,224	1			1					1	
	04:00	2,172	1			1					1	
	05:00	2,161	1			1					1	
	06:00	2,137	1			1					1	
	07:00	2,277				1					1	1
	08:00	2,605	1			1					1	1
	09:00	2,791	1			1					1	1
	10:00	2,959	1			1					1	1
	11:00	3,040	1			1					1	1
	12:00	3,162	1			1					1	1
	13:00	3,238	1			1					1	1
	14:00	3,310	1			1					1	1
	15:00	3,245	1			1					1	1
	16:00	3,094	1			1					1	1
	17:00	3,104	1			1					1	1
	18:00	3,261	1			1	1				1	1
	19:00	3,381	1			1	1				1	1
	20:00	3,461	1			1	1				1	1
	21:00	3,335	1			1	1				1	1
	22:00	3,188	1				1				1	1
	23:00	3,013	1				1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 20 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000	
Η Ρ Ε Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)	
Τετάρτη, 20 Αυγούστου 2025	00:00	2,829	1			1	1				1		
	01:00	2,642	1			1	1				1		
	02:00	2,511	1			1	1				1		
	03:00	2,429	1				1				1		
	04:00	2,402	1				1				1		
	05:00	2,358	1				1				1		
	06:00	2,289	1				1				1		
	07:00	2,465					1				1	1	
	08:00	2,673					1				1	1	
	09:00	2,709					1				1	1	
	10:00	2,861	1				1				1	1	
	11:00	2,927	1				1				1	1	
	12:00	3,141	1				1				1	1	
	13:00	3,223	1				1				1	1	
	14:00	3,208	1				1				1	1	
	15:00	3,173	1				1				1	1	
	16:00	3,110	1				1				1	1	
	17:00	3,164	1				1				1	1	
	18:00	3,311	1				1				1	1	
	19:00	3,392	1				1	1				1	1
	20:00	3,380	1				1	1				1	1
	21:00	3,147	1				1	1				1	1
	22:00	2,974	1					1				1	1
	23:00	2,912	1					1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Απολογισμός Λειτουργίας			Πέμπτη, 21 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000			
Ρ	Θ	Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	ΗΖ (x1)	
Πέμπτη, 21 Αυγούστου 2025			00:00	2,796	1			1	1				1		
			01:00	2,709	1			1	1				1		
			02:00	2,530	1			1	1				1		
			03:00	2,372	1			1	1				1		
			04:00	2,278	1			1					1		
			05:00	2,240	1			1					1		
			06:00	2,209	1			1					1		
			07:00	2,363	1								1	1	
			08:00	2,592	1								1	1	
			09:00	2,701	1								1	1	
			10:00	2,836	1						1			1	1
			11:00	2,970	1						1			1	1
			12:00	3,052	1						1			1	1
			13:00	3,278	1						1			1	1
			14:00	3,355	1						1			1	1
			15:00	3,272	1						1			1	1
			16:00	3,211	1						1			1	1
			17:00	3,202	1						1			1	1
			18:00	3,430	1					1	1			1	1
			19:00	3,468	1					1	1			1	1
			20:00	3,489	1					1	1			1	1
			21:00	3,379	1					1	1			1	1
			22:00	3,200	1						1			1	1
			23:00	3,060	1						1			1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 22 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Α Π Ο Λ Ο Γ Ι Σ Μ Ο Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Παρασκευή, 22 Αυγούστου 2025	00:00	2,890	1			1	1				1	
	01:00	2,708	1			1	1				1	
	02:00	2,598	1			1	1				1	
	03:00	2,512	1			1	1				1	
	04:00	2,407	1				1				1	
	05:00	2,292	1				1				1	
	06:00	2,306	1				1				1	
	07:00	2,462					1				1	1
	08:00	2,813	1				1				1	1
	09:00	2,945	1				1				1	1
	10:00	3,017	1				1				1	1
	11:00	3,201	1				1				1	1
	12:00	3,352	1				1				1	1
	13:00	3,406	1				1				1	1
	14:00	3,488	1			1	1				1	1
	15:00	3,390	1			1	1				1	1
	16:00	3,267	1			1	1				1	1
	17:00	3,251	1			1	1				1	1
	18:00	3,356	1			1	1				1	1
	19:00	3,402	1			1	1				1	1
	20:00	3,507	1			1	1				1	1
	21:00	3,400	1			1	1				1	1
	22:00	3,130	1			1	1				1	1
	23:00	3,006	1				1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 23 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)
Σάββατο, 23 Αυγούστου 2025	00:00	2,786	1			1	1				1	
	01:00	2,584	1			1	1				1	
	02:00	2,464	1			1	1				1	
	03:00	2,327	1				1				1	
	04:00	2,214	1				1				1	
	05:00	2,222	1				1				1	
	06:00	2,207	1				1				1	
	07:00	2,338					1				1	1
	08:00	2,561					1				1	1
	09:00	2,711	1				1				1	1
	10:00	2,881	1				1				1	1
	11:00	3,094	1				1				1	1
	12:00	3,214	1				1				1	1
	13:00	3,309	1				1				1	1
	14:00	3,353	1				1				1	1
	15:00	3,195	1				1				1	1
	16:00	3,097	1				1				1	1
	17:00	3,023	1				1				1	1
	18:00	3,442	1			1	1				1	1
	19:00	3,511	1			1	1				1	1
	20:00	3,528	1			1	1				1	1
	21:00	3,244	1				1				1	1
	22:00	3,015	1				1				1	1
	23:00	2,857	1				1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 24 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Κυριακή, 24 Αυγούστου 2025	00:00	2,740	1				1	1			1	
	01:00	2,525	1				1	1			1	
	02:00	2,496	1				1	1			1	
	03:00	2,512	1				1	1			1	
	04:00	2,424	1				1	1				
	05:00	2,376	1				1	1				
	06:00	2,283	1				1	1				
	07:00	2,414	1					1			1	
	08:00	2,600	1					1			1	
	09:00	2,732	1					1			1	
	10:00	2,845	1					1			1	1
	11:00	2,927	1					1			1	1
	12:00	2,993	1					1			1	1
	13:00	3,001	1					1			1	1
	14:00	3,038	1					1			1	1
	15:00	2,928	1					1			1	1
	16:00	2,794	1					1			1	1
	17:00	2,773	1					1			1	1
	18:00	2,891	1					1			1	1
	19:00	2,995	1					1			1	1
	20:00	3,070	1					1			1	1
	21:00	2,966	1					1			1	1
	22:00	2,838	1					1			1	1
	23:00	2,740	1					1			1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 25 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Ε Τ Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Δευτέρα, 25 Αυγούστου 2025	00:00	2,676	1			1	1				1	
	01:00	2,419	1			1	1				1	
	02:00	2,262	1				1				1	
	03:00	2,162	1				1				1	
	04:00	2,114	1				1				1	
	05:00	2,114	1				1				1	
	06:00	2,142	1				1				1	
	07:00	2,238	1								1	1
	08:00	2,512	1								1	1
	09:00	2,764	1				1				1	1
	10:00	2,807	1				1				1	1
	11:00	2,928	1				1				1	1
	12:00	3,058	1				1				1	1
	13:00	3,244	1				1				1	1
	14:00	3,223	1				1				1	1
	15:00	3,146	1				1				1	1
	16:00	3,053	1				1				1	1
	17:00	3,101	1				1				1	1
	18:00	3,179	1				1	1			1	1
	19:00	3,239	1				1	1			1	1
	20:00	3,270	1				1	1			1	1
	21:00	3,159	1				1	1			1	1
	22:00	2,908	1				1	1			1	
	23:00	2,911	1				1	1			1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης