

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 2 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 2 Σεπτεμβρίου 2025	00:00	2,292	1				1				1
	01:00	2,147	1				1				1
	02:00	2,073	1				1				1
	03:00	2,015	1				1				1
	04:00	1,961	1				1				1
	05:00	1,953	1				1				1
	06:00	1,950	1				1				1
	07:00	2,057	1				1				1
	08:00	2,249	1				1				1
	09:00	2,452				1	1				1
	10:00	2,523	1				1		1		1
	11:00	2,653	1				1		1		1
	12:00	2,842	1				1		1		1
	13:00	2,959	1				1		1		1
	14:00	2,972	1				1		1		1
	15:00	2,863	1				1		1		1
	16:00	2,776	1				1		1		1
	17:00	2,725	1				1		1		1
	18:00	2,796	1				1		1		1
	19:00	2,837	1				1		1		1
	20:00	2,911	1				1		1		1
	21:00	2,773	1				1		1		1
	22:00	2,700	1				1		1		1
	23:00	2,626	1				1		1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 3 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 3 Σεπτεμβρίου 2025	00:00	2,446				1	1		1		1
	01:00	2,294				1	1				1
	02:00	2,189				1	1				1
	03:00	2,126				1	1				1
	04:00	2,076				1	1				1
	05:00	2,028				1	1				1
	06:00	2,003				1	1				1
	07:00	2,185				1	1				1
	08:00	2,379				1	1				1
	09:00	2,573				1	1	1			1
	10:00	2,827				1	1	1			1
	11:00	2,907				1	1	1			1
	12:00	3,020				1	1	1			1
	13:00	3,181				1	1	1			1
	14:00	3,168				1	1	1			1
	15:00	3,040				1	1	1			1
	16:00	3,027				1	1	1			1
	17:00	3,098				1	1	1			1
	18:00	3,205				1	1	1			1
	19:00	3,276				1	1	1			1
	20:00	3,245				1	1	1			1
	21:00	3,195				1	1	1			1
	22:00	3,110				1	1	1			1
	23:00	2,894				1	1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 4 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 4 Σεπτεμβρίου 2025	00:00	2,664				1	1	1			1
	01:00	2,489				1	1	1			1
	02:00	2,373				1		1			1
	03:00	2,297				1		1			1
	04:00	2,226				1		1			1
	05:00	2,207				1		1			1
	06:00	2,060				1		1			1
	07:00	2,268				1		1			1
	08:00	2,506				1	1	1			1
	09:00	2,540				1	1			1	1
	10:00	2,626				1	1			1	1
	11:00	2,705				1	1			1	1
	12:00	2,845	1				1		1		1
	13:00	2,963	1				1		1		1
	14:00	3,040	1				1		1		1
	15:00	2,858	1				1		1		1
	16:00	2,748	1				1		1		1
	17:00	2,722	1				1		1		1
	18:00	2,919	1				1		1		1
	19:00	2,923	1				1		1		1
	20:00	2,975	1				1		1		1
	21:00	2,820	1				1		1		1
	22:00	2,735	1				1		1		1
	23:00	2,468	1				1		1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 5 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Α Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 5 Σεπτεμβρίου 2025	00:00	2,192	1				1				1
	01:00	2,088	1				1				1
	02:00	1,991	1				1				1
	03:00	1,917	1				1				1
	04:00	1,852	1				1				1
	05:00	1,841	1				1				1
	06:00	1,869	1				1				1
	07:00	1,992	1				1				1
	08:00	2,278	1				1				1
	09:00	2,533	1				1	1			1
	10:00	2,563	1				1	1			1
	11:00	2,707	1				1	1			1
	12:00	2,851	1				1	1			1
	13:00	3,017	1				1	1			1
	14:00	3,000	1				1	1			1
	15:00	2,803	1				1	1			1
	16:00	2,669	1				1	1			1
	17:00	2,620	1				1	1			1
	18:00	2,787	1				1	1			1
	19:00	2,920	1				1	1			1
	20:00	2,992	1				1	1			1
	21:00	2,812	1				1	1			1
	22:00	2,739	1				1	1			1
	23:00	2,643	1				1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 6 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 6 Σεπτεμβρίου 2025	00:00	2,283	1				1				1
	01:00	2,247	1				1				1
	02:00	2,209	1				1				1
	03:00	2,081	1				1				1
	04:00	1,860	1				1				1
	05:00	1,707	1				1				1
	06:00	1,632	1				1				1
	07:00	1,693	1				1				1
	08:00	1,823	1				1				1
	09:00	2,167	1				1				1
	10:00	2,353	1				1				1
	11:00	2,771	1				1	1			1
	12:00	2,865	1				1	1			1
	13:00	2,927	1				1	1			1
	14:00	2,940	1				1	1			1
	15:00	2,945	1				1	1			1
	16:00	2,893	1				1	1			1
	17:00	2,859	1				1	1			1
	18:00	2,962	1				1	1			1
	19:00	3,005	1				1	1			1
	20:00	3,058	1				1	1			1
	21:00	3,014	1				1	1			1
	22:00	2,923	1				1	1			1
	23:00	2,842	1				1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 7 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 7 Σεπτεμβρίου 2025	00:00	2,540	1				1	1			1
	01:00	2,330	1				1				1
	02:00	2,300	1				1				1
	03:00	2,221	1				1				1
	04:00	2,251	1				1				1
	05:00	2,202	1				1				1
	06:00	2,148	1				1				1
	07:00	2,236	1				1				1
	08:00	2,283	1				1				1
	09:00	2,366	1				1				1
	10:00	2,283	1				1				1
	11:00	2,437	1				1				1
	12:00	2,658	1				1	1			1
	13:00	2,702	1				1	1			1
	14:00	2,710	1				1	1			1
	15:00	2,769	1				1	1			1
	16:00	2,779	1				1	1			1
	17:00	2,742	1				1	1			1
	18:00	2,771	1				1	1			1
	19:00	2,821	1				1	1			1
	20:00	2,824	1				1	1			1
	21:00	2,790	1				1	1			1
	22:00	2,464	1				1				1
	23:00	2,377	1				1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 8 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 8 Σεπτεμβρίου 2025	00:00	2,302	1				1				1
	01:00	2,233	1				1				1
	02:00	2,139	1				1				1
	03:00	2,075	1				1				1
	04:00	2,022	1				1				1
	05:00	2,037	1				1		1		
	06:00	1,986	1				1		1		
	07:00	2,169	1				1		1		
	08:00	2,353	1				1		1		
	09:00	2,314	1				1		1		
	10:00	2,382	1				1		1		
	11:00	2,504	1				1		1		
	12:00	2,738	1				1		1		1
	13:00	2,897	1				1		1		1
	14:00	2,911	1				1		1		1
	15:00	2,784	1				1		1		1
	16:00	2,723	1				1		1		1
	17:00	2,731	1				1		1		1
	18:00	2,875	1				1		1		1
	19:00	2,935	1				1		1		1
	20:00	2,922	1				1		1		1
	21:00	2,716	1				1		1		1
	22:00	2,737	1				1		1		1
	23:00	2,533	1				1		1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης