

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 5 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ ε τ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τρίτη, 5 Αυγούστου 2025	00:00	3,131	1			1	1				1	
	01:00	2,888	1			1	1				1	
	02:00	2,739	1			1	1				1	
	03:00	2,629	1			1	1				1	
	04:00	2,573	1			1	1				1	
	05:00	2,522	1			1	1				1	
	06:00	2,422	1			1	1				1	
	07:00	2,567	1			1	1				1	
	08:00	2,799				1	1				1	1
	09:00	3,089				1	1				1	1
	10:00	3,116				1	1				1	1
	11:00	3,189				1	1				1	1
	12:00	3,294				1	1				1	1
	13:00	3,487	1			1	1				1	1
	14:00	3,572	1			1	1				1	1
	15:00	3,503	1			1	1				1	1
	16:00	3,451	1			1	1				1	1
	17:00	3,412	1			1	1				1	1
	18:00	3,548	1			1	1				1	1
	19:00	3,509	1			1	1				1	1
	20:00	3,522	1			1	1				1	1
	21:00	3,376	1			1	1				1	1
	22:00	3,216	1			1	1				1	1
	23:00	3,098	1			1	1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 6 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000		
Ρ	Θ	Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τετάρτη, 6 Αυγούστου 2025			00:00	3,033	1			1	1				1	
			01:00	2,869	1			1	1				1	
			02:00	2,738	1			1	1				1	
			03:00	2,609	1			1	1				1	
			04:00	2,556	1			1	1				1	
			05:00	2,511	1			1	1				1	
			06:00	2,390	1			1	1				1	
			07:00	2,606	1			1	1				1	
			08:00	2,862	1				1				1	1
			09:00	2,997	1				1				1	1
			10:00	3,170	1				1				1	1
			11:00	3,207	1				1				1	1
			12:00	3,371	1			1	1				1	1
			13:00	3,452	1			1	1				1	1
			14:00	3,448	1			1	1				1	1
			15:00	3,395	1			1	1				1	1
			16:00	3,275	1			1	1				1	1
			17:00	3,256	1			1	1				1	1
			18:00	3,400	1			1	1				1	1
			19:00	3,421	1			1	1				1	1
			20:00	3,455	1			1	1				1	1
			21:00	3,308	1			1	1				1	1
			22:00	3,168	1			1	1				1	1
			23:00	3,068	1			1	1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 7 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Πέμπτη, 7 Αυγούστου 2025	00:00	2,938	1			1	1				1	1
	01:00	2,764	1			1					1	1
	02:00	2,627	1			1					1	1
	03:00	2,559	1			1					1	1
	04:00	2,482	1			1					1	1
	05:00	2,441	1			1					1	1
	06:00	2,345	1			1					1	1
	07:00	2,475	1			1					1	1
	08:00	2,791	1			1					1	1
	09:00	3,034	1				1				1	1
	10:00	3,222	1				1				1	1
	11:00	3,407	1			1	1				1	1
	12:00	3,514	1			1	1				1	1
	13:00	3,613	1			1	1				1	1
	14:00	3,666	1			1	1				1	1
	15:00	3,584	1			1	1				1	1
	16:00	3,564	1			1	1				1	1
	17:00	3,648	1			1	1				1	1
	18:00	3,789	1			1	1				1	1
	19:00	3,751	1			1	1				1	1
	20:00	3,869	1			1	1				1	1
	21:00	3,766	1			1	1				1	1
	22:00	3,667	1			1	1				1	1
	23:00	3,576	1			1	1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 8 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Παρασκευή, 8 Αυγούστου 2025	00:00	3,389	1			1	1				1	1
	01:00	3,202	1			1	1				1	1
	02:00	3,074	1			1	1				1	
	03:00	2,950	1			1	1				1	
	04:00	2,846	1			1	1				1	
	05:00	2,764	1			1	1				1	
	06:00	2,626	1			1	1				1	
	07:00	2,848	1			1	1				1	1
	08:00	3,113	1			1	1				1	1
	09:00	3,323	1			1	1				1	1
	10:00	3,425	1			1	1				1	1
	11:00	3,541	1			1	1				1	1
	12:00	3,671	1			1	1				1	1
	13:00	3,769	1			1	1				1	1
	14:00	3,815	1			1	1				1	1
	15:00	3,790	1			1	1				1	1
	16:00	3,756	1			1	1				1	1
	17:00	3,704	1			1	1				1	1
	18:00	3,856	1			1	1				1	1
	19:00	3,926	1			1	1	1			1	1
	20:00	4,073	1			1	1	1			1	1
	21:00	4,020	1			1	1	1			1	1
	22:00	3,885	1			1	1	1			1	1
	23:00	3,807	1			1	1	1			1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 9 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000		
Ρ	Θ	Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Σάββατο, 9 Αυγούστου 2025			00:00	3,631	1			1	1	1			1	
			01:00	3,406	1			1	1	1			1	
			02:00	3,274	1			1	1	1			1	
			03:00	3,193	1			1	1	1			1	
			04:00	3,094	1				1	1			1	
			05:00	2,991	1				1	1			1	
			06:00	2,834	1				1	1			1	
			07:00	2,999	1				1	1			1	
			08:00	3,235	1				1	1			1	1
			09:00	3,500	1				1	1			1	1
			10:00	3,531	1				1	1			1	1
			11:00	3,702	1				1	1			1	1
			12:00	3,836	1				1	1			1	1
			13:00	3,936	1				1	1			1	1
			14:00	4,062	1				1	1			1	1
			15:00	4,023	1			1	1	1			1	1
			16:00	3,917	1			1	1	1			1	1
			17:00	3,966	1			1	1	1			1	1
			18:00	4,183	1			1	1	1			1	1
			19:00	4,208	1			1	1	1			1	1
			20:00	4,196	1			1	1	1			1	1
			21:00	4,067	1			1	1	1			1	1
			22:00	3,941	1			1	1	1			1	1
			23:00	3,843	1			1	1	1			1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 10 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Ε Τ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Κυριακή, 10 Αυγούστου 2025	00:00	3,744	1			1	1	1			1	
	01:00	3,610	1			1	1	1			1	
	02:00	3,426	1			1	1	1			1	
	03:00	3,337	1			1	1	1			1	
	04:00	3,214	1				1	1			1	
	05:00	3,133	1				1	1			1	
	06:00	2,983	1				1	1			1	
	07:00	3,127	1				1	1			1	
	08:00	3,386	1			1	1				1	1
	09:00	3,570	1			1	1				1	1
	10:00	3,664	1			1	1				1	1
	11:00	3,820	1			1	1				1	1
	12:00	3,894	1			1	1				1	1
	13:00	3,981	1			1	1				1	1
	14:00	3,993	1			1	1				1	1
	15:00	3,932	1			1	1				1	1
	16:00	3,923	1			1	1				1	1
	17:00	3,992	1			1	1				1	1
	18:00	4,157	1			1	1	1			1	1
	19:00	4,179	1			1	1	1			1	1
	20:00	4,216	1			1	1	1			1	1
	21:00	4,183	1			1	1				1	1
	22:00	4,142	1			1	1				1	1
	23:00	3,893	1			1	1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 11 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000	
Η Ρ Ε Ρ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)	
Δευτέρα, 11 Αυγούστου 2025	00:00	3,668	1			1	1	1			1		
	01:00	3,441	1			1	1	1			1		
	02:00	3,258	1			1	1	1					
	03:00	3,108	1			1	1	1					
	04:00	2,974	1			1	1	1					
	05:00	2,856	1			1	1	1					
	06:00	2,794	1			1	1	1				1	
	07:00	2,899	1			1	1	1				1	
	08:00	3,319	1			1	1					1	
	09:00	3,538	1			1	1					1	
	10:00	3,608	1			1	1					1	1
	11:00	3,674	1			1	1					1	1
	12:00	3,866	1			1	1					1	1
	13:00	3,989	1			1	1					1	1
	14:00	3,953	1			1	1					1	1
	15:00	3,896	1			1	1					1	1
	16:00	3,764	1			1	1					1	1
	17:00	3,766	1			1	1					1	1
	18:00	3,955	1			1	1					1	1
	19:00	3,905	1			1	1					1	1
	20:00	4,073	1			1	1					1	1
	21:00	3,995	1			1	1					1	1
	22:00	3,895	1			1	1					1	1
	23:00	3,799	1			1	1					1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης