

ΗΣ ΣΥΜΗΣ			Απολογισμός Λειτουργίας			Τρίτη, 12 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000	
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)	
Τρίτη, 12 Αυγούστου 2025	00:00	3,565	1			1	1	1			1		
	01:00	3,291	1				1	1			1		
	02:00	3,129	1				1	1			1		
	03:00	3,031	1				1	1			1		
	04:00	2,877	1				1	1			1		
	05:00	2,751	1				1	1			1		
	06:00	2,705	1				1	1			1		
	07:00	2,790	1				1			1	1		
	08:00	3,244	1				1			1	1		
	09:00	3,509	1				1	1		1		1	
	10:00	3,573	1				1	1		1		1	
	11:00	3,698	1				1	1		1		1	
	12:00	3,820	1				1	1		1		1	
	13:00	3,983	1				1	1	1	1		1	
	14:00	4,057	1				1	1	1	1		1	
	15:00	4,037	1				1	1	1			1	
	16:00	3,917	1				1	1	1			1	
	17:00	3,925	1				1	1	1		1	1	
	18:00	4,056	1				1	1			1	1	
	19:00	4,143	1				1	1			1	1	
	20:00	4,152	1				1	1			1	1	
	21:00	4,000	1				1	1			1	1	
	22:00	3,825	1				1	1			1	1	
	23:00	3,735	1				1	1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 13 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Ε Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τετάρτη, 13 Αυγούστου 2025	00:00	3,573	1			1	1		1		1	
	01:00	3,375	1			1	1		1		1	
	02:00	3,215				1	1		1		1	
	03:00	3,054				1	1		1		1	
	04:00	2,979				1	1		1		1	
	05:00	2,889				1	1		1		1	
	06:00	2,755				1	1		1		1	
	07:00	2,848				1	1			1	1	
	08:00	3,167				1	1			1	1	
	09:00	3,376	1			1	1			1	1	
	10:00	3,519	1			1	1			1	1	
	11:00	3,645	1			1	1			1	1	
	12:00	3,813	1			1	1			1	1	
	13:00	3,918	1			1	1			1	1	
	14:00	3,918	1			1	1			1	1	
	15:00	3,499	1			1	1		1		1	
	16:00	3,610	1			1	1	1			1	
	17:00	3,689	1			1	1	1			1	
	18:00	3,867	1			1	1	1			1	
	19:00	3,976	1			1	1	1		1	1	
	20:00	4,180	1			1	1	1		1	1	
	21:00	3,925	1			1	1	1		1	1	
	22:00	3,692	1			1	1			1	1	
	23:00	3,531	1			1	1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 14 Αυγούστου 2025											
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000				
Ρ	Θ	Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)		
Πέμπτη, 14 Αυγούστου 2025		00:00	3,523	1			1	1				1	1			
		01:00	3,348	1			1	1						1		
		02:00	3,194	1				1	1						1	
		03:00	3,046	1				1	1						1	
		04:00	2,938	1				1	1						1	
		05:00	2,814	1				1	1						1	
		06:00	2,698	1				1	1						1	
		07:00	2,834	1					1					1	1	
		08:00	3,128	1					1					1	1	
		09:00	3,402	1				1	1					1	1	
		10:00	3,542	1				1	1					1	1	
		11:00	3,667	1				1	1					1	1	
		12:00	3,730	1				1	1					1	1	
		13:00	3,847	1				1	1					1	1	
		14:00	3,942	1				1	1					1	1	
		15:00	3,925	1				1	1					1	1	
		16:00	3,852	1				1	1					1	1	
		17:00	3,946	1				1	1					1	1	
		18:00	4,096	1				1	1	1				1	1	
		19:00	4,062	1				1	1	1				1	1	
		20:00	4,067	1				1	1	1				1	1	
		21:00	3,859	1				1	1					1	1	
		22:00	3,730	1				1	1					1	1	
		23:00	3,594	1				1	1					1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 15 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Α Π Ο Λ Ο Γ Ι Σ Μ Ο Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Παρασκευή, 15 Αυγούστου 2025	00:00	3,398	1			1	1				1	
	01:00	3,207	1			1	1				1	
	02:00	3,052	1			1	1				1	
	03:00	2,940	1			1	1				1	
	04:00	2,862	1			1	1				1	
	05:00	2,793	1			1	1				1	
	06:00	2,699	1			1	1				1	
	07:00	2,821	1				1			1	1	
	08:00	3,045	1				1			1	1	
	09:00	3,076	1				1			1	1	
	10:00	3,137	1				1			1	1	
	11:00	3,393	1			1	1			1	1	
	12:00	3,636	1			1	1			1	1	
	13:00	3,594	1			1	1			1	1	
	14:00	3,533	1			1	1			1	1	
	15:00	3,374	1			1	1			1	1	
	16:00	3,264	1			1	1			1	1	
	17:00	3,355	1			1	1			1	1	
	18:00	3,612	1			1	1			1	1	
	19:00	3,689	1			1	1			1	1	
	20:00	3,665	1			1	1			1	1	
	21:00	3,478	1			1	1			1	1	
	22:00	3,301	1			1	1			1	1	
	23:00	3,195	1			1	1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 16 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Ε Τ Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Σάββατο, 16 Αυγούστου 2025	00:00	3,066	1			1	1				1	
	01:00	2,983	1			1	1				1	
	02:00	2,800	1			1	1				1	
	03:00	2,743	1			1	1				1	
	04:00	2,729	1			1	1				1	
	05:00	2,691	1			1	1				1	
	06:00	2,548	1			1	1				1	
	07:00	2,667	1				1				1	1
	08:00	2,942	1				1				1	1
	09:00	3,168	1				1				1	1
	10:00	3,278	1				1				1	1
	11:00	3,397	1			1	1				1	1
	12:00	3,505	1			1	1				1	1
	13:00	3,487	1			1	1				1	1
	14:00	3,505	1			1	1				1	1
	15:00	3,427	1			1	1				1	1
	16:00	3,272	1			1	1				1	1
	17:00	3,302	1			1	1				1	1
	18:00	3,416	1			1	1				1	1
	19:00	3,409	1			1	1				1	1
	20:00	3,419	1			1	1				1	1
	21:00	3,147	1			1	1				1	1
	22:00	2,904	1				1				1	1
	23:00	2,795	1				1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 17 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Κυριακή, 17 Αυγούστου 2025	00:00	2,757	1			1	1				1	
	01:00	2,664	1			1	1				1	
	02:00	2,536	1			1	1				1	
	03:00	2,464	1			1	1				1	
	04:00	2,370				1	1				1	
	05:00	2,342				1	1				1	
	06:00	2,256				1	1				1	
	07:00	2,392				1	1			1	1	
	08:00	2,696				1	1			1	1	
	09:00	2,798	1				1			1	1	
	10:00	2,880	1				1			1	1	
	11:00	3,011	1				1			1	1	
	12:00	3,124	1				1			1	1	
	13:00	3,178	1				1			1	1	
	14:00	3,170	1				1			1	1	
	15:00	3,099	1				1			1	1	
	16:00	2,856	1				1			1	1	
	17:00	2,860	1				1			1	1	
	18:00	2,936	1				1			1	1	
	19:00	2,979	1				1			1	1	
	20:00	3,069	1				1			1	1	
	21:00	2,912	1				1			1	1	
	22:00	2,612	1				1			1	1	
	23:00	2,507	1				1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 18 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000		
Η Ρ Ε Τ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)		
Δευτέρα, 18 Αυγούστου 2025	00:00	2,349	1			1					1			
	01:00	2,195	1			1					1			
	02:00	2,105	1				1					1		
	03:00	2,044	1				1					1		
	04:00	1,996	1				1					1		
	05:00	1,973	1				1					1		
	06:00	1,979	1				1					1		
	07:00	2,114					1				1	1		
	08:00	2,412					1				1	1		
	09:00	2,625	1				1				1	1		
	10:00	2,738	1				1				1	1		
	11:00	2,788	1				1				1	1		
	12:00	3,025	1				1				1	1		
	13:00	3,154	1				1				1	1		
	14:00	3,110	1				1				1	1		
	15:00	2,956	1				1				1	1		
	16:00	2,846	1				1				1	1		
	17:00	2,893	1				1				1	1		
	18:00	3,072	1				1				1	1		
	19:00	3,209	1				1				1	1		
	20:00	3,260	1					1				1	1	
	21:00	3,130	1					1				1	1	
	22:00	2,925	1					1				1	1	
	23:00	2,780	1					1				1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης