

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 15 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τρίτη, 15 Ιουλίου 2025	00:00	2,786	1			1	1				1	
	01:00	2,615				1	1				1	
	02:00	2,459				1	1				1	
	03:00	2,365	1				1				1	
	04:00	2,269	1				1				1	
	05:00	2,224	1				1				1	
	06:00	2,049	1				1				1	
	07:00	2,261					1				1	1
	08:00	2,477					1				1	1
	09:00	2,661	1			1	1				1	
	10:00	2,797	1			1	1				1	
	11:00	2,895	1			1	1				1	
	12:00	2,978	1			1	1				1	
	13:00	3,094	1			1	1				1	
	14:00	3,127				1	1				1	1
	15:00	3,086				1	1				1	1
	16:00	2,993				1	1				1	1
	17:00	2,961				1	1				1	1
	18:00	3,118				1	1				1	1
	19:00	3,113				1	1				1	1
	20:00	3,071				1	1				1	1
	21:00	3,033				1	1				1	1
	22:00	2,939				1	1				1	1
	23:00	2,839				1	1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Απολογισμός Λειτουργίας		Τετάρτη, 16 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τετάρτη, 16 Ιουλίου 2025	00:00	2,684	1			1	1				1	
	01:00	2,496	1				1				1	
	02:00	2,361	1				1				1	
	03:00	2,267	1				1				1	
	04:00	2,192	1				1				1	
	05:00	2,154	1				1				1	
	06:00	2,058	1				1				1	
	07:00	2,278	1				1				1	
	08:00	2,541	1				1				1	
	09:00	2,737	1			1	1				1	
	10:00	2,771	1			1	1				1	
	11:00	2,906	1			1	1				1	
	12:00	3,020	1			1	1				1	
	13:00	3,112	1				1				1	1
	14:00	3,150	1				1				1	1
	15:00	3,149	1				1				1	1
	16:00	3,009	1				1				1	1
	17:00	3,001	1				1				1	1
	18:00	3,147	1				1				1	1
	19:00	3,124	1				1				1	1
	20:00	3,090	1				1				1	1
	21:00	3,066	1				1				1	1
	22:00	3,016	1				1				1	1
	23:00	2,868	1				1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 17 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Πέμπτη, 17 Ιουλίου 2025	00:00	2,702	1				1	1			1	
	01:00	2,514	1				1	1			1	
	02:00	2,390					1	1			1	
	03:00	2,302					1	1			1	
	04:00	2,234					1	1			1	
	05:00	2,201					1	1			1	
	06:00	2,098					1	1			1	
	07:00	2,339					1	1			1	1
	08:00	2,551					1	1			1	1
	09:00	2,722					1	1			1	1
	10:00	2,851					1	1			1	1
	11:00	2,996					1	1			1	1
	12:00	3,107					1	1			1	1
	13:00	3,180					1	1			1	1
	14:00	3,224					1	1			1	1
	15:00	3,186					1	1			1	1
	16:00	3,111					1	1			1	1
	17:00	3,114					1	1			1	1
	18:00	3,235					1	1			1	1
	19:00	3,213					1	1			1	1
	20:00	3,190					1	1			1	1
	21:00	3,180					1	1			1	1
	22:00	3,084					1	1			1	1
	23:00	2,992					1	1			1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 18 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)
Παρασκευή, 18 Ιουλίου 2025	00:00	2,756	1			1	1				1	
	01:00	2,568	1			1	1				1	
	02:00	2,410	1				1				1	
	03:00	2,321	1				1				1	
	04:00	2,241	1				1				1	
	05:00	2,233	1				1				1	
	06:00	2,092	1				1				1	
	07:00	2,315	1				1				1	1
	08:00	2,520	1				1				1	1
	09:00	2,584	1				1				1	1
	10:00	2,761	1				1				1	1
	11:00	2,916	1				1				1	1
	12:00	3,053	1				1				1	1
	13:00	3,031	1				1				1	1
	14:00	3,251	1				1				1	1
	15:00	3,264	1				1				1	1
	16:00	3,211	1				1				1	1
	17:00	2,966	1				1				1	1
	18:00	3,216	1				1				1	1
	19:00	3,300	1				1				1	1
	20:00	3,310	1				1				1	1
	21:00	3,237	1				1				1	1
	22:00	3,150	1				1				1	1
	23:00	3,041	1				1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Απολογισμός Λειτουργίας		Σάββατο, 19 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)
Σάββατο, 19 Ιουλίου 2025	00:00	2,859	1			1	1				1	
	01:00	2,712	1			1	1				1	
	02:00	2,602	1			1	1				1	
	03:00	2,518	1			1	1				1	
	04:00	2,428	1			1	1				1	
	05:00	2,358	1			1	1				1	
	06:00	2,161				1	1				1	
	07:00	2,143				1	1				1	
	08:00	2,343					1				1	1
	09:00	2,467					1				1	1
	10:00	2,613				1	1				1	1
	11:00	2,750				1	1				1	1
	12:00	3,035				1	1				1	1
	13:00	3,228				1	1				1	1
	14:00	3,498	1			1	1				1	1
	15:00	3,412	1			1	1				1	1
	16:00	3,224				1	1				1	1
	17:00	3,363				1	1				1	1
	18:00	3,417	1			1	1				1	1
	19:00	3,435	1			1	1				1	1
	20:00	3,411	1			1	1				1	1
	21:00	3,399	1			1	1				1	1
	22:00	3,323				1	1				1	1
	23:00	3,220				1	1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 20 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)
Κυριακή, 20 Ιουλίου 2025	00:00	3,067	1			1	1				1	
	01:00	2,897	1			1	1				1	
	02:00	2,790	1			1	1				1	
	03:00	2,676	1			1	1				1	
	04:00	2,572	1			1	1				1	
	05:00	2,533	1			1	1				1	
	06:00	2,416	1			1	1				1	
	07:00	2,576	1			1	1				1	
	08:00	2,707	1				1				1	1
	09:00	2,849	1				1				1	1
	10:00	2,980	1				1				1	1
	11:00	3,124	1				1				1	1
	12:00	3,320	1			1	1				1	1
	13:00	3,308	1			1	1				1	1
	14:00	3,248	1			1	1				1	1
	15:00	3,198	1			1	1				1	1
	16:00	3,125	1			1	1				1	1
	17:00	3,119				1	1				1	1
	18:00	3,222				1	1				1	1
	19:00	3,393	1			1	1				1	1
	20:00	3,393	1			1	1				1	1
	21:00	3,410	1			1	1				1	1
	22:00	3,278	1			1	1				1	1
	23:00	3,305	1			1	1				1	1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 21 Ιουλίου 2025								
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000	
Η ε ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)	
Δευτέρα, 21 Ιουλίου 2025	00:00	3,189	1			1	1				1		
	01:00	2,981	1			1	1				1		
	02:00	2,834	1				1		1		1		
	03:00	2,699	1				1		1		1		
	04:00	2,615	1				1		1		1		
	05:00	2,540	1				1		1		1		
	06:00	2,341	1				1		1		1		
	07:00	2,257	1				1				1		
	08:00	2,502	1				1				1	1	
	09:00	2,816	1				1				1	1	
	10:00	3,096	1				1				1	1	
	11:00	3,233	1				1				1	1	
	12:00	3,274	1			1	1				1	1	
	13:00	3,088	1			1	1				1	1	
	14:00	3,407	1			1	1				1	1	
	15:00	3,372	1			1	1			1		1	
	16:00	3,361	1			1	1			1		1	
	17:00	3,482	1			1	1			1		1	
	18:00	3,672	1			1	1			1		1	
	19:00	3,736	1			1	1			1		1	
	20:00	3,694	1			1	1			1		1	
	21:00	3,639	1			1	1			1		1	
	22:00	3,517	1			1	1			1		1	
	23:00	3,528	1			1	1			1		1	

Μισθωμένη ισχύς 1 MW. Στο διάστημα 14:20 - 14:23 σημειώθηκε μερική διακοπή λόγω βλάβης στο μισθωμένο Η/Ζ.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης