

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 26 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τρίτη, 26 Αυγούστου 2025	00:00	2,683	1			1	1				1	
	01:00	2,542	1			1	1				1	
	02:00	2,447	1			1	1				1	
	03:00	2,325	1				1				1	
	04:00	2,239	1				1				1	
	05:00	2,244	1				1				1	
	06:00	2,203	1				1				1	
	07:00	2,344					1				1	1
	08:00	2,492					1				1	1
	09:00	2,659					1				1	1
	10:00	2,756	1				1				1	1
	11:00	2,973	1				1				1	1
	12:00	3,131	1				1				1	1
	13:00	3,216	1				1				1	1
	14:00	3,239	1				1				1	1
	15:00	3,205	1				1				1	1
	16:00	3,091	1				1	1			1	1
	17:00	3,067	1				1	1			1	1
	18:00	3,059	1					1			1	1
	19:00	3,151	1					1			1	1
	20:00	3,163	1					1			1	1
	21:00	3,030	1					1			1	1
	22:00	2,930	1					1			1	1
	23:00	2,796	1					1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 27 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Ε Σ Τ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τετάρτη, 27 Αυγούστου 2025	00:00	2,656	1			1	1				1	
	01:00	2,518	1			1	1				1	
	02:00	2,402	1			1	1				1	
	03:00	2,313	1				1				1	
	04:00	2,197	1				1				1	
	05:00	2,171	1				1				1	
	06:00	2,131	1				1				1	
	07:00	2,291					1			1	1	
	08:00	2,418					1			1	1	
	09:00	2,520					1			1	1	
	10:00	2,572					1			1	1	
	11:00	2,586					1			1	1	
	12:00	2,760	1				1			1	1	
	13:00	2,852	1				1			1	1	
	14:00	2,814	1				1			1	1	
	15:00	2,726	1				1			1	1	
	16:00	2,630	1				1			1	1	
	17:00	2,596					1			1	1	
	18:00	2,781					1	1		1	1	
	19:00	2,843					1	1		1	1	
	20:00	2,889					1	1		1	1	
	21:00	2,705					1	1		1	1	
	22:00	2,721					1	1		1	1	
	23:00	2,495					1	1		1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Απολογισμός Λειτουργίας			Πέμπτη, 28 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000		
Ρ	Θ	Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Πέμπτη, 28 Αυγούστου 2025			00:00	2,171				1	1				1	
			01:00	2,023				1	1				1	
			02:00	1,928				1	1				1	
			03:00	1,880				1	1				1	
			04:00	1,851				1	1				1	
			05:00	1,838				1	1				1	
			06:00	1,863				1	1				1	
			07:00	1,977					1			1	1	
			08:00	2,353					1			1	1	
			09:00	2,472					1			1	1	
			10:00	2,550					1			1	1	
			11:00	2,707	1				1			1	1	
			12:00	2,904	1				1			1	1	
			13:00	3,046	1				1			1	1	
			14:00	3,191	1				1			1	1	
			15:00	3,037	1				1			1	1	
			16:00	2,960	1				1			1	1	
			17:00	2,916	1				1			1	1	
			18:00	3,052	1				1			1	1	
			19:00	3,114	1				1			1	1	
			20:00	3,134	1				1			1	1	
			21:00	2,994	1				1			1	1	
			22:00	2,891	1				1			1	1	
			23:00	2,728	1			1	1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 29 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Α Π Ο Λ Ο Γ Ι Σ Μ Ο Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Παρασκευή, 29 Αυγούστου 2025	00:00	2,510	1			1	1				1	
	01:00	2,323	1				1				1	
	02:00	2,208	1				1				1	
	03:00	2,148	1				1				1	
	04:00	2,078	1				1				1	
	05:00	2,040	1				1				1	
	06:00	1,989	1				1				1	
	07:00	2,168					1			1	1	
	08:00	2,389					1			1	1	
	09:00	2,542					1			1	1	
	10:00	2,614					1			1	1	
	11:00	2,806	1				1			1	1	
	12:00	2,918	1				1			1	1	
	13:00	3,089	1				1			1	1	
	14:00	3,151	1				1			1	1	
	15:00	3,046	1				1			1	1	
	16:00	2,797	1				1			1	1	
	17:00	2,846	1				1			1	1	
	18:00	3,012	1				1			1	1	
	19:00	3,064	1				1			1	1	
	20:00	3,082	1				1			1	1	
	21:00	2,926	1				1			1	1	
	22:00	2,755	1				1			1	1	
	23:00	2,579	1				1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 30 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)		0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000	
Ρ	Θ	Ε	Τ	Ε	Η							
Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)	
Σάββατο, 30 Αυγούστου 2025	00:00	2,416	1			1				1		
	01:00	2,262	1			1				1		
	02:00	2,175	1			1				1		
	03:00	2,019	1			1				1		
	04:00	1,938	1			1				1		
	05:00	1,987	1			1				1		
	06:00	1,986	1			1				1		
	07:00	2,097				1			1	1		
	08:00	2,313				1			1	1		
	09:00	2,460				1			1	1		
	10:00	2,575				1			1	1		
	11:00	2,704	1			1			1	1		
	12:00	2,814	1			1			1	1		
	13:00	2,873	1			1			1	1		
	14:00	2,895	1			1			1	1		
	15:00	2,865	1			1			1	1		
	16:00	2,773	1			1			1	1		
	17:00	2,759	1			1			1	1		
	18:00	2,842	1			1			1	1		
	19:00	2,912	1			1			1	1		
	20:00	2,770	1			1			1	1		
	21:00	2,564	1			1			1	1		
	22:00	2,467	1			1			1	1		
	23:00	2,346	1			1			1	1		

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 31 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000	
Η Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)	
Κυριακή, 31 Αυγούστου 2025	00:00	2,051	1			1					1		
	01:00	1,908	1			1					1		
	02:00	1,840	1			1					1		
	03:00	1,773	1			1					1		
	04:00	1,725	1			1					1		
	05:00	1,799	1			1					1		
	06:00	1,798	1			1					1		
	07:00	1,879				1				1	1		
	08:00	2,134				1				1	1		
	09:00	2,319				1				1	1		
	10:00	2,416				1				1	1		
	11:00	2,591				1				1	1		
	12:00	2,729	1			1				1	1		
	13:00	2,781	1			1				1	1		
	14:00	2,794	1			1				1	1		
	15:00	2,615	1			1				1	1		
	16:00	2,587				1				1	1		
	17:00	2,503				1				1	1		
	18:00	2,573				1				1	1		
	19:00	2,657				1				1	1		
	20:00	2,721	1				1				1	1	
	21:00	2,634	1				1				1	1	
	22:00	2,549	1				1				1	1	
	23:00	2,435	1				1				1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 1 Σεπτεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)		0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000		
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
Δευτέρα, 1 Σεπτεμβρίου 2025	00:00	2,263	1				1				1	
	01:00	2,170	1				1				1	
	02:00	2,074	1				1				1	
	03:00	2,006	1				1				1	
	04:00	1,956	1				1				1	
	05:00	1,934	1				1				1	
	06:00	1,875	1				1				1	
	07:00	2,070	1				1				1	
	08:00	2,314	1			1	1					
	09:00	2,330	1			1	1					
	10:00	2,423	1			1	1					
	11:00	2,738	1			1	1		1		1	
	12:00	2,868	1				1		1		1	
	13:00	2,951	1				1		1		1	
	14:00	2,983	1				1		1		1	
	15:00	2,837	1				1		1		1	
	16:00	2,795	1				1		1		1	
	17:00	2,759	1				1		1		1	
	18:00	2,874	1				1		1		1	
	19:00	2,876	1				1		1		1	
	20:00	2,873	1				1		1		1	
	21:00	2,753	1				1		1		1	
	22:00	2,662	1				1		1		1	
	23:00	2,457	1				1		1		1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης