

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 3 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
Τετάρτη, 3 Σεπτεμβρίου 2025	00:00	2,250	1			1	1				1	
	01:00	2,153	1			1	1					
	02:00	2,069	1			1	1					
	03:00	1,980	1			1	1					
	04:00	1,936	1			1	1					
	05:00	1,925	1			1	1					
	06:00	1,946	1			1	1					
	07:00	2,055	1			1	1					
	08:00	2,219	1			1	1					
	09:00	2,362	1			1	1				1	
	10:00	2,477	1			1	1				1	
	11:00	2,570	1			1	1				1	
	12:00	2,658	1			1	1				1	
	13:00	2,716	1			1	1				1	
	14:00	2,724	1			1	1				1	
	15:00	2,756	1			1	1				1	
	16:00	2,741	1			1	1				1	
	17:00	2,736	1			1	1				1	
	18:00	2,774	1			1	1				1	
	19:00	2,788	1			1	1				1	
	20:00	2,822	1			1	1				1	
	21:00	2,766	1			1	1				1	
	22:00	2,613	1			1	1				1	
	23:00	2,386	1			1	1				1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 4 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	
Η Ε Ρ Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
Πέμπτη, 4 Σεπτεμβρίου 2025	00:00	2,398	1			1	1				1	
	01:00	2,277	1			1	1				1	
	02:00	2,166	1			1	1					
	03:00	2,075	1			1	1					
	04:00	1,996	1			1	1					
	05:00	1,952	1			1	1					
	06:00	1,966	1			1	1					
	07:00	2,077	1			1	1					
	08:00	2,266	1			1	1					1
	09:00	2,402	1			1	1					1
	10:00	2,526	1			1	1					1
	11:00	2,652	1			1	1					1
	12:00	2,767	1			1	1					1
	13:00	2,837	1			1	1					1
	14:00	2,879	1			1	1					1
	15:00	2,847	1			1	1					1
	16:00	2,704	1			1	1					1
	17:00	2,684	1			1	1					1
	18:00	2,733	1			1	1					1
	19:00	2,775	1			1	1					1
	20:00	2,772	1			1	1					1
	21:00	2,699	1			1	1					1
	22:00	2,537	1			1	1					1
	23:00	2,323	1			1	1					1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 5 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
Παρασκευή, 5 Σεπτεμβρίου 2025	00:00	2,292	1			1	1				1	
	01:00	2,153	1			1	1					
	02:00	2,079	1			1	1					
	03:00	1,998	1			1	1					
	04:00	1,923	1			1	1					
	05:00	1,905	1			1	1					
	06:00	1,921	1			1	1					
	07:00	2,035	1			1	1					
	08:00	2,187	1			1	1					
	09:00	2,367	1			1	1	1				
	10:00	2,495	1			1	1	1				
	11:00	2,588	1			1	1	1				
	12:00	2,683	1			1	1	1				
	13:00	2,745	1			1	1	1				
	14:00	2,768	1			1	1	1				
	15:00	2,724	1			1	1	1				
	16:00	2,617	1			1	1	1				
	17:00	2,627	1			1	1	1				
	18:00	2,694	1			1	1	1				
	19:00	2,759	1			1	1	1				
	20:00	2,743	1			1	1	1				
	21:00	2,654	1			1	1	1				
	22:00	2,504	1			1	1	1				
	23:00	2,291	1			1	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ					Σάββατο, 6 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000		
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9		
Σάββατο, 6 Σεπτεμβρίου 2025	00:00	2,197	1			1	1						
	01:00	2,104	1			1							
	02:00	2,011	1			1							
	03:00	1,932	1			1							
	04:00	1,851	1			1							
	05:00	1,854	1			1							
	06:00	1,878	1			1							
	07:00	1,960	1			1							
	08:00	2,128	1			1							
	09:00	2,286	1			1	1						
	10:00	2,420	1			1	1						
	11:00	2,520	1			1	1						
	12:00	2,590	1			1	1						
	13:00	2,626	1			1	1						
	14:00	2,654	1			1	1						
	15:00	2,610	1			1	1						
	16:00	2,543	1			1	1						
	17:00	2,554	1			1	1						
	18:00	2,627	1			1	1						
	19:00	2,690	1			1	1						
	20:00	2,682	1			1	1						
	21:00	2,590	1			1	1						
	22:00	2,451	1			1	1						
	23:00	2,263	1			1	1						



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 7 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
Κυριακή, 7 Σεπτεμβρίου 2025	00:00	2,156	1			1	1					
	01:00	2,047	1			1	1					
	02:00	1,948	1			1	1					
	03:00	1,868	1			1	1					
	04:00	1,791	1			1	1					
	05:00	1,784	1			1	1					
	06:00	1,813	1			1	1					
	07:00	1,891	1			1	1					
	08:00	2,055	1			1	1					
	09:00	2,192	1			1	1					
	10:00	2,342	1			1	1	1				
	11:00	2,448	1			1	1	1				
	12:00	2,522	1			1	1	1				
	13:00	2,565	1			1	1	1				
	14:00	2,577	1			1	1	1				
	15:00	2,488	1			1	1	1				
	16:00	2,448	1			1	1	1				
	17:00	2,424	1			1	1	1				
	18:00	2,497	1			1	1	1				
	19:00	2,584	1			1	1	1				
	20:00	2,585	1			1	1	1				
	21:00	2,527	1			1	1	1				
	22:00	2,387	1			1	1	1				
	23:00	2,172	1			1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 8 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
Δευτέρα, 8 Σεπτεμβρίου 2025	00:00	2,072	1			1	1					
	01:00	1,968	1			1	1					
	02:00	1,875	1			1	1					
	03:00	1,799	1			1	1					
	04:00	1,748	1			1	1					
	05:00	1,741	1			1	1					
	06:00	1,791	1			1	1					
	07:00	1,905	1			1	1					
	08:00	2,090	1			1	1					
	09:00	2,252	1			1	1	1				
	10:00	2,370	1			1	1	1				
	11:00	2,458	1			1	1	1				
	12:00	2,519	1			1	1	1				
	13:00	2,549	1			1	1	1				
	14:00	2,537	1			1	1	1				
	15:00	2,447	1			1	1	1				
	16:00	2,399	1			1	1	1				
	17:00	2,392	1			1	1	1				
	18:00	2,468	1			1	1	1				
	19:00	2,559	1			1	1	1				
	20:00	2,571	1			1	1	1				
	21:00	2,502	1			1	1	1				
	22:00	2,349	1			1	1	1				
	23:00	2,132	1			1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 9 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	
Ρ	Θ	Ε	Σ	Η								
Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9		
Τρίτη, 9 Σεπτεμβρίου 2025	00:00	2,024	1			1	1					
	01:00	1,929	1			1	1					
	02:00	1,843	1			1	1					
	03:00	1,771	1			1	1					
	04:00	1,723	1			1	1					
	05:00	1,716	1			1	1					
	06:00	1,766	1			1	1					
	07:00	1,892	1			1	1					
	08:00	2,074	1			1	1					
	09:00	2,255	1			1	1	1				
	10:00	2,350	1			1	1	1				
	11:00	2,432	1			1	1	1				
	12:00	2,489	1			1	1	1				
	13:00	2,517	1			1	1	1				
	14:00	2,502	1			1	1	1				
	15:00	2,425	1			1	1	1				
	16:00	2,370	1			1	1	1				
	17:00	2,365	1			1	1	1				
	18:00	2,437	1			1	1	1				
	19:00	2,521	1			1	1	1				
	20:00	2,537	1			1	1	1				
	21:00	2,462	1			1	1	1				
	22:00	2,300	1			1	1	1				
	23:00	2,086	1			1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης