

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 6 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ α χ ή	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τετάρτη, 6 Αυγούστου 2025	00:00	2,991	1			1	1		1			1
	01:00	2,862	1			1	1		1			
	02:00	2,690	1			1	1		1			
	03:00	2,554	1			1	1		1			
	04:00	2,455	1			1	1		1			
	05:00	2,390	1			1	1		1			
	06:00	2,393	1			1	1		1			
	07:00	2,543	1			1	1		1			
	08:00	2,722	1			1	1		1			
	09:00	2,888	1			1	1		1			1
	10:00	3,039	1			1	1		1			1
	11:00	3,151	1			1	1		1			1
	12:00	3,231	1			1	1		1			1
	13:00	3,273	1			1	1		1			1
	14:00	3,263	1			1	1		1			1
	15:00	3,206	1			1	1		1			1
	16:00	3,151	1			1	1		1			1
	17:00	3,148	1			1	1		1			1
	18:00	3,237	1			1	1		1			1
	19:00	3,329	1			1	1		1			1
	20:00	3,361	1			1	1		1			1
	21:00	3,323	1			1	1		1			1
	22:00	3,190	1			1	1		1			1
	23:00	2,983	1			1	1		1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 7 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	ΗΖ (Χ1)
Πέμπτη, 7 Αυγούστου 2025	00:00	2,850	1				1	1		1		1
	01:00	2,716	1				1	1		1		
	02:00	2,591	1				1	1		1		
	03:00	2,474	1				1	1		1		
	04:00	2,379	1				1	1		1		
	05:00	2,318	1				1	1		1		
	06:00	2,307	1				1	1		1		
	07:00	2,459	1				1	1		1		
	08:00	2,651	1				1	1		1		
	09:00	2,872	1				1	1		1		
	10:00	2,972	1				1	1		1		1
	11:00	3,102	1				1	1		1		1
	12:00	3,218	1				1	1		1		1
	13:00	3,262	1				1	1		1		1
	14:00	3,241	1				1	1		1		1
	15:00	3,183	1				1	1		1		1
	16:00	3,257	1				1	1		1		1
	17:00	3,249	1				1	1		1		1
	18:00	3,324	1				1	1		1		1
	19:00	3,391	1				1	1		1		1
	20:00	3,397	1				1	1		1		1
	21:00	3,338	1				1	1		1		1
	22:00	3,179	1				1	1		1		1
	23:00	2,946	1				1	1		1		1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 8 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ α χ ή	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Παρασκευή, 8 Αυγούστου 2025	00:00	2,750	1			1	1		1			
	01:00	2,705	1			1	1		1			
	02:00	2,579	1			1	1		1			
	03:00	2,468	1			1	1		1			
	04:00	2,379	1			1	1		1			
	05:00	2,320	1			1	1		1			
	06:00	2,303	1			1	1		1			
	07:00	2,403	1			1	1		1			
	08:00	2,580	1			1	1		1			
	09:00	2,791	1			1	1		1			
	10:00	2,962	1			1	1		1			1
	11:00	3,114	1			1	1		1			1
	12:00	3,229	1			1	1		1			1
	13:00	3,312	1			1	1		1			1
	14:00	3,335	1			1	1		1			1
	15:00	3,296	1			1	1		1			1
	16:00	3,304	1			1	1		1			1
	17:00	3,296	1			1	1		1			1
	18:00	3,352	1			1	1		1			1
	19:00	3,408	1			1	1		1			1
	20:00	3,408	1			1	1		1			1
	21:00	3,332	1			1	1		1			1
	22:00	3,167	1			1	1		1			1
	23:00	2,930	1			1	1		1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 9 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Ρ	Θ	Ε	Σ	Η	Ε	Π	Ε	Π	Ε	Π	Ε	Π
Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)	
Σάββατο, 9 Αυγούστου 2025	00:00	2,873	1			1	1		1			
	01:00	2,738	1			1	1		1			
	02:00	2,609	1			1	1		1			
	03:00	2,502	1			1	1		1			
	04:00	2,422	1			1	1		1			
	05:00	2,372	1			1	1		1			
	06:00	2,355	1			1	1		1			
	07:00	2,416	1			1	1		1			
	08:00	2,572	1			1	1		1			
	09:00	2,769	1			1	1		1			
	10:00	2,948	1			1	1		1			1
	11:00	3,100	1			1	1		1			1
	12:00	3,224	1			1	1		1			1
	13:00	3,314	1			1	1		1			1
	14:00	3,355	1			1	1		1			1
	15:00	3,320	1			1	1		1			1
	16:00	3,286	1			1	1		1			1
	17:00	3,291	1			1	1		1			1
	18:00	3,348	1			1	1		1			1
	19:00	3,404	1			1	1		1			1
	20:00	3,410	1			1	1		1			1
	21:00	3,333	1			1	1		1			1
	22:00	3,176	1			1	1		1			1
	23:00	2,943	1			1	1		1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 10 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Κυριακή, 10 Αυγούστου 2025	00:00	2,895	1			1	1		1			
	01:00	2,750	1			1	1		1			
	02:00	2,616	1			1	1		1			
	03:00	2,501	1			1	1		1			
	04:00	2,412	1			1	1		1			
	05:00	2,356	1			1	1		1			
	06:00	2,328	1			1	1		1			
	07:00	2,385	1			1	1		1			
	08:00	2,521	1			1	1		1			
	09:00	2,705	1			1	1		1			
	10:00	2,879	1			1	1		1			1
	11:00	3,027	1			1	1		1			1
	12:00	3,137	1			1	1		1			1
	13:00	3,216	1			1	1		1			1
	14:00	3,252	1			1	1		1			1
	15:00	3,213	1			1	1		1			1
	16:00	3,154	1			1	1		1			1
	17:00	3,153	1			1	1		1			1
	18:00	3,220	1			1	1		1			1
	19:00	3,291	1			1	1		1			1
	20:00	3,312	1			1	1		1			1
	21:00	3,224	1			1	1		1			1
	22:00	3,067	1			1	1		1			1
	23:00	2,786	1			1	1		1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 11 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Δευτέρα, 11 Αυγούστου 2025	00:00	2,772	1			1	1		1			
	01:00	2,645	1			1	1		1			
	02:00	2,523	1			1	1		1			
	03:00	2,404	1			1	1		1			
	04:00	2,316	1			1	1		1			
	05:00	2,290	1			1	1		1			
	06:00	2,282	1			1	1		1			
	07:00	2,387	1			1	1		1			
	08:00	2,555	1			1	1		1			
	09:00	2,764	1			1	1		1			
	10:00	2,932	1			1	1		1			1
	11:00	3,065	1			1	1		1			1
	12:00	3,156	1			1	1		1			1
	13:00	3,220	1			1	1		1			1
	14:00	3,238	1			1	1		1			1
	15:00	3,195	1			1	1		1			1
	16:00	3,129	1			1	1		1			1
	17:00	3,113	1			1	1		1			1
	18:00	3,171	1			1	1		1			1
	19:00	3,252	1			1	1		1			1
	20:00	3,287	1			1	1		1			1
	21:00	3,210	1			1	1		1			1
	22:00	3,047	1			1	1		1			1
	23:00	2,756	1			1	1		1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 12 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Ε Σ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)
Τρίτη, 12 Αυγούστου 2025	00:00	2,731	1				1	1		1		
	01:00	2,608	1				1	1		1		
	02:00	2,486	1				1	1		1		
	03:00	2,377	1				1	1		1		
	04:00	2,297	1				1	1		1		
	05:00	2,248	1				1	1		1		
	06:00	2,251	1				1	1		1		
	07:00	2,362	1				1	1		1		
	08:00	2,538	1				1	1		1		
	09:00	2,749	1				1	1		1		
	10:00	2,908	1				1	1		1		1
	11:00	3,028	1				1	1		1		1
	12:00	3,114	1				1	1		1		1
	13:00	3,168	1				1	1		1		1
	14:00	3,184	1				1	1		1		1
	15:00	3,143	1				1	1		1		1
	16:00	3,080	1				1	1		1		1
	17:00	3,064	1				1	1		1		1
	18:00	3,124	1				1	1		1		1
	19:00	3,214	1				1	1		1		1
	20:00	3,254	1				1	1		1		1
	21:00	3,195	1				1	1		1		1
	22:00	3,029	1				1	1		1		1
	23:00	2,755	1				1	1		1		

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης