

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 23 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τετάρτη, 23 Ιουλίου 2025	00:00	3,175	1			1	1	1			1	
	01:00	3,043	1			1	1				1	
	02:00	2,892	1			1	1				1	
	03:00	2,736	1			1	1				1	
	04:00	2,607	1			1	1				1	
	05:00	2,529	1			1	1				1	
	06:00	2,506	1			1	1				1	
	07:00	2,621	1			1	1				1	
	08:00	2,762	1			1	1				1	
	09:00	2,922	1			1	1				1	
	10:00	3,066	1			1	1				1	
	11:00	3,202	1			1	1	1			1	
	12:00	3,313	1			1	1	1			1	
	13:00	3,388	1			1	1	1			1	
	14:00	3,432	1			1	1	1			1	
	15:00	3,408	1			1	1	1			1	
	16:00	3,318	1			1	1	1			1	
	17:00	3,298	1			1	1	1			1	
	18:00	3,378	1			1	1	1			1	
	19:00	3,447	1			1	1	1			1	
	20:00	3,463	1			1	1	1			1	
	21:00	3,495	1			1	1	1			1	
	22:00	3,428	1			1	1	1			1	
	23:00	3,275	1			1	1	1			1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 24 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	ΗΖ (Χ1)
Πέμπτη, 24 Ιουλίου 2025	00:00	3,218	1			1	1	1			1	
	01:00	3,075	1			1	1				1	
	02:00	2,923	1			1	1				1	
	03:00	2,780	1			1	1				1	
	04:00	2,651	1			1	1				1	
	05:00	2,556	1			1	1				1	
	06:00	2,541	1			1	1				1	
	07:00	2,653	1			1	1				1	
	08:00	2,781	1			1	1				1	
	09:00	2,930	1			1	1				1	
	10:00	3,077	1			1	1				1	
	11:00	3,220	1			1	1	1			1	
	12:00	3,344	1			1	1	1			1	
	13:00	3,441	1			1	1	1			1	
	14:00	3,506	1			1	1	1			1	
	15:00	3,500	1			1	1	1			1	
	16:00	3,395	1			1	1	1			1	
	17:00	3,360	1			1	1	1			1	
	18:00	3,406	1			1	1	1			1	
	19:00	3,458	1			1	1	1			1	
	20:00	3,497	1			1	1	1			1	
	21:00	3,480	1			1	1	1			1	
	22:00	3,352	1			1	1	1			1	
	23:00	3,132	1			1	1	1			1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 25 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Παρασκευή, 25 Ιουλίου 2025	00:00	3,118	1			1	1				1	
	01:00	2,952	1			1	1				1	
	02:00	2,788	1			1	1				1	
	03:00	2,646	1			1	1				1	
	04:00	2,528	1			1	1				1	
	05:00	2,454	1			1	1				1	
	06:00	2,423	1			1	1				1	
	07:00	2,546	1			1	1				1	
	08:00	2,705	1			1	1				1	
	09:00	2,882	1			1	1				1	
	10:00	3,059	1			1	1				1	
	11:00	3,214	1			1	1	1			1	
	12:00	3,340	1			1	1	1			1	
	13:00	3,418	1			1	1	1			1	
	14:00	3,498	1			1	1	1			1	
	15:00	3,502	1			1	1	1			1	
	16:00	3,438	1			1	1	1			1	
	17:00	3,355	1			1	1	1			1	
	18:00	3,440	1			1	1	1			1	
	19:00	3,506	1			1	1	1			1	
	20:00	3,539	1			1	1	1			1	
	21:00	3,501	1			1	1	1			1	
	22:00	3,356	1			1	1	1			1	
	23:00	3,122	1			1	1				1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 26 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)
Σάββατο, 26 Ιουλίου 2025	00:00	3,123	1			1	1				1	
	01:00	2,969	1			1	1				1	
	02:00	2,826	1			1	1				1	
	03:00	2,701	1			1	1				1	
	04:00	2,575	1			1	1				1	
	05:00	2,505	1			1	1				1	
	06:00	2,474	1			1	1				1	
	07:00	2,543	1			1	1				1	
	08:00	2,695	1			1	1				1	
	09:00	2,861	1			1	1				1	
	10:00	3,033	1			1	1				1	
	11:00	3,179	1			1	1	1			1	
	12:00	3,327	1			1	1	1			1	
	13:00	3,442	1			1	1	1			1	
	14:00	3,553	1			1	1	1			1	
	15:00	3,561	1			1	1	1			1	
	16:00	3,485	1			1	1	1			1	
	17:00	3,468	1			1	1	1			1	
	18:00	3,507	1			1	1	1			1	
	19:00	3,557	1			1	1	1			1	
	20:00	3,554	1			1	1	1			1	
	21:00	3,511	1			1	1	1			1	
	22:00	3,380	1			1	1	1			1	
	23:00	3,157	1			1	1	1			1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 27 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ α χ ή	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Κυριακή, 27 Ιουλίου 2025	00:00	3,193	1			1	1	1			1	
	01:00	3,030	1			1	1				1	
	02:00	2,876	1			1	1				1	
	03:00	2,737	1			1	1				1	
	04:00	2,621	1			1	1				1	
	05:00	2,548	1			1	1				1	
	06:00	2,522	1			1	1				1	
	07:00	2,581	1			1	1				1	
	08:00	2,711	1			1	1				1	
	09:00	2,876	1			1	1				1	
	10:00	3,044	1			1	1				1	
	11:00	3,190	1			1	1	1			1	
	12:00	3,321	1			1	1	1			1	
	13:00	3,405	1			1	1	1			1	
	14:00	3,445	1			1	1	1			1	
	15:00	3,417	1			1	1	1			1	
	16:00	3,330	1			1	1	1			1	
	17:00	3,291	1			1	1	1			1	
	18:00	3,336	1			1	1	1			1	
	19:00	3,429	1			1	1	1			1	
	20:00	3,461	1			1	1	1			1	
	21:00	3,413	1			1	1	1			1	
	22:00	3,265	1			1	1	1			1	
	23:00	3,036	1			1	1				1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 28 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Δευτέρα, 28 Ιουλίου 2025	00:00	3,018	1			1	1				1	
	01:00	2,874	1			1	1				1	
	02:00	2,729	1			1	1				1	
	03:00	2,591	1			1	1				1	
	04:00	2,482	1			1	1				1	
	05:00	2,417	1			1	1				1	
	06:00	2,386	1			1	1				1	
	07:00	2,466	1			1	1				1	
	08:00	2,645	1			1	1				1	
	09:00	2,876	1			1	1				1	
	10:00	3,068	1			1	1				1	
	11:00	3,205	1			1	1	1			1	
	12:00	3,303	1			1	1	1			1	
	13:00	3,347	1			1	1	1			1	
	14:00	3,410	1			1	1	1			1	
	15:00	3,382	1			1	1	1			1	
	16:00	3,322	1			1	1	1			1	
	17:00	3,306	1			1	1	1			1	
	18:00	3,361	1			1	1	1			1	
	19:00	3,447	1			1	1	1			1	
	20:00	3,485	1			1	1	1			1	
	21:00	3,444	1			1	1	1			1	
	22:00	3,285	1			1	1	1			1	
	23:00	3,032	1			1	1				1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 29 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Η Ε Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)
Τρίτη, 29 Ιουλίου 2025	00:00	2,968	1			1	1				1	
	01:00	2,832	1			1	1				1	
	02:00	2,686	1			1	1				1	
	03:00	2,548	1			1	1				1	
	04:00	2,439	1			1	1				1	
	05:00	2,393	1			1	1				1	
	06:00	2,381	1			1	1				1	
	07:00	2,498	1			1	1				1	
	08:00	2,675	1			1	1				1	
	09:00	2,880	1			1	1				1	
	10:00	3,056	1			1	1				1	
	11:00	3,193	1			1	1	1			1	
	12:00	3,305	1			1	1	1			1	
	13:00	3,385	1			1	1	1			1	
	14:00	3,452	1			1	1	1			1	
	15:00	3,448	1			1	1	1			1	
	16:00	3,392	1			1	1	1			1	
	17:00	3,363	1			1	1	1			1	
	18:00	3,406	1			1	1	1			1	
	19:00	3,483	1			1	1	1			1	
	20:00	3,525	1			1	1	1			1	
	21:00	3,493	1			1	1	1			1	
	22:00	3,346	1			1	1	1			1	
	23:00	3,100	1			1	1				1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης