

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 30 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Τετάρτη, 30 Ιουλίου 2025	00:00	2,966	1			1	1	1	1			
	01:00	2,763	1			1	1	1				
	02:00	2,680	1			1	1	1				
	03:00	2,557	1			1	1	1				
	04:00	2,457	1			1	1	1				
	05:00	2,397	1			1	1	1				
	06:00	2,371	1			1	1	1				
	07:00	2,525	1			1	1	1				
	08:00	2,704	1			1	1	1				
	09:00	2,884	1			1	1	1	1			
	10:00	3,035	1			1	1	1	1			
	11:00	3,134	1			1	1	1	1			
	12:00	3,207	1			1	1	1	1			
	13:00	3,244	1			1	1	1	1			
	14:00	3,241	1			1	1	1	1			
	15:00	3,183	1			1	1	1	1			
	16:00	3,140	1			1	1	1	1			
	17:00	3,164	1			1	1	1	1			
	18:00	3,257	1			1	1	1	1			
	19:00	3,349	1			1	1	1	1			
	20:00	3,423	1			1	1	1	1			
	21:00	3,348	1			1	1	1	1			
	22:00	3,204	1			1	1	1	1			
	23:00	2,988	1			1	1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 31 Ιουλίου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Πέμπτη, 31 Ιουλίου 2025	00:00	2,845	1			1	1	1	1			
	01:00	2,729	1			1	1	1				
	02:00	2,603	1			1	1	1				
	03:00	2,501	1			1	1	1				
	04:00	2,422	1			1	1	1				
	05:00	2,351	1			1	1	1				
	06:00	2,331	1			1	1	1				
	07:00	2,492	1			1	1	1				
	08:00	2,669	1			1	1	1				
	09:00	2,834	1			1	1	1	1			
	10:00	2,976	1			1	1	1	1			
	11:00	3,098	1			1	1	1	1			
	12:00	3,181	1			1	1	1	1			
	13:00	3,221	1			1	1	1	1			
	14:00	3,211	1			1	1	1	1			
	15:00	3,148	1			1	1	1	1			
	16:00	3,202	1			1	1	1	1			
	17:00	3,204	1			1	1	1	1			
	18:00	3,261	1			1	1	1	1			
	19:00	3,330	1			1	1	1	1			
	20:00	3,407	1			1	1	1	1			
	21:00	3,312	1			1	1	1	1			
	22:00	3,162	1			1	1	1	1			
	23:00	2,941	1			1	1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 1 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Παρασκευή, 1 Αυγούστου 2025	00:00	2,728	1			1	1	1				
	01:00	2,681	1			1	1	1				
	02:00	2,564	1			1	1	1				
	03:00	2,469	1			1	1	1				
	04:00	2,395	1			1	1	1				
	05:00	2,352	1			1	1	1				
	06:00	2,346	1			1	1	1				
	07:00	2,447	1			1	1	1				
	08:00	2,610	1			1	1	1				
	09:00	2,789	1			1	1	1				
	10:00	2,940	1			1	1	1	1			
	11:00	3,070	1			1	1	1	1			
	12:00	3,168	1			1	1	1	1			
	13:00	3,226	1			1	1	1	1			
	14:00	3,229	1			1	1	1	1			
	15:00	3,175	1			1	1	1	1			
	16:00	3,153	1			1	1	1	1			
	17:00	3,141	1			1	1	1	1			
	18:00	3,192	1			1	1	1	1			
	19:00	3,264	1			1	1	1	1			
	20:00	3,361	1			1	1	1	1			
	21:00	3,261	1			1	1	1	1			
	22:00	3,118	1			1	1	1	1			
	23:00	2,911	1			1	1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 2 Αυγούστου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000		
Ρ	Θ	Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Σάββατο, 2 Αυγούστου 2025			00:00	2,762	1			1	1	1				
			01:00	2,651	1			1	1	1				
			02:00	2,546	1			1	1	1				
			03:00	2,451	1			1	1	1				
			04:00	2,381	1			1	1	1				
			05:00	2,339	1			1	1	1				
			06:00	2,335	1			1	1	1				
			07:00	2,419	1			1	1	1				
			08:00	2,564	1			1	1	1				
			09:00	2,734	1			1	1	1				
			10:00	2,891	1			1	1	1	1			
			11:00	3,023	1			1	1	1	1			
			12:00	3,124	1			1	1	1	1			
			13:00	3,194	1			1	1	1	1			
			14:00	3,218	1			1	1	1	1			
			15:00	3,191	1			1	1	1	1			
			16:00	3,154	1			1	1	1	1			
			17:00	3,147	1			1	1	1	1			
			18:00	3,197	1			1	1	1	1			
			19:00	3,269	1			1	1	1	1			
			20:00	3,373	1			1	1	1	1			
			21:00	3,247	1			1	1	1	1			
			22:00	3,107	1			1	1	1	1			
			23:00	2,896	1			1	1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 3 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ α χ ή	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Κυριακή, 3 Αυγούστου 2025	00:00	2,721	1			1	1	1				
	01:00	2,651	1			1	1	1				
	02:00	2,534	1			1	1	1				
	03:00	2,435	1			1	1	1				
	04:00	2,361	1			1	1	1				
	05:00	2,314	1			1	1	1				
	06:00	2,307	1			1	1	1				
	07:00	2,377	1			1	1	1				
	08:00	2,507	1			1	1	1				
	09:00	2,679	1			1	1	1				
	10:00	2,839	1			1	1	1	1			
	11:00	2,980	1			1	1	1	1			
	12:00	3,086	1			1	1	1	1			
	13:00	3,146	1			1	1	1	1			
	14:00	3,166	1			1	1	1	1			
	15:00	3,132	1			1	1	1	1			
	16:00	3,089	1			1	1	1	1			
	17:00	3,089	1			1	1	1	1			
	18:00	3,141	1			1	1	1	1			
	19:00	3,212	1			1	1	1	1			
	20:00	3,294	1			1	1	1	1			
	21:00	3,176	1			1	1	1	1			
	22:00	3,032	1			1	1	1	1			
	23:00	2,737	1			1	1	1				

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 4 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
α ρ ε τ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (X1)
Δευτέρα, 4 Αυγούστου 2025	00:00	2,705	1			1	1	1				
	01:00	2,592	1			1	1	1				
	02:00	2,482	1			1	1	1				
	03:00	2,386	1			1	1	1				
	04:00	2,312	1			1	1	1				
	05:00	2,274	1			1	1	1				
	06:00	2,267	1			1	1	1				
	07:00	2,387	1			1	1	1				
	08:00	2,557	1			1	1	1				
	09:00	2,757	1			1	1	1				
	10:00	2,918	1			1	1	1	1			
	11:00	3,046	1			1	1	1	1			
	12:00	3,148	1			1	1	1	1			
	13:00	3,213	1			1	1	1	1			
	14:00	3,230	1			1	1	1	1			
	15:00	3,179	1			1	1	1	1			
	16:00	3,117	1			1	1	1	1			
	17:00	3,101	1			1	1	1	1			
	18:00	3,151	1			1	1	1	1			
	19:00	3,225	1			1	1	1	1			
	20:00	3,358	1			1	1	1	1			
	21:00	3,185	1			1	1	1	1			
	22:00	3,024	1			1	1	1	1			
	23:00	2,749	1			1	1	1				

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 5 Αυγούστου 2025					
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	1,000
Ρ	Θ	Ε	Σ	Ε	Σ	Ε	Ρ	Θ	Ε	Σ	Ε	Σ
Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x1)	
Τρίτη, 5 Αυγούστου 2025	00:00	2,721	1			1	1	1				
	01:00	2,597	1			1	1	1				
	02:00	2,477	1			1	1	1				
	03:00	2,370	1			1	1	1				
	04:00	2,285	1			1	1	1				
	05:00	2,256	1			1	1	1				
	06:00	2,258	1			1	1	1				
	07:00	2,362	1			1	1	1				
	08:00	2,547	1			1	1	1				
	09:00	2,756	1			1	1	1				
	10:00	2,922	1			1	1	1	1			
	11:00	3,052	1			1	1	1	1			
	12:00	3,154	1			1	1	1	1			
	13:00	3,228	1			1	1	1	1			
	14:00	3,261	1			1	1	1	1			
	15:00	3,225	1			1	1	1	1			
	16:00	3,171	1			1	1	1	1			
	17:00	3,153	1			1	1	1	1			
	18:00	3,199	1			1	1	1	1			
	19:00	3,268	1			1	1	1	1			
	20:00	3,395	1			1	1	1	1			
	21:00	3,237	1			1	1	1	1			
	22:00	3,078	1			1	1	1	1			
	23:00	2,803	1			1	1	1				

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης