

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 7 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 7 Οκτωβρίου 2025	00:00	1,155			1	1		
	01:00	1,146			1	1		
	02:00	1,122			1	1		
	03:00	1,074			1	1		
	04:00	1,056			1	1		
	05:00	1,070			1	1		
	06:00	1,122			1	1		
	07:00	1,203			1	1		
	08:00	1,326			1	1		
	09:00	1,485			1	1		
	10:00	1,468			1	1		
	11:00	1,531			1	1		
	12:00	1,600			1	1		
	13:00	1,556			1	1		
	14:00	1,526			1	1		
	15:00	1,519			1	1		
	16:00	1,454			1	1		
	17:00	1,473			1	1		
	18:00	1,574			1	1		
	19:00	1,677			1	1		
	20:00	1,644			1	1		
	21:00	1,571			1	1		
	22:00	1,242			1	1		
	23:00	1,060			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 8 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 8 Οκτωβρίου 2025	00:00	0,990			1	1		
	01:00	0,904			1	1		
	02:00	0,863			1	1		
	03:00	0,866			1	1		
	04:00	0,872			1	1		
	05:00	0,892			1	1		
	06:00	0,977			1	1		
	07:00	1,111			1	1		
	08:00	1,285			1	1		
	09:00	1,321			1	1		
	10:00	1,332			1	1		
	11:00	1,211			1	1		
	12:00	1,215			1	1		
	13:00	1,245			1	1		
	14:00	1,234			1	1		
	15:00	1,287			1	1		
	16:00	1,285			1	1		
	17:00	1,392			1	1		
	18:00	1,494			1	1		
	19:00	1,624			1	1		
	20:00	1,539			1	1		
	21:00	1,439			1	1		
	22:00	1,340			1	1		
	23:00	1,199			1	1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 9 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 9 Οκτωβρίου 2025	00:00	1,108			1	1		
	01:00	1,059			1	1		
	02:00	1,036			1	1		
	03:00	1,007			1	1		
	04:00	1,007			1	1		
	05:00	1,026			1	1		
	06:00	1,075			1	1		
	07:00	1,192			1	1		
	08:00	1,307			1	1		
	09:00	1,309			1	1		
	10:00	1,300			1	1		
	11:00	1,304			1	1		
	12:00	1,277			1	1		
	13:00	1,266			1	1		
	14:00	1,248			1	1		
	15:00	1,239			1	1		
	16:00	1,273			1	1		
	17:00	1,282			1	1		
	18:00	1,425			1	1		
	19:00	1,592			1	1		
	20:00	1,560			1	1		
	21:00	1,456			1	1		
	22:00	1,344			1	1		
	23:00	1,197			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 10 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 10 Οκτωβρίου 2025	00:00	1,104			1	1		
	01:00	0,994			1	1		
	02:00	0,930			1	1		
	03:00	0,932			1			
	04:00	0,931			1			
	05:00	0,899			1			
	06:00	0,957			1			
	07:00	1,040			1	1		
	08:00	1,168			1	1		
	09:00	1,237			1	1		
	10:00	1,275			1	1		
	11:00	1,228			1	1		
	12:00	1,267			1	1		
	13:00	1,221			1	1		
	14:00	1,239			1	1		
	15:00	1,215			1	1		
	16:00	1,203			1	1		
	17:00	1,266			1	1		
	18:00	1,398			1	1		
	19:00	1,547			1	1		
	20:00	1,495			1	1		
	21:00	1,348			1	1		
	22:00	1,248			1	1		
	23:00	1,117			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 11 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 11 Οκτωβρίου 2025	00:00	1,080			1	1		
	01:00	1,020			1	1		
	02:00	0,952			1			
	03:00	0,953			1			
	04:00	0,951			1			
	05:00	0,969			1	1		
	06:00	1,011			1	1		
	07:00	1,132			1	1		
	08:00	1,321			1	1		
	09:00	1,334			1	1		
	10:00	1,344			1	1		
	11:00	1,286			1	1		
	12:00	1,319			1	1		
	13:00	1,299			1	1		
	14:00	1,245			1	1		
	15:00	1,261			1	1		
	16:00	1,261			1	1		
	17:00	1,333			1	1		
	18:00	1,435			1	1		
	19:00	1,501			1	1		
	20:00	1,413			1	1		
	21:00	1,366			1	1		
	22:00	1,242			1	1		
	23:00	1,069			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 12 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 12 Οκτωβρίου 2025	00:00	1,002			1	1		
	01:00	0,945			1	1		
	02:00	0,914			1			
	03:00	0,900			1			
	04:00	0,917			1			
	05:00	0,908			1	1		
	06:00	0,930			1	1		
	07:00	0,966			1	1		
	08:00	1,056			1	1		
	09:00	1,131			1	1		
	10:00	1,126			1	1		
	11:00	1,184			1	1		
	12:00	1,262			1	1		
	13:00	1,221			1	1		
	14:00	1,168			1	1		
	15:00	1,109			1	1		
	16:00	1,150			1	1		
	17:00	1,201			1	1		
	18:00	1,324			1	1		
	19:00	1,507			1	1		
	20:00	1,495			1	1		
	21:00	1,375		1		1		
	22:00	1,226		1		1		
	23:00	1,117		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 13 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 13 Οκτωβρίου 2025	00:00	1,044		1		1		
	01:00	1,004		1		1		
	02:00	0,959		1				
	03:00	0,969		1				
	04:00	0,989		1				
	05:00	1,001		1				
	06:00	1,048		1				
	07:00	1,121		1		1		
	08:00	1,249		1		1		
	09:00	1,213		1		1		
	10:00	1,203		1		1		
	11:00	1,222		1		1		
	12:00	1,260		1		1		
	13:00	1,209		1		1		
	14:00	1,240		1		1		
	15:00	1,172		1		1		
	16:00	1,208		1		1		
	17:00	1,240		1		1		
	18:00	1,359		1		1		
	19:00	1,511		1		1		
	20:00	1,482		1		1		
	21:00	1,336		1		1		
	22:00	1,203		1		1		
	23:00	1,094		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης