

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 14 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ ρ ε τ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 14 Οκτωβρίου 2025	00:00	1,042		1				
	01:00	0,968		1				
	02:00	0,900		1				
	03:00	0,903		1				
	04:00	0,914		1				
	05:00	0,964		1				
	06:00	1,039		1				
	07:00	1,040		1				
	08:00	1,158		1		1		
	09:00	1,176		1		1		
	10:00	1,165		1		1		
	11:00	1,111		1		1		
	12:00	1,120		1		1		
	13:00	1,189		1		1		
	14:00	1,160		1		1		
	15:00	1,074		1		1		
	16:00	1,133		1		1		
	17:00	1,226		1		1		
	18:00	1,344		1		1		
	19:00	1,553		1		1		
	20:00	1,488		1		1		
	21:00	1,370		1		1		
	22:00	1,222		1		1		
	23:00	1,088		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 15 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 15 Οκτωβρίου 2025	00:00	1,046		1		1		
	01:00	0,995		1		1		
	02:00	0,963		1				
	03:00	0,944		1				
	04:00	0,976		1				
	05:00	0,998		1				
	06:00	1,049		1				
	07:00	1,072		1				
	08:00	1,165		1		1		
	09:00	1,220		1		1		
	10:00	1,205		1		1		
	11:00	1,219		1		1		
	12:00	1,191		1		1		
	13:00	1,136		1		1		
	14:00	1,112		1		1		
	15:00	1,082		1		1		
	16:00	1,121		1		1		
	17:00	1,230		1		1		
	18:00	1,387		1		1		
	19:00	1,507		1		1		
	20:00	1,476		1		1		
	21:00	1,362		1		1		
	22:00	1,187		1		1		
	23:00	1,105		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 16 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 16 Οκτωβρίου 2025	00:00	1,056		1		1		
	01:00	1,043		1		1		
	02:00	0,977		1		1		
	03:00	0,914		1				
	04:00	0,850		1				
	05:00	0,861		1				
	06:00	0,911		1				
	07:00	0,955		1				
	08:00	1,064		1				
	09:00	1,109		1		1		
	10:00	1,152		1		1		
	11:00	1,120		1		1		
	12:00	1,104		1		1		
	13:00	1,077		1	1	1		
	14:00	1,062		1		1		
	15:00	1,034		1		1		
	16:00	1,079		1		1		
	17:00	1,163		1		1		
	18:00	1,257		1		1		
	19:00	1,365		1		1		
	20:00	1,348		1		1		
	21:00	1,333		1		1		
	22:00	1,227		1		1		
	23:00	1,127		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 17 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 17 Οκτωβρίου 2025	00:00	1,043		1		1		
	01:00	0,982		1		1		
	02:00	0,935		1				
	03:00	0,929		1				
	04:00	0,952		1				
	05:00	0,958		1				
	06:00	1,013		1				
	07:00	1,063		1				
	08:00	1,110		1		1		
	09:00	1,163		1		1		
	10:00	1,121		1		1		
	11:00	1,176		1		1		
	12:00	1,100		1		1		
	13:00	1,023		1		1		
	14:00	1,001		1		1		
	15:00	1,028		1		1		
	16:00	1,091		1		1		
	17:00	1,206		1		1		
	18:00	1,322		1		1		
	19:00	1,398		1		1		
	20:00	1,299		1		1		
	21:00	1,171		1		1		
	22:00	1,092		1		1		
	23:00	1,043		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 18 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 18 Οκτωβρίου 2025	00:00	0,995		1		1		
	01:00	0,968		1		1		
	02:00	0,848		1				
	03:00	0,828		1				
	04:00	0,850		1				
	05:00	0,889		1				
	06:00	0,931		1				
	07:00	1,006		1				
	08:00	1,049		1				
	09:00	1,046		1				
	10:00	1,073		1		1		
	11:00	1,059		1		1		
	12:00	1,156		1		1		
	13:00	1,182		1		1		
	14:00	1,139		1		1		
	15:00	1,150		1		1		
	16:00	1,228		1		1		
	17:00	1,204		1		1		
	18:00	1,356		1		1		
	19:00	1,482		1		1		
	20:00	1,453		1		1		
	21:00	1,370		1		1		
	22:00	1,240		1		1		
	23:00	1,112		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 19 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η ε ξ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 19 Οκτωβρίου 2025	00:00	1,066		1		1		
	01:00	0,994		1		1		
	02:00	0,949				1		
	03:00	0,942				1		
	04:00	0,943				1		
	05:00	0,946				1		
	06:00	0,968				1		
	07:00	1,009				1		
	08:00	1,048				1		
	09:00	1,068		1		1		
	10:00	1,181		1		1		
	11:00	1,274		1		1		
	12:00	1,251		1		1		
	13:00	1,244		1		1		
	14:00	1,235		1		1		
	15:00	1,228		1		1		
	16:00	1,249		1		1		
	17:00	1,272		1		1		
	18:00	1,224		1		1		
	19:00	1,319		1		1		
	20:00	1,325		1		1		
	21:00	1,232		1		1		
	22:00	1,120		1		1		
	23:00	1,070		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 20 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 20 Οκτωβρίου 2025	00:00	0,981		1		1		
	01:00	0,947		1		1		
	02:00	0,926		1				
	03:00	0,918		1				
	04:00	0,924		1				
	05:00	0,946		1				
	06:00	0,965		1				
	07:00	1,058		1				
	08:00	1,174		1		1		
	09:00	1,270		1		1		
	10:00	1,322		1		1		
	11:00	1,350		1		1		
	12:00	1,322		1		1		
	13:00	1,259		1		1		
	14:00	1,301		1		1		
	15:00	1,334		1		1		
	16:00	1,305		1		1		
	17:00	1,288		1		1		
	18:00	1,330		1		1		
	19:00	1,383		1		1		
	20:00	1,354		1		1		
	21:00	1,287		1		1		
	22:00	1,123		1		1		
	23:00	1,062		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης