

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 16 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 16 Σεπτεμβρίου 2025	00:00	1,587			1	1		
	01:00	1,470			1	1		
	02:00	1,385			1	1		
	03:00	1,366			1	1		
	04:00	1,343			1	1		
	05:00	1,358			1	1		
	06:00	1,404			1	1		
	07:00	1,515			1	1		
	08:00	1,687			1	1		
	09:00	1,777			1	1		
	10:00	1,812			1	1		
	11:00	1,748			1	1		
	12:00	1,771			1	1		
	13:00	1,778			1	1		
	14:00	1,700			1	1		
	15:00	1,693			1	1		
	16:00	1,699			1	1		
	17:00	1,715			1	1		
	18:00	1,859			1	1		
	19:00	2,059		1	1	1		
	20:00	2,127		1	1	1		
	21:00	2,009		1	1	1		
	22:00	1,840		1	1	1		
	23:00	1,706			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 17 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ ρ ε μ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 17 Σεπτεμβρίου 2025	00:00	1,526			1	1		
	01:00	1,422			1	1		
	02:00	1,386			1	1		
	03:00	1,374			1	1		
	04:00	1,366			1	1		
	05:00	1,375			1	1		
	06:00	1,453			1	1		
	07:00	1,540			1	1		
	08:00	1,649			1	1		
	09:00	1,713			1	1		
	10:00	1,701			1	1		
	11:00	1,704			1	1		
	12:00	1,674			1	1		
	13:00	1,655			1	1		
	14:00	1,620			1	1		
	15:00	1,596			1	1		
	16:00	1,610			1	1		
	17:00	1,635			1	1		
	18:00	1,763			1	1		
	19:00	1,998		1	1	1		
	20:00	2,024		1	1	1		
	21:00	1,912		1	1	1		
	22:00	1,789		1	1	1		
	23:00	1,593			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 18 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 18 Σεπτεμβρίου 2025	00:00	1,432			1	1		
	01:00	1,347			1	1		
	02:00	1,296			1	1		
	03:00	1,330			1	1		
	04:00	1,305			1	1		
	05:00	1,286			1	1		
	06:00	1,289			1	1		
	07:00	1,380			1	1		
	08:00	1,607			1	1		
	09:00	1,832			1	1		
	10:00	1,795			1	1		
	11:00	1,767			1	1		
	12:00	1,826			1	1		
	13:00	1,816			1	1		
	14:00	1,742			1	1		
	15:00	1,708			1	1		
	16:00	1,685			1	1		
	17:00	1,724			1	1		
	18:00	1,868			1	1		
	19:00	2,041		1	1	1		
	20:00	2,082		1	1	1		
	21:00	1,910		1	1	1		
	22:00	1,783		1	1	1		
	23:00	1,623		1	1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 19 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 19 Σεπτεμβρίου 2025	00:00	1,480			1	1		
	01:00	1,406			1	1		
	02:00	1,309			1	1		
	03:00	1,306			1	1		
	04:00	1,304			1	1		
	05:00	1,356			1	1		
	06:00	1,383			1	1		
	07:00	1,357			1	1		
	08:00	1,434			1	1		
	09:00	1,524			1	1		
	10:00	1,554			1	1		
	11:00	1,614			1	1		
	12:00	1,619			1	1		
	13:00	1,616			1	1		
	14:00	1,648			1	1		
	15:00	1,586			1	1		
	16:00	1,652			1	1		
	17:00	1,698			1	1		
	18:00	1,787			1	1		
	19:00	1,971			1	1		
	20:00	2,021		1	1	1		
	21:00	1,843			1	1		
	22:00	1,733			1	1		
	23:00	1,479			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 20 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 20 Σεπτεμβρίου 2025	00:00	1,322			1	1		
	01:00	1,214			1	1		
	02:00	1,194			1	1		
	03:00	1,182			1	1		
	04:00	1,184			1	1		
	05:00	1,168			1	1		
	06:00	1,198			1	1		
	07:00	1,280			1	1		
	08:00	1,409			1	1		
	09:00	1,489			1	1		
	10:00	1,604			1	1		
	11:00	1,705			1	1		
	12:00	1,701			1	1		
	13:00	1,663			1	1		
	14:00	1,621			1	1		
	15:00	1,550			1	1		
	16:00	1,550			1	1		
	17:00	1,595			1	1		
	18:00	1,726			1	1		
	19:00	1,897			1	1		
	20:00	1,898			1	1		
	21:00	1,728			1	1		
	22:00	1,593			1	1		
	23:00	1,524			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 21 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ ρ ε μ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 21 Σεπτεμβρίου 2025	00:00	1,382			1	1		
	01:00	1,289			1	1		
	02:00	1,249			1	1		
	03:00	1,237			1	1		
	04:00	1,215			1	1		
	05:00	1,218			1	1		
	06:00	1,211			1	1		
	07:00	1,263			1	1		
	08:00	1,413			1	1		
	09:00	1,522			1	1		
	10:00	1,612			1	1		
	11:00	1,632			1	1		
	12:00	1,644			1	1		
	13:00	1,661			1	1		
	14:00	1,609			1	1		
	15:00	1,563			1	1		
	16:00	1,558			1	1		
	17:00	1,576			1	1		
	18:00	1,670			1	1		
	19:00	1,913			1	1		
	20:00	1,922			1	1		
	21:00	1,775			1	1		
	22:00	1,622			1	1		
	23:00	1,535			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 22 Σεπτεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 22 Σεπτεμβρίου 2025	00:00	1,390			1	1		
	01:00	1,256			1	1		
	02:00	1,215			1	1		
	03:00	1,217			1	1		
	04:00	1,185			1	1		
	05:00	1,048			1	1		
	06:00	1,072			1	1		
	07:00	1,166			1	1		
	08:00	1,395			1	1		
	09:00	1,498			1	1		
	10:00	1,532			1	1		
	11:00	1,635			1	1		
	12:00	1,737			1	1		
	13:00	1,676			1	1		
	14:00	1,760			1	1		
	15:00	1,746			1	1		
	16:00	1,737			1	1		
	17:00	1,809			1	1		
	18:00	1,848			1	1		
	19:00	2,013			1	1		
	20:00	2,009			1	1		
	21:00	1,892			1	1		
	22:00	1,782			1	1		
	23:00	1,626			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης