

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογισμός Λειτουργίας									Κυριακή, 20 Ιουλίου 2025														
Αποδιδόμενη Ισχύς (MW)						9,000	11,000	11,000	11,000	16,000	16,000	11,000	11,500	11,500	23,100	1,500	1,300	1,300	5,000	5,000	5,000	7,200				
Α	Σ	Ρ	Ε	Τ	Η	ΑΣΠ Κω										ΑΣΠ Καλύμνου						Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)			
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ G34	MTU 9-11	G1	G2	G3	G4	G5			G6		
Κυριακή, 20 Ιουλίου 2025						00:00	74,04	67,82	5,93	0,30	1	1	1	1	1	1					1	1	1	1	16,10	16,10
						01:00	74,35	68,40	5,82	0,12	1	1	1	1	1	1					1	1	1	1	16,10	16,10
						02:00	70,20	64,25	5,82	0,13	1	1	1	1	1	1					1	1	1		16,10	16,10
						03:00	67,57	60,58	6,87	0,12	1	1	1	1	1	1					1	1	1		16,10	16,10
						04:00	66,19	57,28	8,71	0,21	1	1	1	1	1	1					1	1	1		16,10	16,10
						05:00	64,77	56,42	7,95	0,40	1	1	1	1	1	1					1	1	1		16,10	16,10
						06:00	63,95	56,45	7,40	0,09	1	1	1	1	1	1					1	1	1		16,10	16,10
						07:00	69,31	61,21	8,04	0,06	1	1	1	1	1	1					1	1	1		16,10	16,10
						08:00	77,28	69,53	7,63	0,12	1	1	1	1	1	1					1	1	1		16,10	16,10
						09:00	77,92	71,17	6,53	0,21	1	1		1	1	1					1	1	1	1	16,10	16,10
						10:00	78,08	71,68	6,22	0,18	1	1	1	1	1	1					1	1	1	1	16,10	16,10
						11:00	77,44	70,93	6,43	0,07		1	1	1	1	1					1	1	1	1	16,10	16,10
						12:00	78,74	72,84	5,53	0,37		1	1	1	1	1					1	1	1	1	16,10	16,10
						13:00	80,03	74,66	5,12	0,25		1	1	1	1	1					1	1	1	1	16,10	16,10
						14:00	80,34	74,92	5,42	0,00		1	1	1	1	1					1	1	1	1	16,10	16,10
						15:00	80,66	72,03	8,61	0,03		1	1	1	1	1					1	1	1	1	16,10	16,10
						16:00	82,40	74,05	8,35	0,00		1	1	1	1	1					1	1	1	1	16,10	16,10
						17:00	85,94	78,01	7,78	0,15		1	1	1	1	1					1	1	1	1	16,10	16,10
						18:00	90,30	81,79	8,10	0,40	1	1	1	1	1	1					1	1	1	1	16,10	16,10
						19:00	91,45	81,84	9,34	0,27	1	1	1	1	1	1					1	1	1	1	16,10	16,10
						20:00	91,33	81,45	9,72	0,17	1	1	1	1	1	1					1	1	1	1	16,10	16,10
						21:00	89,13	78,99	10,11	0,03	1	1	1	1	1	1					1	1	1	1	16,10	16,10
						22:00	83,88	72,93	10,95	0,00	1	1	1	1	1	1					1	1	1	1	16,10	16,10
						23:00	78,45	68,07	10,38	0,00	1	1	1	1	1	1					1	1	1	1	16,10	16,10

Το ΑΠ ΚΕΦΑΛΟΣ 1 παρουσίαζε προβλήματα επικοινωνίας καθόλη τη διάρκεια της ημέρας. Στις 05:15 πραγματοποιήθηκαν εργασίες στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης