

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογισμός Λειτουργίας										Πέμπτη, 31 Ιουλίου 2025																					
			Αποδιδόμενη Ισχύς (MW)				9,000	11,000	11,000	11,000	16,000	16,000	11,000	11,500	11,500	23,100	1,500	1,300	1,300	5,000	5,000	5,000	7,200											
Α	Χ	Ε	Σ	Τ	Ε	ΑΣΠ Κω										ΑΣΠ Καλύμνου						Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)											
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ G34	MTU 9-11	G1	G2	G3	G4	G5			G6										
Πέμπτη, 31 Ιουλίου 2025		00:00			78,32	78,27	0,04	0,01	1	1	1	1	1		1	1	1				1	1	1	1	16,10	16,10								
		01:00			72,94	72,85	0,08	0,01	1	1	1	1	1		1	1	1				1	1	1	1	16,10	16,10								
		02:00			68,90	68,69	0,20	0,01	1	1	1	1	1			1	1					1	1	1	1	16,10	16,10							
		03:00			66,50	66,00	0,49	0,01	1	1	1	1	1				1	1					1	1	1	1	16,10	16,10						
		04:00			65,35	64,19	1,15	0,01	1	1	1	1	1	1			1	1	1					1	1	1	1	16,10	16,10					
		05:00			65,69	64,10	1,58	0,01	1	1	1	1	1	1				1	1						1	1	1	1	16,10	15,80				
		06:00			66,86	65,20	1,65	0,01	1	1	1	1	1	1				1	1						1	1	1	1	16,10	16,10				
		07:00			75,47	74,03	1,44	0,01	1	1	1	1	1	1	1			1	1	1	1					1	1	1	1	16,10	16,10			
		08:00			83,40	81,58	1,82	0,01	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10			
		09:00			91,14	88,80	2,32	0,01	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10		
		10:00			93,81	91,68	2,03	0,10	1	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10	
		11:00			94,27	92,93	1,13	0,21	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10		
		12:00			96,39	95,46	0,52	0,41	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10		
		13:00			99,33	97,79	1,14	0,41	1	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10	
		14:00			100,18	98,16	1,61	0,41	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10		
		15:00			98,32	96,26	1,65	0,41	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10		
		16:00			98,80	96,12	2,27	0,41	1	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10	
		17:00			103,35	100,15	2,79	0,41	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10		
		18:00			108,12	105,23	2,46	0,43	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10		
		19:00			107,12	104,54	2,12	0,46	1	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10	
		20:00			104,28	100,01	3,73	0,55	1	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10	
		21:00			100,03	94,64	4,79	0,60	1	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10	
		22:00			93,16	87,59	4,88	0,68	1	1	1	1	1	1	1	1	1				1	1	1	1					1	1	1	1	16,10	16,10
		23:00			88,59	81,07	7,02	0,51	1	1	1	1	1	1	1					1	1							1	1	1	1	16,10	16,10	

Το ΑΠ ΚΕΦΑΛΟΣ 1 παρουσίαζε προβλήματα επικοινωνίας καθόλη τη διάρκεια της ημέρας.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης