

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Πέμπτη, 23 Οκτωβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 23 Οκτωβρίου 2025	00:00	61		1					
	01:00	58		1					
	02:00	56		1					
	03:00	55		1					
	04:00	55		1					
	05:00	55		1					
	06:00	56		1					
	07:00	58		1					
	08:00	55		1					
	09:00	56		1					
	10:00	55		1					
	11:00	55		1					
	12:00	56		1					
	13:00	57		1					
	14:00	57		1					
	15:00	57		1					
	16:00	58		1					
	17:00	61		1					
	18:00	62		1					
	19:00	72		1		1			
	20:00	74		1		1			
	21:00	75		1		1			
	22:00	75		1		1			
	23:00	79		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Παρασκευή, 24 Οκτωβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 24 Οκτωβρίου 2025	00:00	62		1					
	01:00	58		1					
	02:00	57		1					
	03:00	56		1					
	04:00	56		1					
	05:00	56		1					
	06:00	58		1					
	07:00	59		1					
	08:00	58		1					
	09:00	57		1					
	10:00	58		1					
	11:00	57		1					
	12:00	58		1					
	13:00	58		1					
	14:00	58		1					
	15:00	58		1					
	16:00	61		1					
	17:00	63		1					
	18:00	65		1		1			
	19:00	72		1		1			
	20:00	74		1		1			
	21:00	76		1		1			
	22:00	77		1		1			
	23:00	81		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Σάββατο, 25 Οκτωβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 25 Οκτωβρίου 2025	00:00	63		1					
	01:00	60		1					
	02:00	58		1					
	03:00	57		1					
	04:00	57		1					
	05:00	58		1					
	06:00	59		1					
	07:00	59		1					
	08:00	59		1					
	09:00	58		1					
	10:00	58		1					
	11:00	58		1					
	12:00	59		1					
	13:00	59		1					
	14:00	59		1					
	15:00	59		1					
	16:00	60		1					
	17:00	63		1					
	18:00	65		1		1			
	19:00	71		1		1			
	20:00	75		1		1			
	21:00	76		1		1			
	22:00	77		1		1			
	23:00	81		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Κυριακή, 26 Οκτωβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 26 Οκτωβρίου 2025	00:00	63		1					
	01:00	60		1					
	02:00	59		1					
	03:00	58		1					
	04:00	58		1					
	05:00	59		1					
	06:00	59		1					
	07:00	60		1					
	08:00	59		1					
	09:00	59		1					
	10:00	58		1					
	11:00	59		1					
	12:00	59		1					
	13:00	59		1					
	14:00	59		1					
	15:00	59		1					
	16:00	60		1					
	17:00	63		1					
	18:00	64		1		1			
	19:00	70		1		1			
	20:00	74		1		1			
	21:00	76		1		1			
	22:00	78		1		1			
	23:00	82		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Δευτέρα, 27 Οκτωβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 27 Οκτωβρίου 2025	00:00	58		1					
	01:00	62		1					
	02:00	60		1					
	03:00	60		1					
	04:00	59		1					
	05:00	59		1					
	06:00	60		1					
	07:00	61		1					
	08:00	59		1					
	09:00	60		1					
	10:00	58		1					
	11:00	60		1					
	12:00	62		1					
	13:00	62		1					
	14:00	61		1					
	15:00	62		1					
	16:00	63		1					
	17:00	64		1		1			
	18:00	66		1		1			
	19:00	71		1		1			
	20:00	74		1		1			
	21:00	76		1		1			
	22:00	79		1		1			
	23:00	82		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Τρίτη, 28 Οκτωβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 28 Οκτωβρίου 2025	00:00	62		1					
	01:00	60		1					
	02:00	60		1					
	03:00	59		1					
	04:00	58		1					
	05:00	57		1					
	06:00	58		1					
	07:00	58		1					
	08:00	58		1					
	09:00	58		1					
	10:00	58		1					
	11:00	57		1					
	12:00	58		1					
	13:00	58		1					
	14:00	58		1					
	15:00	57		1					
	16:00	58		1					
	17:00	59		1					
	18:00	61		1					
	19:00	67		1		1			
	20:00	70		1		1			
	21:00	72		1		1			
	22:00	75		1		1			
	23:00	79		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Τετάρτη, 29 Οκτωβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 29 Οκτωβρίου 2025	00:00	63		1					
	01:00	59		1					
	02:00	57		1					
	03:00	56		1					
	04:00	56		1					
	05:00	56		1					
	06:00	57		1					
	07:00	58		1					
	08:00	56		1					
	09:00	56		1					
	10:00	56		1					
	11:00	55		1					
	12:00	56		1					
	13:00	56		1					
	14:00	56		1					
	15:00	56		1					
	16:00	57		1					
	17:00	59		1					
	18:00	61		1					
	19:00	68		1		1			
	20:00	70		1		1			
	21:00	73		1		1			
	22:00	76		1		1			
	23:00	81		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης