

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 24 Σεπτεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 24 Σεπτεμβρίου 2025	00:00	1,254	1	1							
	01:00	1,157	1	1							
	02:00	1,112	1	1							
	03:00	1,112	1	1							
	04:00	1,098	1	1							
	05:00	1,142	1	1							
	06:00	1,236	1	1							
	07:00	1,239	1	1							
	08:00	1,323	1	1							
	09:00	1,308	1	1							
	10:00	1,333	1	1							
	11:00	1,370	1	1							
	12:00	1,386	1	1							
	13:00	1,426	1	1							
	14:00	1,418	1	1							
	15:00	1,381	1	1							
	16:00	1,386	1	1							
	17:00	1,428	1	1							
	18:00	1,529	1	1							
	19:00	1,674	1	1							
	20:00	1,711	1	1							
	21:00	1,582	1	1							
	22:00	1,461	1	1							
	23:00	1,337	1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 25 Σεπτεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000
Α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 25 Σεπτεμβρίου 2025	00:00	1,284	1	1							
	01:00	1,213	1	1							
	02:00	1,149	1	1							
	03:00	1,129	1	1							
	04:00	1,110	1	1							
	05:00	1,157	1	1							
	06:00	1,245	1						1		
	07:00	1,256	1						1		
	08:00	1,309	1						1		
	09:00	1,320	1						1		
	10:00	1,338	1						1		
	11:00	1,445	1						1		
	12:00	1,411	1						1		
	13:00	1,480	1						1		
	14:00	1,477	1						1		
	15:00	1,394	1						1		
	16:00	1,331	1						1		
	17:00	1,390	1						1		
	18:00	1,494	1						1		
	19:00	1,667	1						1		
	20:00	1,631	1						1		
	21:00	1,514	1						1		
	22:00	1,384	1						1		
	23:00	1,294	1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 26 Σεπτεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000
α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 26 Σεπτεμβρίου 2025	00:00	1,206	1	1							
	01:00	1,126	1	1							
	02:00	1,084	1	1							
	03:00	1,077	1	1							
	04:00	1,060	1	1							
	05:00	1,106	1	1							
	06:00	1,205	1	1							
	07:00	1,205	1	1							
	08:00	1,293	1	1							
	09:00	1,312	1	1							
	10:00	1,303	1	1							
	11:00	1,335	1	1							
	12:00	1,359	1	1							
	13:00	1,421	1	1							
	14:00	1,435	1	1							
	15:00	1,360	1	1							
	16:00	1,353	1	1							
	17:00	1,396	1	1							
	18:00	1,511	1	1							
	19:00	1,599	1	1							
	20:00	1,676	1	1							
	21:00	1,575	1	1							
	22:00	1,444	1	1							
	23:00	1,334	1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 27 Σεπτεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000
α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 27 Σεπτεμβρίου 2025	00:00	1,242	1	1							
	01:00	1,132	1	1							
	02:00	1,076	1	1							
	03:00	1,053	1	1							
	04:00	1,021	1	1							
	05:00	1,093	1	1							
	06:00	1,179	1	1							
	07:00	1,175	1	1							
	08:00	1,292	1	1							
	09:00	1,328	1	1							
	10:00	1,337	1	1							
	11:00	1,404	1	1							
	12:00	1,406	1	1							
	13:00	1,431	1	1							
	14:00	1,400	1	1							
	15:00	1,367	1	1							
	16:00	1,355	1	1							
	17:00	1,365	1	1							
	18:00	1,447	1	1							
	19:00	1,556	1	1							
	20:00	1,560	1	1							
	21:00	1,471	1	1							
	22:00	1,353	1	1							
	23:00	1,238	1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 28 Σεπτεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 28 Σεπτεμβρίου 2025	00:00	1,185	1	1							
	01:00	1,118	1	1							
	02:00	1,079	1	1							
	03:00	1,062	1	1							
	04:00	1,029	1	1							
	05:00	1,088	1	1							
	06:00	1,156	1	1							
	07:00	1,114	1	1							
	08:00	1,217	1	1							
	09:00	1,271	1	1							
	10:00	1,301	1	1							
	11:00	1,372	1	1							
	12:00	1,406	1	1							
	13:00	1,360	1	1							
	14:00	1,420	1	1							
	15:00	1,334	1	1							
	16:00	1,311	1	1							
	17:00	1,330	1	1							
	18:00	1,374	1	1							
	19:00	1,524	1	1							
	20:00	1,546	1	1							
	21:00	1,420	1	1							
	22:00	1,301	1	1							
	23:00	1,205	1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 29 Σεπτεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 29 Σεπτεμβρίου 2025	00:00	1,112	1	1							
	01:00	1,028	1	1							
	02:00	1,004	1	1							
	03:00	0,990	1	1							
	04:00	0,981	1	1							
	05:00	1,064	1	1							
	06:00	1,150	1	1							
	07:00	1,175	1	1							
	08:00	1,352	1	1							
	09:00	1,363	1	1							
	10:00	1,377	1	1							
	11:00	1,444	1	1							
	12:00	1,492	1	1							
	13:00	1,487	1	1							
	14:00	1,456	1	1							
	15:00	1,381	1	1							
	16:00	1,230	1	1							
	17:00	1,222	1	1							
	18:00	1,303	1	1							
	19:00	1,493	1	1							
	20:00	1,507	1	1							
	21:00	1,427	1	1							
	22:00	1,300	1	1							
	23:00	1,173	1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 30 Σεπτεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 30 Σεπτεμβρίου 2025	00:00	1,101	1	1							
	01:00	1,014	1	1							
	02:00	0,970	1	1							
	03:00	0,941	1	1							
	04:00	0,939	1	1							
	05:00	0,997	1	1							
	06:00	1,103	1	1							
	07:00	1,110	1	1							
	08:00	1,156	1	1							
	09:00	1,190		1					1		
	10:00	1,200		1					1		
	11:00	1,217		1					1		
	12:00	1,235		1					1		
	13:00	1,196		1					1		
	14:00	1,233		1					1		
	15:00	1,165		1					1		
	16:00	1,137		1					1		
	17:00	1,141		1					1		
	18:00	1,272		1					1		
	19:00	1,406		1					1		
	20:00	1,475		1					1		
	21:00	1,362		1					1		
	22:00	1,243		1					1		
	23:00	1,144		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης