

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 30 Ιουλίου 2025									
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τετάρτη, 30 Ιουλίου 2025	00:00	3,110	1	1								2
	01:00	2,817	1	1					1			2
	02:00	2,645	1	1					1			1
	03:00	2,540	1	1					1			1
	04:00	2,450	1	1					1			1
	05:00	2,401	1	1					1			1
	06:00	2,346	1	1								1
	07:00	2,457	1	1								1
	08:00	2,546	1	1					1			1
	09:00	2,723	1	1					1			1
	10:00	2,938	1	1					1			1
	11:00	3,127	1	1					1			1
	12:00	3,151	1	1					1			1
	13:00	3,311	1	1					1			1
	14:00	3,372	1	1					1	1		1
	15:00	3,379	1	1					1	1		1
	16:00	3,492	1	1					1	1		1
	17:00	3,541	1	1					1			2
	18:00	3,542	1	1								2
	19:00	3,560	1	1								2
	20:00	3,500	1	1								2
	21:00	3,490	1	1								2
	22:00	3,488	1	1								2
	23:00	3,351	1	1								2

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 31 Ιουλίου 2025									
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Πέμπτη, 31 Ιουλίου 2025	00:00	3,172	1	1								2
	01:00	2,912	1	1					1			2
	02:00	2,707	1	1					1			1
	03:00	2,628	1	1					1			1
	04:00	2,519	1	1					1			1
	05:00	2,458	1	1					1			1
	06:00	2,455	1						1			1
	07:00	2,465	1						1			1
	08:00	2,584	1	1					1			1
	09:00	2,801	1	1					1			1
	10:00	2,986	1	1					1			1
	11:00	3,195	1	1					1			1
	12:00	3,164	1	1					1			1
	13:00	3,286	1	1					1			1
	14:00	3,290	1	1					1			1
	15:00	3,345	1	1					1			1
	16:00	3,349	1	1					1			1
	17:00	3,338	1	1					1			2
	18:00	3,440	1	1								2
	19:00	3,453	1	1								2
	20:00	3,468	1	1								2
	21:00	3,445	1	1								2
	22:00	3,336	1	1								2
	23:00	3,172	1	1								2

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 1 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ Ε Σ Υ Λ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Παρασκευή, 1 Αυγούστου 2025	00:00	3,000	1	1								2
	01:00	2,716	1	1					1			2
	02:00	2,497	1	1					1			1
	03:00	2,378	1	1					1			1
	04:00	2,296	1	1					1			1
	05:00	2,243	1	1								1
	06:00	2,295	1	1								1
	07:00	2,314	1	1								1
	08:00	2,465	1	1								1
	09:00	2,507	1	1								1
	10:00	2,658	1	1					1			1
	11:00	2,767	1	1					1			1
	12:00	2,835	1	1					1			1
	13:00	2,953	1	1					1			1
	14:00	2,972	1	1					1			1
	15:00	2,948	1	1					1			1
	16:00	3,114	1	1					1			1
	17:00	3,196	1	1					1			2
	18:00	3,277	1	1								2
	19:00	3,339	1	1								2
	20:00	3,273	1	1								2
	21:00	3,407	1	1								2
	22:00	3,265	1	1								2
	23:00	3,123	1	1								2

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 2 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Σάββατο, 2 Αυγούστου 2025	00:00	2,925	1	1								2
	01:00	2,674	1	1					1			2
	02:00	2,530	1	1					1			1
	03:00	2,426	1	1					1			1
	04:00	2,354	1	1					1			1
	05:00	2,297	1	1								1
	06:00	2,348	1	1								1
	07:00	2,257	1	1								1
	08:00	2,537	1	1								1
	09:00	2,697	1	1					1			1
	10:00	2,844	1	1					1			1
	11:00	2,949	1	1					1			1
	12:00	2,992	1	1					1			1
	13:00	3,163	1	1					1			1
	14:00	3,149	1	1					1			1
	15:00	3,112	1	1					1			1
	16:00	3,181	1	1					1			1
	17:00	3,347	1	1					1			2
	18:00	3,501	1	1								2
	19:00	3,620	1	1					1			2
	20:00	3,549	1	1					1			2
	21:00	3,555	1	1					1			2
	22:00	3,365	1	1								2
	23:00	3,189	1	1								2

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 3 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Κυριακή, 3 Αυγούστου 2025	00:00	3,023	1	1					1			2
	01:00	2,801	1	1					1			1
	02:00	2,642	1	1					1			1
	03:00	2,537	1	1					1			1
	04:00	2,425	1	1					1			1
	05:00	2,367	1	1								1
	06:00	2,382	1	1								1
	07:00	2,389	1	1								1
	08:00	2,575	1	1					1			1
	09:00	2,757	1	1					1			1
	10:00	2,920	1	1					1			1
	11:00	3,018	1	1					1			1
	12:00	3,056	1	1					1			1
	13:00	3,163	1	1					1			1
	14:00	3,186	1	1					1			1
	15:00	3,116	1	1					1			1
	16:00	3,073	1	1					1			1
	17:00	3,126	1	1					1			2
	18:00	3,226	1	1								2
	19:00	3,338	1	1								2
	20:00	3,325	1	1								2
	21:00	3,421	1	1								2
	22:00	3,243	1	1								2
	23:00	3,119	1	1								2

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 4 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Δευτέρα, 4 Αυγούστου 2025	00:00	2,949	1	1					1			2
	01:00	2,664	1	1					1			1
	02:00	2,512	1	1					1			1
	03:00	2,398	1	1					1			1
	04:00	2,314	1	1					1			1
	05:00	2,257	1	1								1
	06:00	2,294	1	1								1
	07:00	2,327	1	1								1
	08:00	2,509	1	1								1
	09:00	2,789	1	1							1	1
	10:00	3,028	1	1							1	1
	11:00	3,084	1	1							1	1
	12:00	3,174	1	1					1		1	1
	13:00	3,222	1	1					1			1
	14:00	3,322	1	1					1			1
	15:00	3,419	1	1					1			1
	16:00	3,424	1	1					1			1
	17:00	3,477	1	1					1			2
	18:00	3,606	1	1					1			2
	19:00	3,690	1	1					1			2
	20:00	3,643	1	1					1			2
	21:00	3,724	1	1					1			2
	22:00	3,575	1	1					1			2
	23:00	3,403	1	1					1			2

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 5 Αυγούστου 2025									
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ Ε Σ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τρίτη, 5 Αυγούστου 2025	00:00	3,154	1	1					1			2
	01:00	2,865	1	1					1			1
	02:00	2,630	1	1					1			1
	03:00	2,463	1	1					1			1
	04:00	2,354	1	1					1			1
	05:00	2,329	1	1					1			1
	06:00	2,343		1					1			1
	07:00	2,396		1					1			1
	08:00	2,602		1					1	1		1
	09:00	2,862		1					1	1		1
	10:00	3,049	1	1					1	1		1
	11:00	3,069	1	1					1			1
	12:00	3,185	1	1					1			1
	13:00	3,272	1	1					1			1
	14:00	3,367	1	1					1	1		1
	15:00	3,427	1	1					1	1		1
	16:00	3,417	1	1					1	1		1
	17:00	3,493	1	1					1			2
	18:00	3,576	1	1					1			2
	19:00	3,631	1	1					1			2
	20:00	3,604	1	1					1			2
	21:00	3,630	1	1					1			2
	22:00	3,378	1	1					1			2
	23:00	3,246	1	1					1			2

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης