

ΗΣ ΚΥΘΟΝΟΥ		Προτεινόμενος ΗΕΠ				Πέμπτη, 21 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Η Ρ Ε Τ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Πέμπτη, 21 Αυγούστου 2025	00:00	2,807	1	1					1	1		
	01:00	2,647	1	1					1	1		
	02:00	2,545	1	1					1	1		
	03:00	2,366	1	1					1			
	04:00	2,250	1	1					1			
	05:00	2,182	1	1					1			
	06:00	2,133	1	1					1			
	07:00	2,171	1	1					1			
	08:00	2,342	1	1					1			1
	09:00	2,557	1	1					1			1
	10:00	2,786	1	1					1			1
	11:00	2,904	1	1					1			1
	12:00	2,947	1	1					1			1
	13:00	2,968	1	1					1			1
	14:00	3,000	1	1					1			1
	15:00	3,026	1	1					1			1
	16:00	3,059	1	1					1			1
	17:00	3,147	1	1					1			1
	18:00	3,278	1	1					1			2
	19:00	3,387	1	1					1			2
	20:00	3,442	1	1					1			2
	21:00	3,369	1	1					1			2
	22:00	3,160	1	1					1			1
	23:00	2,879	1	1					1			1

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 22 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Παρασκευή, 22 Αυγούστου 2025	00:00	2,814	1	1					1	1		
	01:00	2,674	1	1					1	1		
	02:00	2,520	1	1					1	1		
	03:00	2,384	1	1					1			
	04:00	2,266	1	1					1			
	05:00	2,179	1	1					1			
	06:00	2,124	1	1					1			
	07:00	2,161	1	1					1			
	08:00	2,324	1	1					1			1
	09:00	2,531	1	1					1			1
	10:00	2,756	1	1					1			1
	11:00	2,895	1	1					1			1
	12:00	2,968	1	1					1			1
	13:00	3,004	1	1					1			1
	14:00	3,033	1	1					1			1
	15:00	3,040	1	1					1			1
	16:00	3,218	1	1					1			1
	17:00	3,280	1	1					1			2
	18:00	3,394	1	1					1			2
	19:00	3,459	1	1					1			2
	20:00	3,489	1	1					1			2
	21:00	3,443	1	1					1			2
	22:00	3,231	1	1					1			1
	23:00	2,918	1	1					1			1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 23 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Σάββατο, 23 Αυγούστου 2025	00:00	2,869	1	1					1	1		
	01:00	2,736	1	1					1	1		
	02:00	2,604	1	1					1	1		
	03:00	2,481	1	1					1	1		
	04:00	2,382	1	1					1			
	05:00	2,307	1	1					1			
	06:00	2,250	1	1					1			
	07:00	2,249	1	1					1			
	08:00	2,428	1	1					1			1
	09:00	2,640	1	1					1			1
	10:00	2,878	1	1					1			1
	11:00	3,028	1	1					1			1
	12:00	3,104	1	1					1			1
	13:00	3,150	1	1					1			1
	14:00	3,171	1	1					1			1
	15:00	3,186	1	1					1			1
	16:00	3,248	1	1					1			1
	17:00	3,293	1	1					1			2
	18:00	3,388	1	1					1			2
	19:00	3,442	1	1					1			2
	20:00	3,361	1	1					1			2
	21:00	3,309	1	1					1			2
	22:00	3,121	1	1					1			1
	23:00	2,851	1	1					1			1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 24 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Κυριακή, 24 Αυγούστου 2025	00:00	2,929	1	1					1	1		
	01:00	2,811	1	1					1	1		
	02:00	2,682	1	1					1	1		
	03:00	2,555	1	1					1	1		
	04:00	2,443	1	1					1			
	05:00	2,348	1	1					1			
	06:00	2,279	1	1					1			
	07:00	2,252	1	1					1			
	08:00	2,397	1	1					1			1
	09:00	2,559	1	1					1			1
	10:00	2,750	1	1					1			1
	11:00	2,868	1	1					1			1
	12:00	2,920	1	1					1			1
	13:00	2,941	1	1					1			1
	14:00	2,945	1	1					1			1
	15:00	2,941	1	1					1			1
	16:00	2,948	1	1					1			1
	17:00	2,985	1	1					1			1
	18:00	3,063	1	1					1			1
	19:00	3,138	1	1					1			1
	20:00	3,126	1	1					1			1
	21:00	3,111	1	1					1			1
	22:00	2,975	1	1					1			1
	23:00	2,754	1	1					1			1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 25 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Δευτέρα, 25 Αυγούστου 2025	00:00	2,882	1	1					1	1		
	01:00	2,725	1	1					1	1		
	02:00	2,565	1	1					1	1		
	03:00	2,414	1	1					1			
	04:00	2,291	1	1					1			
	05:00	2,210	1	1					1			
	06:00	2,176	1	1					1			
	07:00	2,168	1	1					1			
	08:00	2,317	1	1					1			1
	09:00	2,518	1	1					1			1
	10:00	2,737	1	1					1			1
	11:00	2,854	1	1					1			1
	12:00	2,907	1	1					1			1
	13:00	2,947	1	1					1			1
	14:00	2,958	1	1					1			1
	15:00	2,952	1	1					1			1
	16:00	2,956	1	1					1			1
	17:00	3,017	1	1					1			1
	18:00	3,133	1	1					1			1
	19:00	3,229	1	1					1			2
	20:00	3,266	1	1					1			2
	21:00	3,253	1	1					1			2
	22:00	3,079	1	1					1			1
	23:00	2,809	1	1					1			1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 26 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Η Ρ Α Τ Η Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τρίτη, 26 Αυγούστου 2025	00:00	2,911	1	1					1	1		
	01:00	2,759	1	1					1	1		
	02:00	2,597	1	1					1	1		
	03:00	2,444	1	1					1			
	04:00	2,318	1	1					1			
	05:00	2,231	1	1					1			
	06:00	2,191	1	1					1			
	07:00	2,182	1	1					1			
	08:00	2,326	1	1					1			1
	09:00	2,552	1	1					1			1
	10:00	2,788	1	1					1			1
	11:00	2,929	1	1					1			1
	12:00	3,009	1	1					1			1
	13:00	3,054	1	1					1			1
	14:00	3,065	1	1					1			1
	15:00	3,068	1	1					1			1
	16:00	3,084	1	1					1			1
	17:00	3,153	1	1					1			1
	18:00	3,282	1	1					1			2
	19:00	3,398	1	1					1			2
	20:00	3,456	1	1					1			2
	21:00	3,438	1	1					1			2
	22:00	3,258	1	1					1			1
	23:00	2,939	1	1					1			1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 27 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τετάρτη, 27 Αυγούστου 2025	00:00	3,035	1	1					1	1		
	01:00	2,909	1	1					1	1		
	02:00	2,765	1	1					1	1		
	03:00	2,618	1	1					1	1		
	04:00	2,516	1	1					1	1		
	05:00	2,381	1	1					1			
	06:00	2,310	1	1					1			
	07:00	2,313	1	1					1			
	08:00	2,432	1	1					1			1
	09:00	2,647	1	1					1			1
	10:00	2,882	1	1					1			1
	11:00	3,021	1	1					1			1
	12:00	3,087	1	1					1			1
	13:00	3,105	1	1					1			1
	14:00	3,095	1	1					1			1
	15:00	3,082	1	1					1			1
	16:00	3,088	1	1					1			1
	17:00	3,145	1	1					1			1
	18:00	3,259	1	1					1			2
	19:00	3,377	1	1					1			2
	20:00	3,453	1	1					1			2
	21:00	3,467	1	1					1			2
	22:00	3,324	1	1					1			2
	23:00	3,013	1	1					1			1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης