

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 28 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Θ	Σ	Ε	Τ	Η							
Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)	
Πέμπτη, 28 Αυγούστου 2025	00:00	2,460	1	1				1				
	01:00	2,303	1	1				1				
	02:00	2,153	1	1				1				
	03:00	2,044	1	1				1				
	04:00	1,957	1	1				1				
	05:00	1,900	1	1				1				
	06:00	1,891	1	1				1				
	07:00	1,932	1	1							1	
	08:00	2,052	1	1							1	
	09:00	2,218	1	1							1	
	10:00	2,360	1	1							1	
	11:00	2,429	1	1							1	
	12:00	2,434	1	1							1	
	13:00	2,480	1	1							2	
	14:00	2,486	1	1							2	
	15:00	2,506	1	1							2	
	16:00	2,513	1	1							2	
	17:00	2,604	1	1							2	
	18:00	2,736	1	1							2	
	19:00	2,823	1	1							2	
	20:00	2,954	1	1							2	
	21:00	2,895	1	1							2	
	22:00	2,602	1	1							2	
	23:00	2,410	1	1							1	

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 29 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Παρασκευή, 29 Αυγούστου 2025	00:00	2,418	1	1					1			
	01:00	2,280	1	1					1			
	02:00	2,120	1	1					1			
	03:00	2,003	1	1					1			
	04:00	1,917	1	1					1			
	05:00	1,858	1	1					1			
	06:00	1,836	1	1					1			
	07:00	1,875	1	1								1
	08:00	2,009	1	1								1
	09:00	2,184	1	1								1
	10:00	2,348	1	1								1
	11:00	2,426	1	1								1
	12:00	2,456	1	1								1
	13:00	2,469	1	1								1
	14:00	2,480	1	1								2
	15:00	2,494	1	1								2
	16:00	2,531	1	1								2
	17:00	2,616	1	1								2
	18:00	2,744	1	1								2
	19:00	2,829	1	1								2
	20:00	2,887	1	1								2
	21:00	2,830	1	1								2
	22:00	2,583	1	1								2
	23:00	2,390	1	1								1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 30 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Σάββατο, 30 Αυγούστου 2025	00:00	2,337	1	1					1			
	01:00	2,209	1	1					1			
	02:00	2,079	1	1					1			
	03:00	1,970	1	1					1			
	04:00	1,886	1	1					1			
	05:00	1,830	1	1					1			
	06:00	1,810	1	1					1			
	07:00	1,849	1	1								1
	08:00	2,012	1	1								1
	09:00	2,210	1	1								1
	10:00	2,397	1	1								1
	11:00	2,506	1	1								2
	12:00	2,549	1	1								2
	13:00	2,575	1	1								2
	14:00	2,582	1	1								2
	15:00	2,589	1	1								2
	16:00	2,612	1	1								2
	17:00	2,675	1	1								2
	18:00	2,767	1	1								2
	19:00	2,820	1	1								2
	20:00	2,815	1	1								2
	21:00	2,772	1	1								2
	22:00	2,548	1	1								2
	23:00	2,357	1	1								1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 31 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Κυριακή, 31 Αυγούστου 2025	00:00	2,291	1	1					1			
	01:00	2,182	1	1					1			
	02:00	2,070	1	1					1			
	03:00	1,965	1	1					1			
	04:00	1,882	1	1					1			
	05:00	1,829	1	1					1			
	06:00	1,812	1	1					1			
	07:00	1,844	1	1								1
	08:00	2,010	1	1								1
	09:00	2,191	1	1								1
	10:00	2,369	1	1								1
	11:00	2,462	1	1								1
	12:00	2,522	1	1								2
	13:00	2,545	1	1								2
	14:00	2,562	1	1								2
	15:00	2,552	1	1								2
	16:00	2,553	1	1								2
	17:00	2,594	1	1								2
	18:00	2,656	1	1								2
	19:00	2,705	1	1								2
	20:00	2,672	1	1								2
	21:00	2,646	1	1								2
	22:00	2,461	1	1								1
	23:00	2,294	1	1								1

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 1 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	0,000
Ρ Θ Σ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Δευτέρα, 1 Σεπτεμβρίου 2025	00:00	2,297	1	1					1			
	01:00	2,151	1	1					1			
	02:00	2,011	1	1					1			
	03:00	1,908	1	1					1			
	04:00	1,829	1	1					1			
	05:00	1,788	1	1					1			
	06:00	1,779	1	1					1			
	07:00	1,807	1	1					1			
	08:00	1,972	1	1					1			
	09:00	2,175	1	1					1			
	10:00	2,384	1	1					1			
	11:00	2,507	1	1					1	1		
	12:00	2,545	1	1					1	1		
	13:00	2,586	1	1					1	1		
	14:00	2,632	1	1					1	1		
	15:00	2,634	1	1					1	1		
	16:00	2,639	1	1					1	1		
	17:00	2,677	1	1					1	1		
	18:00	2,758	1	1					1	1		
	19:00	2,833	1	1					1	1		
	20:00	2,745	1	1					1	1		
	21:00	2,690	1	1					1	1		
	22:00	2,468	1	1					1	1		
	23:00	2,259	1	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 2 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	0,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τρίτη, 2 Σεπτεμβρίου 2025	00:00	2,372	1	1					1			
	01:00	2,213	1	1					1			
	02:00	2,072	1	1					1			
	03:00	1,963	1	1					1			
	04:00	1,884	1	1					1			
	05:00	1,839	1	1					1			
	06:00	1,829	1	1					1			
	07:00	1,851	1	1					1			
	08:00	2,013	1	1					1			
	09:00	2,209	1	1					1			
	10:00	2,412	1	1					1			
	11:00	2,537	1	1					1	1		
	12:00	2,590	1	1					1	1		
	13:00	2,631	1	1					1	1		
	14:00	2,654	1	1					1	1		
	15:00	2,664	1	1					1	1		
	16:00	2,660	1	1					1	1		
	17:00	2,730	1	1					1	1		
	18:00	2,843	1	1					1	1		
	19:00	2,938	1	1					1	1		
	20:00	2,917	1	1					1	1		
	21:00	2,883	1	1					1	1		
	22:00	2,645	1	1					1	1		
	23:00	2,419	1	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 3 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	0,000
Ρ Θ Σ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τετάρτη, 3 Σεπτεμβρίου 2025	00:00	2,404	1	1					1			
	01:00	2,386	1	1					1			
	02:00	2,242	1	1					1			
	03:00	2,123	1	1					1			
	04:00	2,033	1	1					1			
	05:00	1,978	1	1					1			
	06:00	1,956	1	1					1			
	07:00	1,972	1	1					1			
	08:00	2,082	1	1					1			
	09:00	2,263	1	1					1			
	10:00	2,460	1	1					1			
	11:00	2,585	1	1					1	1		
	12:00	2,639	1	1					1	1		
	13:00	2,671	1	1					1	1		
	14:00	2,676	1	1					1	1		
	15:00	2,679	1	1					1	1		
	16:00	2,681	1	1					1	1		
	17:00	2,753	1	1					1	1		
	18:00	2,876	1	1					1	1		
	19:00	2,982	1	1					1	1		
	20:00	3,017	1	1					1	1		
	21:00	3,019	1	1					1	1		
	22:00	2,782	1	1					1	1		
	23:00	2,542	1	1					1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης