

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 30 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 30 Οκτωβρίου 2025	00:00	0,806		1					1		
	01:00	0,755		1							
	02:00	0,725		1							
	03:00	0,711		1							
	04:00	0,714		1							
	05:00	0,735		1							
	06:00	0,782		1							
	07:00	0,804		1					1		
	08:00	0,806		1					1		
	09:00	0,815		1					1		
	10:00	0,825		1					1		
	11:00	0,837		1					1		
	12:00	0,841		1					1		
	13:00	0,843		1					1		
	14:00	0,854		1					1		
	15:00	0,886		1					1		
	16:00	0,939		1					1		
	17:00	1,017		1					1		
	18:00	1,087		1					1		
	19:00	1,153		1					1		
	20:00	1,176		1					1		
	21:00	1,127		1					1		
	22:00	1,040		1					1		
	23:00	0,927		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 31 Οκτωβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 31 Οκτωβρίου 2025	00:00	0,797		1					1		
	01:00	0,744		1							
	02:00	0,710		1							
	03:00	0,693		1							
	04:00	0,693		1							
	05:00	0,714		1							
	06:00	0,757		1							
	07:00	0,792		1							
	08:00	0,812		1					1		
	09:00	0,829		1					1		
	10:00	0,852		1					1		
	11:00	0,885		1					1		
	12:00	0,906		1					1		
	13:00	0,875		1					1		
	14:00	0,874		1					1		
	15:00	0,883		1					1		
	16:00	0,938		1					1		
	17:00	1,024		1					1		
	18:00	1,109		1					1		
	19:00	1,180		1					1		
	20:00	1,201		1					1		
	21:00	1,148		1					1		
	22:00	1,048		1					1		
	23:00	0,917		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 1 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 1 Νοεμβρίου 2025	00:00	0,825		1					1		
	01:00	0,769		1							
	02:00	0,731		1							
	03:00	0,710		1							
	04:00	0,709		1							
	05:00	0,726		1							
	06:00	0,769		1							
	07:00	0,810		1					1		
	08:00	0,823		1					1		
	09:00	0,837		1					1		
	10:00	0,849		1					1		
	11:00	0,869		1					1		
	12:00	0,874		1					1		
	13:00	0,867		1					1		
	14:00	0,873		1					1		
	15:00	0,899		1					1		
	16:00	0,953		1					1		
	17:00	1,038		1					1		
	18:00	1,121		1					1		
	19:00	1,191		1					1		
	20:00	1,215		1					1		
	21:00	1,173		1					1		
	22:00	1,079		1					1		
	23:00	0,947		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 2 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 2 Νοεμβρίου 2025	00:00	0,831		1					1		
	01:00	0,766		1							
	02:00	0,723		1							
	03:00	0,699		1							
	04:00	0,694		1							
	05:00	0,705		1							
	06:00	0,746		1							
	07:00	0,785		1							
	08:00	0,792		1							
	09:00	0,800		1					1		
	10:00	0,817		1					1		
	11:00	0,835		1					1		
	12:00	0,843		1					1		
	13:00	0,830		1					1		
	14:00	0,827		1					1		
	15:00	0,843		1					1		
	16:00	0,886		1					1		
	17:00	0,955		1					1		
	18:00	1,024		1					1		
	19:00	1,067		1					1		
	20:00	1,088		1					1		
	21:00	1,058		1					1		
	22:00	0,982		1					1		
	23:00	0,867		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 3 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 3 Νοεμβρίου 2025	00:00	0,764		1							
	01:00	0,717		1							
	02:00	0,691		1							
	03:00	0,679		1							
	04:00	0,684		1							
	05:00	0,702		1							
	06:00	0,743		1							
	07:00	0,776		1							
	08:00	0,781		1							
	09:00	0,773		1							
	10:00	0,779		1							
	11:00	0,789		1							
	12:00	0,912		1					1		
	13:00	0,938		1					1		
	14:00	0,896		1					1		
	15:00	0,845		1					1		
	16:00	0,890		1					1		
	17:00	0,976		1					1		
	18:00	1,054		1					1		
	19:00	1,087		1					1		
	20:00	1,106		1					1		
	21:00	1,068		1					1		
	22:00	0,991		1					1		
	23:00	0,877		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 4 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 4 Νοεμβρίου 2025	00:00	0,749		1							
	01:00	0,710		1							
	02:00	0,689		1							
	03:00	0,682		1							
	04:00	0,691		1							
	05:00	0,712		1							
	06:00	0,751		1							
	07:00	0,788		1							
	08:00	0,791		1							
	09:00	0,785		1							
	10:00	0,787		1							
	11:00	0,790		1							
	12:00	0,794		1							
	13:00	0,796		1					1		
	14:00	0,805		1					1		
	15:00	0,833		1					1		
	16:00	0,890		1					1		
	17:00	0,978		1					1		
	18:00	1,056		1					1		
	19:00	1,096		1					1		
	20:00	1,116		1					1		
	21:00	1,075		1					1		
	22:00	0,991		1					1		
	23:00	0,869		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 5 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 5 Νοεμβρίου 2025	00:00	0,748		1							
	01:00	0,709		1							
	02:00	0,687		1							
	03:00	0,679		1							
	04:00	0,687		1							
	05:00	0,709		1							
	06:00	0,747		1							
	07:00	0,788		1							
	08:00	0,794		1							
	09:00	0,791		1							
	10:00	0,790		1							
	11:00	0,789		1							
	12:00	0,786		1							
	13:00	0,785		1							
	14:00	0,792		1							
	15:00	0,821		1					1		
	16:00	0,878		1					1		
	17:00	0,969		1					1		
	18:00	1,047		1					1		
	19:00	1,097		1					1		
	20:00	1,120		1					1		
	21:00	1,078		1					1		
	22:00	0,985		1					1		
	23:00	0,854		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης