

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα						Τρίτη, 14 Οκτωβρίου 2025														
Αποδιδόμενη Ισχύς (MW)						7,500	10,000	10,000	10,000	13,500	13,500	10,885	9,142	9,142	28,000	1,400	1,800	1,800	5,500	5,500	5,500	8,250
Η Ε Π Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	Πρόβλεψη Θερμικής Παραγωγής (MW)	Πρόβλεψη Αιολικής Παραγωγής (MW)	Πρόγραμμα Παραγωγής ΥΒΣ Τήλου (MW)	ΑΣΠ Κω										ΑΣΠ Καλύμνου						
						61	62	63	64	65	66	A/Σ 67	A/Σ 632	A/Σ 633	A/Σ 634	MTU 9-11	61	62	63	64	65	66
Τρίτη, 14 Οκτωβρίου 2025	00:00	42,30	42,28	0,02	0,00		1	1	1	1	1							1				
	01:00	39,07	39,05	0,02	0,00		1	1		1	1							1				
	02:00	37,91	37,86	0,05	0,00		1	1		1	1							1				
	03:00	37,20	37,12	0,08	0,00		1	1		1	1							1				
	04:00	37,18	37,09	0,08	0,00		1	1		1	1							1				
	05:00	39,69	39,60	0,10	0,00		1	1		1	1							1				
	06:00	44,19	44,06	0,13	0,00		1	1	1	1	1							1				
	07:00	50,62	50,29	0,13	0,20		1	1	1	1	1							1				
	08:00	53,33	53,04	0,09	0,20		1	1	1	1	1							1			1	
	09:00	56,29	55,99	0,10	0,20		1	1	1	1	1							1			1	
	10:00	58,31	58,00	0,12	0,20		1	1	1	1	1							1			1	
	11:00	55,39	54,85	0,33	0,20		1	1	1	1	1							1			1	
	12:00	55,04	54,31	0,53	0,20		1	1	1	1	1							1			1	
	13:00	55,43	54,50	0,73	0,20		1	1	1	1	1							1			1	
	14:00	55,06	53,64	1,22	0,20		1	1	1	1	1							1			1	
	15:00	51,99	50,30	1,49	0,20		1	1	1	1	1							1			1	
	16:00	52,98	51,31	1,47	0,20		1	1	1	1	1							1			1	
	17:00	56,92	55,45	1,48	0,00		1	1	1	1	1							1		1	1	
	18:00	63,15	61,53	1,62	0,00		1	1	1	1	1							1		1	1	
	19:00	68,03	66,44	1,59	0,00		1	1	1	1	1							1		1	1	
	20:00	66,06	64,48	1,58	0,00		1	1	1	1	1							1		1	1	
	21:00	60,52	58,85	1,67	0,00		1	1	1	1	1							1		1	1	
	22:00	53,26	51,62	1,64	0,00		1	1	1	1	1							1			1	
	23:00	47,47	45,77	1,70	0,00		1	1	1	1	1							1			1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης