

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 7 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 7 Αυγούστου 2025	00:00	2,891			1	1		1	
	01:00	2,632			1	1		1	
	02:00	2,444			1	1		1	
	03:00	2,335			1	1		1	
	04:00	2,223			1	1		1	
	05:00	2,184			1	1		1	
	06:00	2,154			1	1		1	
	07:00	2,417			1	1		1	
	08:00	2,740			1	1		1	
	09:00	2,923			1	1		1	
	10:00	2,987	1		1	1		1	
	11:00	2,937	1		1	1		1	
	12:00	3,070	1		1	1		1	
	13:00	3,220	1		1	1		1	
	14:00	3,167	1		1	1		1	
	15:00	3,004	1		1	1		1	
	16:00	2,952	1		1	1		1	
	17:00	3,149	1		1	1		1	
	18:00	3,358	1		1	1		1	
	19:00	3,572	1		1	1		1	
	20:00	3,760			1	1	1	1	
	21:00	3,833			1	1	1	1	
	22:00	3,463			1	1	1	1	
	23:00	3,256			1	1	1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 8 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 8 Αυγούστου 2025	00:00	3,018			1	1		1	
	01:00	2,715			1	1		1	
	02:00	2,489			1	1		1	
	03:00	2,326			1	1		1	
	04:00	2,229			1	1		1	
	05:00	2,174			1	1		1	
	06:00	2,265			1	1		1	
	07:00	2,478			1	1		1	
	08:00	2,732			1	1		1	
	09:00	2,890			1	1		1	
	10:00	2,985			1	1		1	
	11:00	3,037			1	1		1	
	12:00	3,148			1	1		1	
	13:00	3,250			1	1		1	1
	14:00	3,253			1	1		1	1
	15:00	3,165			1	1		1	1
	16:00	3,114			1	1		1	1
	17:00	3,224			1	1		1	1
	18:00	3,380			1	1		1	1
	19:00	3,562			1	1		1	1
	20:00	3,699		1	1	1		1	
	21:00	3,716		1	1	1		1	
	22:00	3,353		1	1	1		1	
	23:00	3,123		1	1	1		1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 9 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Π Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 9 Αυγούστου 2025	00:00	2,967		1	1	1		1	
	01:00	2,655		1	1	1			
	02:00	2,447		1	1	1			
	03:00	2,318		1	1	1			
	04:00	2,242		1	1	1			
	05:00	2,178		1	1	1			
	06:00	2,189		1	1	1			
	07:00	2,399		1	1	1			
	08:00	2,611		1	1	1			
	09:00	2,834		1	1	1			
	10:00	2,911		1	1	1			
	11:00	2,904		1	1	1			
	12:00	2,975		1	1	1			
	13:00	3,061		1	1	1			
	14:00	2,932		1	1	1			
	15:00	2,860		1	1	1			
	16:00	2,858		1	1	1			
	17:00	2,999		1	1	1			
	18:00	3,230	1	1	1	1			
	19:00	3,396	1	1	1	1			
	20:00	3,739	1	1	1	1			
	21:00	3,609	1	1	1	1			
	22:00	3,241	1	1	1	1			
	23:00	3,062	1	1	1	1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 10 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 10 Αυγούστου 2025	00:00	2,865	1	1	1			1	
	01:00	2,677		1	1			1	
	02:00	2,418		1	1			1	
	03:00	2,321		1	1			1	
	04:00	2,250		1	1			1	
	05:00	2,186		1	1			1	
	06:00	2,226		1	1			1	
	07:00	2,427		1	1			1	
	08:00	2,673		1	1			1	
	09:00	2,846		1	1			1	
	10:00	2,953		1	1			1	
	11:00	2,967		1	1			1	1
	12:00	3,007		1	1			1	1
	13:00	3,102		1	1			1	1
	14:00	3,089		1	1			1	1
	15:00	3,022		1	1			1	1
	16:00	2,989		1	1			1	1
	17:00	3,149		1	1			1	1
	18:00	3,293		1	1			1	1
	19:00	3,528		1	1			1	1
	20:00	3,730		1	1			1	1
	21:00	3,706		1	1		1	1	
	22:00	3,388		1	1		1	1	
	23:00	3,188		1	1		1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 11 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 11 Αυγούστου 2025	00:00	2,986		1	1		1	1	
	01:00	2,715		1	1		1	1	
	02:00	2,478		1			1	1	
	03:00	2,321		1			1	1	
	04:00	2,267		1			1	1	
	05:00	2,227		1			1	1	
	06:00	2,269		1			1	1	
	07:00	2,570		1			1	1	
	08:00	2,842		1			1	1	
	09:00	3,029		1			1	1	
	10:00	3,063	1	1			1	1	
	11:00	3,108	1	1			1	1	
	12:00	3,130	1	1			1	1	
	13:00	3,287	1	1			1	1	
	14:00	3,299	1	1			1	1	
	15:00	3,167	1	1			1	1	
	16:00	3,140	1	1			1	1	
	17:00	3,217	1	1			1	1	
	18:00	3,428	1	1			1	1	
	19:00	3,606	1	1			1	1	
	20:00	3,928		1		1	1	1	
	21:00	4,011		1		1	1	1	
	22:00	3,587		1		1	1	1	
	23:00	3,367		1		1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 12 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 12 Αυγούστου 2025	00:00	3,047		1		1	1	1	
	01:00	2,769				1	1	1	
	02:00	2,567				1	1	1	
	03:00	2,428				1	1	1	
	04:00	2,341				1	1	1	
	05:00	2,292				1	1	1	
	06:00	2,374				1	1	1	
	07:00	2,687			1	1	1	1	
	08:00	2,924			1	1		1	
	09:00	2,957			1	1		1	1
	10:00	3,089			1	1		1	1
	11:00	3,088			1	1		1	1
	12:00	3,214			1	1		1	1
	13:00	3,326			1	1		1	1
	14:00	3,295			1	1		1	1
	15:00	3,178			1	1		1	1
	16:00	3,168			1	1		1	1
	17:00	3,211			1	1		1	1
	18:00	3,439			1	1		1	1
	19:00	3,673			1	1		1	1
	20:00	3,854		1	1	1		1	1
	21:00	3,882		1	1	1		1	
	22:00	3,539		1	1	1		1	
	23:00	3,231		1	1	1		1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 13 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 13 Αυγούστου 2025	00:00	2,936		1	1	1		1	
	01:00	2,679		1	1	1		1	
	02:00	2,415		1	1	1			
	03:00	2,285		1	1	1			
	04:00	2,231		1	1	1			
	05:00	2,231		1	1	1			
	06:00	2,262		1	1	1			
	07:00	2,490		1	1	1			
	08:00	2,757		1	1	1			
	09:00	2,987		1	1	1			
	10:00	3,072		1	1	1	1		
	11:00	3,085		1	1	1	1		
	12:00	3,100		1	1	1	1		
	13:00	3,167		1	1	1	1		
	14:00	3,154		1	1	1	1		
	15:00	2,985		1	1	1	1		
	16:00	2,953		1	1	1	1		
	17:00	3,081		1	1	1	1		
	18:00	3,364		1	1	1	1		
	19:00	3,627		1	1	1	1		
	20:00	3,929		1	1	1	1		
	21:00	3,927	1	1	1	1	1		
	22:00	3,494	1	1	1	1	1		
	23:00	3,157		1	1	1	1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης