

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 16 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 16 Οκτωβρίου 2025	00:00	1,228		1		1			
	01:00	1,191		1		1			
	02:00	1,127		1		1			
	03:00	1,084		1		1			
	04:00	1,098		1		1			
	05:00	1,157		1		1			
	06:00	1,226		1		1			
	07:00	1,376		1		1			
	08:00	1,409		1		1			
	09:00	1,376				1			1
	10:00	1,452				1			1
	11:00	1,359				1			1
	12:00	1,445				1			1
	13:00	1,465				1			1
	14:00	1,404				1			1
	15:00	1,266				1			1
	16:00	1,227				1			1
	17:00	1,321				1			1
	18:00	1,517				1			1
	19:00	1,715			1	1			
	20:00	1,735			1	1			
	21:00	1,648			1	1			
	22:00	1,471			1	1			
	23:00	1,310			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 17 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 17 Οκτωβρίου 2025	00:00	1,216			1	1			
	01:00	1,159			1	1			
	02:00	1,124			1	1			
	03:00	1,105			1	1			
	04:00	1,104			1	1			
	05:00	1,140			1	1			
	06:00	1,222			1	1			
	07:00	1,405			1	1			
	08:00	1,508	1		1				
	09:00	1,590	1		1				
	10:00	1,558	1		1				
	11:00	1,603	1		1				
	12:00	1,468	1		1				
	13:00	1,301	1		1				
	14:00	1,357	1		1				
	15:00	1,255	1		1				
	16:00	1,282	1		1				
	17:00	1,337	1		1				
	18:00	1,519	1		1				
	19:00	1,675	1		1				
	20:00	1,651			1			1	
	21:00	1,578			1			1	
	22:00	1,467			1			1	
	23:00	1,342			1			1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 18 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 18 Οκτωβρίου 2025	00:00	1,219			1			1	
	01:00	1,147			1			1	
	02:00	1,101			1			1	
	03:00	1,075			1			1	
	04:00	1,093			1			1	
	05:00	1,121			1			1	
	06:00	1,166			1			1	
	07:00	1,257			1			1	
	08:00	1,365			1			1	
	09:00	1,378						1	1
	10:00	1,364						1	1
	11:00	1,378						1	1
	12:00	1,452						1	1
	13:00	1,412						1	1
	14:00	1,339						1	1
	15:00	1,170						1	1
	16:00	1,186						1	1
	17:00	1,283						1	1
	18:00	1,419						1	1
	19:00	1,638		1				1	
	20:00	1,683		1				1	
	21:00	1,557		1				1	
	22:00	1,396		1				1	
	23:00	1,257		1				1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 19 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 19 Οκτωβρίου 2025	00:00	1,209		1				1	
	01:00	1,160		1				1	
	02:00	1,109		1				1	
	03:00	1,085		1				1	
	04:00	1,113		1				1	
	05:00	1,135		1				1	
	06:00	1,159		1				1	
	07:00	1,202		1				1	
	08:00	1,257		1				1	
	09:00	1,367		1				1	
	10:00	1,543		1				1	
	11:00	1,611		1				1	
	12:00	1,613		1				1	
	13:00	1,615		1				1	
	14:00	1,595		1				1	
	15:00	1,466		1				1	
	16:00	1,378		1				1	
	17:00	1,413		1				1	
	18:00	1,526		1				1	
	19:00	1,661		1				1	
	20:00	1,655		1				1	
	21:00	1,600		1			1		
	22:00	1,427		1			1		
	23:00	1,326		1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 20 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 20 Οκτωβρίου 2025	00:00	1,203		1			1		
	01:00	1,133		1			1		
	02:00	1,091		1			1		
	03:00	1,069		1			1		
	04:00	1,048		1			1		
	05:00	1,097		1			1		
	06:00	1,161		1			1		
	07:00	1,326		1			1		
	08:00	1,416	1				1		
	09:00	1,490	1				1		
	10:00	1,470	1				1		
	11:00	1,569	1				1		
	12:00	1,506	1				1		
	13:00	1,405	1				1		
	14:00	1,358	1				1		
	15:00	1,249	1				1		
	16:00	1,187	1				1		
	17:00	1,301	1				1		
	18:00	1,487	1				1		
	19:00	1,748			1		1		
	20:00	1,778			1		1		
	21:00	1,664			1		1		
	22:00	1,455			1		1		
	23:00	1,318			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 21 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 21 Οκτωβρίου 2025	00:00	1,182			1		1		
	01:00	1,134			1		1		
	02:00	1,121			1		1		
	03:00	1,072			1		1		
	04:00	1,072			1		1		
	05:00	1,123			1		1		
	06:00	1,183			1		1		
	07:00	1,388			1		1		
	08:00	1,486			1				1
	09:00	1,536			1				1
	10:00	1,542			1				1
	11:00	1,537			1				1
	12:00	1,540			1				1
	13:00	1,580			1				1
	14:00	1,619			1				1
	15:00	1,377			1				1
	16:00	1,377			1				1
	17:00	1,389			1				1
	18:00	1,501			1				1
	19:00	1,789			1	1			
	20:00	1,816			1	1			
	21:00	1,699			1	1			
	22:00	1,514			1	1			
	23:00	1,333			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 22 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 22 Οκτωβρίου 2025	00:00	1,236			1	1			
	01:00	1,175			1	1			
	02:00	1,125			1	1			
	03:00	1,074			1	1			
	04:00	1,066			1	1			
	05:00	1,134			1	1			
	06:00	1,202			1	1			
	07:00	1,341			1	1			
	08:00	1,428	1			1			
	09:00	1,420	1			1			
	10:00	1,362	1			1			
	11:00	1,407	1			1			
	12:00	1,397	1			1			
	13:00	1,422	1			1			
	14:00	1,365	1			1			
	15:00	1,277	1			1			
	16:00	1,262	1			1			
	17:00	1,354	1			1			
	18:00	1,547	1			1			
	19:00	1,746	1			1			
	20:00	1,777		1		1			
	21:00	1,652		1		1			
	22:00	1,443		1		1			
	23:00	1,305		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης