

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 18 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 18 Σεπτεμβρίου 2025	00:00	1,599		1				1	
	01:00	1,488		1				1	
	02:00	1,448		1				1	
	03:00	1,423		1				1	
	04:00	1,419		1				1	
	05:00	1,411		1				1	
	06:00	1,488		1				1	
	07:00	1,578		1				1	
	08:00	1,668		1				1	
	09:00	1,807		1				1	
	10:00	1,887		1				1	
	11:00	1,751		1				1	
	12:00	1,684		1				1	
	13:00	1,695		1				1	
	14:00	1,583		1				1	
	15:00	1,486		1				1	
	16:00	1,497		1				1	
	17:00	1,600		1				1	
	18:00	1,763		1				1	
	19:00	2,054		1		1		1	
	20:00	2,134		1		1		1	
	21:00	1,989		1		1		1	
	22:00	1,818		1		1		1	
	23:00	1,588		1		1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 19 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 19 Σεπτεμβρίου 2025	00:00	1,440		1		1			
	01:00	1,353		1		1			
	02:00	1,298		1		1			
	03:00	1,289		1		1			
	04:00	1,302		1		1			
	05:00	1,319		1		1			
	06:00	1,432		1		1			
	07:00	1,598	1	1					
	08:00	1,685	1	1					
	09:00	1,773	1	1					
	10:00	1,757	1	1					
	11:00	1,645	1	1					
	12:00	1,694	1	1					
	13:00	1,706	1	1					
	14:00	1,682	1	1					
	15:00	1,532	1	1					
	16:00	1,473	1	1					
	17:00	1,646	1	1					
	18:00	1,812	1	1					
	19:00	1,978	1	1	1				
	20:00	2,073	1	1	1				
	21:00	1,982	1	1	1				
	22:00	1,807	1	1	1				
	23:00	1,620		1	1				



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 20 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 20 Σεπτεμβρίου 2025	00:00	1,482		1	1				
	01:00	1,400		1	1				
	02:00	1,343		1	1				
	03:00	1,310		1	1				
	04:00	1,290		1	1				
	05:00	1,305		1	1				
	06:00	1,388		1	1				
	07:00	1,535		1	1				
	08:00	1,678			1				1
	09:00	1,734			1				1
	10:00	1,642			1				1
	11:00	1,633			1				1
	12:00	1,714			1				1
	13:00	1,738			1				1
	14:00	1,655			1				1
	15:00	1,540			1				1
	16:00	1,522			1				1
	17:00	1,656			1				1
	18:00	1,814			1				1
	19:00	1,974			1	1			1
	20:00	2,048			1	1			1
	21:00	1,888			1	1			1
	22:00	1,689			1	1			1
	23:00	1,590			1	1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 21 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 21 Σεπτεμβρίου 2025	00:00	1,465			1	1			
	01:00	1,367			1	1			
	02:00	1,326			1	1			
	03:00	1,317			1	1			
	04:00	1,303			1	1			
	05:00	1,335			1	1			
	06:00	1,443			1	1			
	07:00	1,503			1	1			
	08:00	1,688	1			1			
	09:00	1,787	1			1			
	10:00	1,779	1			1			
	11:00	1,774	1			1			
	12:00	1,744	1			1			
	13:00	1,741	1			1			
	14:00	1,619	1			1			
	15:00	1,525	1			1			
	16:00	1,476	1			1			
	17:00	1,639	1			1			
	18:00	1,729	1			1			
	19:00	1,877	1			1	1		
	20:00	2,026	1			1	1		
	21:00	1,913				1	1	1	
	22:00	1,707					1	1	
	23:00	1,569					1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 22 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 22 Σεπτεμβρίου 2025	00:00	1,436					1	1	
	01:00	1,341					1	1	
	02:00	1,284					1	1	
	03:00	1,280					1	1	
	04:00	1,301					1	1	
	05:00	1,321					1	1	
	06:00	1,432					1	1	
	07:00	1,637					1	1	
	08:00	1,829					1	1	
	09:00	1,937					1	1	
	10:00	1,920					1	1	
	11:00	1,804					1	1	
	12:00	1,865					1	1	
	13:00	1,840					1	1	
	14:00	1,753					1	1	
	15:00	1,542					1	1	
	16:00	1,574					1	1	
	17:00	1,606					1	1	
	18:00	1,796					1	1	
	19:00	1,986					1	1	
	20:00	2,075					1	1	
	21:00	1,971					1	1	
	22:00	1,701					1	1	
	23:00	1,571					1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 23 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 23 Σεπτεμβρίου 2025	00:00	1,435					1	1	
	01:00	1,344					1	1	
	02:00	1,295					1	1	
	03:00	1,303					1	1	
	04:00	1,290					1	1	
	05:00	1,330					1	1	
	06:00	1,422					1	1	
	07:00	1,599					1	1	
	08:00	1,773					1	1	
	09:00	1,797					1	1	
	10:00	1,606					1	1	
	11:00	1,574				1	1	1	
	12:00	1,760		1		1			
	13:00	1,723		1		1			
	14:00	1,617		1		1			
	15:00	1,474		1		1			
	16:00	1,437		1		1			
	17:00	1,559		1		1			
	18:00	1,784		1		1			
	19:00	1,994		1		1			
	20:00	2,119		1		1			
	21:00	1,921		1		1			
	22:00	1,713		1		1			
	23:00	1,538		1		1			

Μερική διακοπή στις 10:50 λόγω πυρκαγιάς στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 24 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 24 Σεπτεμβρίου 2025	00:00	1,375		1		1			
	01:00	1,295		1		1			
	02:00	1,264		1		1			
	03:00	1,235		1		1			
	04:00	1,247		1		1			
	05:00	1,286		1		1			
	06:00	1,393		1		1			
	07:00	1,531		1		1			
	08:00	1,531		1		1			
	09:00	1,657	1						1
	10:00	1,585	1						1
	11:00	1,658	1						1
	12:00	1,610			1		1		
	13:00	1,566			1		1		
	14:00	1,477			1		1		
	15:00	1,455			1		1		
	16:00	1,411			1		1		
	17:00	1,529			1		1		
	18:00	1,768			1		1		
	19:00	1,961			1		1		
	20:00	2,092			1		1		
	21:00	1,923			1			1	
	22:00	1,642			1			1	
	23:00	1,479			1			1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης