

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 21 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ω Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 21 Αυγούστου 2025	00:00	2,530			1	1	1		
	01:00	2,329			1	1	1		
	02:00	2,124			1	1	1		
	03:00	1,999			1	1	1		
	04:00	1,956			1	1	1		
	05:00	1,936			1	1	1		
	06:00	1,968			1	1	1		
	07:00	2,230			1	1	1		
	08:00	2,388			1	1	1		
	09:00	2,559			1	1	1		
	10:00	2,725			1	1	1		
	11:00	2,795			1	1	1		
	12:00	2,806			1	1	1		
	13:00	3,016			1	1	1		
	14:00	2,919			1	1	1		
	15:00	2,805			1	1	1		
	16:00	2,771			1	1	1		
	17:00	2,894			1	1	1		
	18:00	3,182			1	1	1		
	19:00	3,518		1	1	1	1		
	20:00	3,735		1	1	1	1		
	21:00	3,688		1	1	1	1		
	22:00	3,252		1	1	1	1		
	23:00	2,958		1	1	1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 22 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 22 Αυγούστου 2025	00:00	2,691		1	1		1		
	01:00	2,457		1	1		1		
	02:00	2,273		1	1		1		
	03:00	2,178		1	1		1		
	04:00	2,122		1	1		1		
	05:00	2,111		1	1		1		
	06:00	2,171		1	1		1		
	07:00	2,390		1	1		1		
	08:00	2,607		1	1		1		
	09:00	2,908		1	1		1		
	10:00	3,066		1	1		1		
	11:00	3,192		1	1		1		
	12:00	3,239	1	1	1		1		
	13:00	3,400	1	1	1		1		
	14:00	3,324	1	1	1		1		
	15:00	3,281	1	1	1		1		
	16:00	3,219	1	1	1		1		
	17:00	3,410	1	1	1		1		
	18:00	3,643	1	1	1		1		
	19:00	3,823		1	1		1	1	
	20:00	4,070		1	1		1	1	
	21:00	3,893		1	1		1	1	
	22:00	3,536		1	1		1	1	
	23:00	3,320		1	1		1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 23 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 23 Αυγούστου 2025	00:00	3,228		1	1		1	1	
	01:00	3,009		1	1		1	1	
	02:00	2,798		1	1		1	1	
	03:00	2,656		1			1	1	
	04:00	2,501		1			1	1	
	05:00	2,478		1			1	1	
	06:00	2,473		1			1	1	
	07:00	2,588		1			1	1	
	08:00	2,816		1			1	1	
	09:00	3,032		1			1	1	
	10:00	3,086		1			1	1	
	11:00	3,091		1			1	1	
	12:00	3,132		1			1	1	1
	13:00	3,165		1			1	1	1
	14:00	3,147		1			1	1	1
	15:00	3,005		1			1	1	1
	16:00	3,007		1			1	1	1
	17:00	3,120		1			1	1	1
	18:00	3,331		1			1	1	1
	19:00	3,504		1			1	1	1
	20:00	3,723		1		1	1	1	
	21:00	3,596		1		1	1	1	
	22:00	3,291		1		1	1	1	
	23:00	3,139		1		1	1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 24 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 24 Αυγούστου 2025	00:00	2,921		1		1	1	1	
	01:00	2,737		1		1		1	
	02:00	2,521		1		1		1	
	03:00	2,428		1		1		1	
	04:00	2,367		1		1		1	
	05:00	2,341		1		1		1	
	06:00	2,398		1		1		1	
	07:00	2,223		1		1		1	
	08:00	2,337			1	1		1	1
	09:00	2,821			1	1		1	1
	10:00	2,912			1	1		1	1
	11:00	2,942			1	1		1	1
	12:00	3,052			1	1		1	1
	13:00	3,040			1	1		1	1
	14:00	3,021			1	1		1	1
	15:00	2,835			1	1		1	1
	16:00	2,781			1	1		1	
	17:00	2,862			1	1		1	
	18:00	2,984			1	1		1	
	19:00	3,169			1	1	1	1	
	20:00	3,389			1	1	1	1	
	21:00	3,308			1	1	1	1	
	22:00	2,931			1	1	1	1	
	23:00	2,734			1		1	1	

Στο διάστημα 07:55 – 08:05 σημειώθηκε γενική διακοπή στο ΗΣ λόγω βλάβης της μονάδας G2.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 25 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 25 Αυγούστου 2025	00:00	2,490			1		1	1	
	01:00	2,316			1		1	1	
	02:00	2,111			1		1	1	
	03:00	2,074			1		1	1	
	04:00	2,039			1		1	1	
	05:00	2,024			1		1	1	
	06:00	2,040			1		1	1	
	07:00	2,245			1		1	1	
	08:00	2,468			1		1	1	
	09:00	2,666			1		1	1	
	10:00	2,639			1		1	1	
	11:00	2,648			1		1	1	
	12:00	2,714			1		1	1	
	13:00	2,780			1		1	1	
	14:00	2,718			1		1	1	
	15:00	2,641			1		1	1	
	16:00	2,586			1		1	1	
	17:00	2,669			1		1	1	
	18:00	2,820			1		1	1	
	19:00	3,055			1	1	1	1	
	20:00	3,330			1	1	1	1	
	21:00	3,257			1	1	1	1	
	22:00	2,859			1	1	1	1	
	23:00	2,656			1	1	1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 26 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 26 Αυγούστου 2025	00:00	2,412			1	1	1		
	01:00	2,233			1	1	1		
	02:00	2,074			1	1	1		
	03:00	1,962			1	1	1		
	04:00	1,883			1	1	1		
	05:00	1,883				1	1		
	06:00	1,969				1	1		
	07:00	2,178	1			1	1		
	08:00	2,412	1			1	1		
	09:00	2,520				1	1		1
	10:00	2,594				1	1		1
	11:00	2,594				1	1		1
	12:00	2,650				1	1		1
	13:00	2,741				1	1		1
	14:00	2,674				1	1		1
	15:00	2,507				1	1		1
	16:00	2,392				1	1		1
	17:00	2,550				1	1		1
	18:00	2,825				1	1		1
	19:00	3,012				1	1	1	1
	20:00	3,218				1	1	1	1
	21:00	3,084				1	1	1	1
	22:00	2,828				1	1	1	1
	23:00	2,526				1	1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 27 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 27 Αυγούστου 2025	00:00	2,338				1	1	1	
	01:00	2,152				1	1	1	
	02:00	1,986				1	1	1	
	03:00	1,922				1	1	1	
	04:00	1,862				1		1	
	05:00	1,912				1		1	
	06:00	1,958				1		1	
	07:00	2,161	1			1		1	
	08:00	2,249	1			1		1	
	09:00	2,469	1			1		1	
	10:00	2,528	1			1		1	
	11:00	2,504	1			1		1	
	12:00	2,541	1			1		1	
	13:00	2,616	1			1		1	
	14:00	2,490	1			1		1	
	15:00	2,339	1			1		1	
	16:00	2,308	1			1		1	
	17:00	2,428	1			1		1	
	18:00	2,644	1			1		1	
	19:00	2,862	1			1		1	
	20:00	3,178	1		1	1		1	
	21:00	3,087	1		1	1		1	
	22:00	2,767	1		1	1		1	
	23:00	2,516			1	1		1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης