

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 23 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 23 Οκτωβρίου 2025	00:00	1,205		1		1			
	01:00	1,125		1		1			
	02:00	1,081		1		1			
	03:00	1,060		1		1			
	04:00	1,069		1		1			
	05:00	1,112		1		1			
	06:00	1,206		1		1			
	07:00	1,305		1		1			
	08:00	1,372		1					1
	09:00	1,398		1					1
	10:00	1,337		1					1
	11:00	1,328		1					1
	12:00	1,372		1					1
	13:00	1,340		1					1
	14:00	1,256		1					1
	15:00	1,123		1					1
	16:00	1,153		1					1
	17:00	1,132		1					1
	18:00	1,298		1					1
	19:00	1,532		1			1		
	20:00	1,572		1			1		
	21:00	1,558		1			1		
	22:00	1,435		1			1		
	23:00	1,307		1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 24 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ ρ ε μ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 24 Οκτωβρίου 2025	00:00	1,170		1			1		
	01:00	1,120		1			1		
	02:00	1,054		1			1		
	03:00	1,053		1			1		
	04:00	1,040		1			1		
	05:00	1,093		1			1		
	06:00	1,145		1			1		
	07:00	1,314		1			1		
	08:00	1,377	1				1		
	09:00	1,374	1				1		
	10:00	1,360	1				1		
	11:00	1,363	1				1		
	12:00	1,331	1				1		
	13:00	1,354	1				1		
	14:00	1,285	1				1		
	15:00	1,145	1				1		
	16:00	1,177	1				1		
	17:00	1,273	1				1		
	18:00	1,454	1				1		
	19:00	1,619	1				1		
	20:00	1,641			1		1		
	21:00	1,590			1		1		
	22:00	1,477			1		1		
	23:00	1,345			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 25 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 25 Οκτωβρίου 2025	00:00	1,204			1		1		
	01:00	1,142			1		1		
	02:00	1,114			1		1		
	03:00	1,063			1		1		
	04:00	1,090			1		1		
	05:00	1,106			1		1		
	06:00	1,171			1		1		
	07:00	1,291			1		1		
	08:00	1,274			1				1
	09:00	1,245			1				1
	10:00	1,250			1				1
	11:00	1,243			1				1
	12:00	1,268			1				1
	13:00	1,311			1				1
	14:00	1,178			1				1
	15:00	1,140			1				1
	16:00	1,109			1				1
	17:00	1,160			1				1
	18:00	1,376			1				1
	19:00	1,588			1				1
	20:00	1,611			1	1			
	21:00	1,536			1	1			
	22:00	1,376			1	1			
	23:00	1,281			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 26 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 26 Οκτωβρίου 2025	00:00	1,194			1	1			
	01:00	1,137			1	1			
	02:00	1,104			1	1			
	03:00	1,078			1	1			
	04:00	1,071			1	1			
	05:00	1,080			1	1			
	06:00	1,131			1	1			
	07:00	1,237			1	1			
	08:00	1,293	1			1			
	09:00	1,305	1			1			
	10:00	1,260	1			1			
	11:00	1,382	1			1			
	12:00	1,284	1			1			
	13:00	1,355	1			1			
	14:00	1,288	1			1			
	15:00	1,203	1			1			
	16:00	1,268	1			1			
	17:00	1,395	1			1			
	18:00	1,583	1			1			
	19:00	1,582	1			1			
	20:00	1,520				1	1		
	21:00	1,444				1	1		
	22:00	1,348				1	1		
	23:00	1,252				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 27 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ ρ ε τ ι κ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 27 Οκτωβρίου 2025	00:00	1,167				1	1		
	01:00	1,162				1	1		
	02:00	1,093				1	1		
	03:00	1,075				1	1		
	04:00	1,095				1	1		
	05:00	1,103				1	1		
	06:00	1,135				1	1		
	07:00	1,252				1	1		
	08:00	1,264					1		1
	09:00	1,410					1		1
	10:00	1,409					1		1
	11:00	1,437					1		1
	12:00	1,573					1		1
	13:00	1,645					1		1
	14:00	1,546					1		1
	15:00	1,373					1		1
	16:00	1,308					1		1
	17:00	1,395					1		1
	18:00	1,608					1		1
	19:00	1,709		1			1		
	20:00	1,662		1			1		
	21:00	1,585		1			1		
	22:00	1,419		1			1		
	23:00	1,269		1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 28 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 28 Οκτωβρίου 2025	00:00	1,188		1			1		
	01:00	1,144		1			1		
	02:00	1,085		1			1		
	03:00	1,075		1			1		
	04:00	1,067		1			1		
	05:00	1,107		1			1		
	06:00	1,196		1			1		
	07:00	1,281		1			1		
	08:00	1,377		1			1		
	09:00	1,255	1				1		
	10:00	1,125	1				1		
	11:00	1,071	1				1		
	12:00	1,295	1				1		
	13:00	1,286	1				1		
	14:00	1,124	1				1		
	15:00	1,117	1				1		
	16:00	1,164	1				1		
	17:00	1,317	1				1		
	18:00	1,466	1				1		
	19:00	1,498			1		1		
	20:00	1,451			1		1		
	21:00	1,386			1		1		
	22:00	1,300			1		1		
	23:00	1,205			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 29 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 29 Οκτωβρίου 2025	00:00	1,107			1		1		
	01:00	1,087			1		1		
	02:00	1,045			1		1		
	03:00	1,067			1		1		
	04:00	1,078			1		1		
	05:00	1,082			1		1		
	06:00	1,100			1		1		
	07:00	1,239			1		1		
	08:00	1,262			1		1		
	09:00	1,197					1		1
	10:00	1,166					1		1
	11:00	1,131					1		1
	12:00	1,158					1		1
	13:00	1,215					1		1
	14:00	1,176					1		1
	15:00	1,075					1		1
	16:00	1,192					1		1
	17:00	1,379					1		1
	18:00	1,578		1		1			
	19:00	1,644		1		1			
	20:00	1,641		1		1			
	21:00	1,562		1		1			
	22:00	1,406		1		1			
	23:00	1,270		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης