

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 28 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 28 Αυγούστου 2025	00:00	2,273			1	1		1	
	01:00	2,074			1	1		1	
	02:00	1,921			1	1		1	
	03:00	1,879			1	1		1	
	04:00	1,765			1			1	
	05:00	1,763			1			1	
	06:00	1,841			1			1	
	07:00	2,030			1			1	
	08:00	2,279			1			1	1
	09:00	2,517			1			1	1
	10:00	2,490			1			1	1
	11:00	2,435			1			1	1
	12:00	2,409			1			1	1
	13:00	2,538			1			1	1
	14:00	2,540			1			1	1
	15:00	2,341			1			1	1
	16:00	2,235			1			1	1
	17:00	2,458			1			1	1
	18:00	2,622			1			1	1
	19:00	2,852			1			1	1
	20:00	3,051			1	1	1	1	
	21:00	2,949			1	1	1	1	
	22:00	2,644			1	1	1	1	
	23:00	2,412				1	1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 29 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 29 Αυγούστου 2025	00:00	2,207				1	1	1	
	01:00	2,001				1	1	1	
	02:00	1,810				1	1		
	03:00	1,739				1	1		
	04:00	1,683				1	1		
	05:00	1,696				1	1		
	06:00	1,815				1	1		
	07:00	2,053	1			1	1		
	08:00	2,174	1			1	1		
	09:00	2,408	1			1	1		
	10:00	2,496	1			1	1		
	11:00	2,477	1			1	1		
	12:00	2,505	1			1	1		
	13:00	2,574	1			1	1		
	14:00	2,449	1			1	1		
	15:00	2,298	1			1	1		
	16:00	2,239	1			1	1		
	17:00	2,386	1			1	1		
	18:00	2,583	1			1	1		
	19:00	2,797	1			1	1		
	20:00	3,043	1		1	1	1		
	21:00	2,912	1		1	1	1		
	22:00	2,581			1	1	1		
	23:00	2,412			1	1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 30 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 30 Αυγούστου 2025	00:00	2,195			1	1	1		
	01:00	1,995			1	1	1		
	02:00	1,840			1		1		
	03:00	1,764			1		1		
	04:00	1,712			1		1		
	05:00	1,708			1		1		
	06:00	1,762			1		1		
	07:00	1,934			1		1		
	08:00	2,114			1		1		1
	09:00	2,316			1		1		1
	10:00	2,336			1		1		1
	11:00	2,285			1		1		1
	12:00	2,398			1		1		1
	13:00	2,461			1		1		1
	14:00	2,435			1		1		1
	15:00	2,413			1		1		1
	16:00	2,282			1		1		1
	17:00	2,405			1		1		1
	18:00	2,754			1		1		1
	19:00	2,812			1		1		1
	20:00	3,059			1		1		1
	21:00	2,903			1		1	1	
	22:00	2,596			1		1	1	
	23:00	2,435			1		1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 31 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 31 Αυγούστου 2025	00:00	2,232			1		1	1	
	01:00	2,057			1		1	1	
	02:00	1,935			1		1	1	
	03:00	1,847			1			1	
	04:00	1,774			1			1	
	05:00	1,780			1			1	
	06:00	1,808			1			1	
	07:00	2,011			1			1	
	08:00	2,181	1		1			1	
	09:00	2,451	1		1			1	
	10:00	2,498	1		1			1	
	11:00	2,524	1		1			1	
	12:00	2,568	1		1			1	
	13:00	2,576	1		1			1	
	14:00	2,554	1		1			1	
	15:00	2,562	1		1			1	
	16:00	2,517	1		1			1	
	17:00	2,553	1		1			1	
	18:00	2,701	1		1			1	
	19:00	2,819	1		1			1	
	20:00	3,048	1		1			1	
	21:00	2,974	1		1			1	
	22:00	2,695			1	1		1	
	23:00	2,525			1	1		1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 1 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 1 Σεπτεμβρίου 2025	00:00	2,338			1	1		1	
	01:00	2,081			1	1		1	
	02:00	1,914			1	1		1	
	03:00	1,885				1		1	
	04:00	1,860				1		1	
	05:00	1,855				1		1	
	06:00	1,960				1		1	
	07:00	2,197				1		1	1
	08:00	2,352				1		1	1
	09:00	2,495				1		1	1
	10:00	2,468				1		1	1
	11:00	2,484				1		1	1
	12:00	2,574				1		1	1
	13:00	2,695				1		1	1
	14:00	2,568				1		1	1
	15:00	2,624				1		1	1
	16:00	2,482				1		1	1
	17:00	2,490				1		1	1
	18:00	2,669				1		1	1
	19:00	2,855				1		1	1
	20:00	2,935		1		1	1	1	
	21:00	2,874		1		1	1	1	
	22:00	2,570				1	1	1	
	23:00	2,291				1	1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 2 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Π Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 2 Σεπτεμβρίου 2025	00:00	2,076				1	1	1	
	01:00	1,902				1	1	1	
	02:00	1,785				1	1		
	03:00	1,745				1	1		
	04:00	1,735				1	1		
	05:00	1,761				1	1		
	06:00	1,856				1	1		
	07:00	2,049	1			1	1		
	08:00	2,202	1			1	1		
	09:00	2,284	1			1	1		
	10:00	2,364	1			1	1		
	11:00	2,423	1	1			1		
	12:00	2,472	1	1			1		
	13:00	2,585	1	1			1		
	14:00	2,529	1	1			1		
	15:00	2,338	1	1			1		
	16:00	2,211	1	1			1		
	17:00	2,343	1	1			1		
	18:00	2,509	1	1			1		
	19:00	2,699	1	1			1		
	20:00	2,988	1	1			1		
	21:00	2,839	1	1	1		1		
	22:00	2,544		1	1		1		
	23:00	2,329		1	1		1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 3 Σεπτεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ω Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 3 Σεπτεμβρίου 2025	00:00	2,150		1	1		1		
	01:00	2,021		1	1		1		
	02:00	1,881		1	1				
	03:00	1,846		1	1				
	04:00	1,782		1	1				
	05:00	1,793		1	1				
	06:00	1,857		1	1				
	07:00	2,096		1	1				1
	08:00	2,227		1	1				1
	09:00	2,343		1	1				1
	10:00	2,383		1	1				1
	11:00	2,375		1	1				1
	12:00	2,510		1	1				1
	13:00	2,706		1	1				1
	14:00	2,576	1	1	1				1
	15:00	2,461	1	1	1				1
	16:00	2,378		1	1				1
	17:00	2,487		1	1				1
	18:00	2,642		1	1				1
	19:00	2,777		1	1			1	
	20:00	2,985		1	1			1	
	21:00	2,901		1	1			1	
	22:00	2,576		1	1			1	
	23:00	2,426		1	1			1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης