

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 6 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 6 Νοεμβρίου 2025	00:00	0,781		1							
	01:00	0,737		1							
	02:00	0,710		1							
	03:00	0,696		1							
	04:00	0,701		1							
	05:00	0,719		1							
	06:00	0,764		1							
	07:00	0,781		1							
	08:00	0,780		1							
	09:00	0,784		1							
	10:00	0,785		1							
	11:00	0,794		1							
	12:00	0,809		1					1		
	13:00	0,816		1					1		
	14:00	0,838		1					1		
	15:00	0,876		1					1		
	16:00	0,937		1					1		
	17:00	1,015		1					1		
	18:00	1,067		1					1		
	19:00	1,114		1					1		
	20:00	1,091		1					1		
	21:00	1,031		1					1		
	22:00	0,930		1					1		
	23:00	0,799		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 7 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 7 Νοεμβρίου 2025	00:00	0,768		1							
	01:00	0,720		1							
	02:00	0,689		1							
	03:00	0,673		1							
	04:00	0,675		1							
	05:00	0,693		1							
	06:00	0,738		1							
	07:00	0,758		1							
	08:00	0,758		1							
	09:00	0,763		1							
	10:00	0,781		1							
	11:00	0,848		1					1		
	12:00	0,871		1					1		
	13:00	0,857		1					1		
	14:00	0,820		1					1		
	15:00	0,852		1					1		
	16:00	0,916		1					1		
	17:00	1,014		1					1		
	18:00	1,088		1					1		
	19:00	1,138		1					1		
	20:00	1,129		1					1		
	21:00	1,067		1					1		
	22:00	0,960		1					1		
	23:00	0,819		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 8 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 8 Νοεμβρίου 2025	00:00	0,790		1							
	01:00	0,738		1							
	02:00	0,703		1							
	03:00	0,686		1							
	04:00	0,688		1							
	05:00	0,707		1							
	06:00	0,753		1							
	07:00	0,794		1							
	08:00	0,813		1					1		
	09:00	0,838		1					1		
	10:00	0,818		1					1		
	11:00	0,828		1					1		
	12:00	0,837		1					1		
	13:00	0,842		1					1		
	14:00	0,862		1					1		
	15:00	0,896		1					1		
	16:00	0,961		1					1		
	17:00	1,060		1					1		
	18:00	1,136		1					1		
	19:00	1,181		1					1		
	20:00	1,174		1					1		
	21:00	1,109		1					1		
	22:00	1,000		1					1		
	23:00	0,859		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 9 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 9 Νοεμβρίου 2025	00:00	0,808		1					1		
	01:00	0,749		1							
	02:00	0,710		1							
	03:00	0,689		1							
	04:00	0,684		1							
	05:00	0,698		1							
	06:00	0,743		1							
	07:00	0,780		1							
	08:00	0,814		1					1		
	09:00	0,867		1					1		
	10:00	0,891		1					1		
	11:00	0,934		1					1		
	12:00	0,947		1					1		
	13:00	0,895		1					1		
	14:00	0,859		1					1		
	15:00	0,844		1					1		
	16:00	0,888		1					1		
	17:00	0,963		1					1		
	18:00	1,022		1					1		
	19:00	1,054		1					1		
	20:00	1,054		1					1		
	21:00	1,007		1					1		
	22:00	0,920		1					1		
	23:00	0,801		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 10 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 10 Νοεμβρίου 2025	00:00	0,753		1							
	01:00	0,712		1							
	02:00	0,689		1							
	03:00	0,679		1							
	04:00	0,684		1							
	05:00	0,700		1							
	06:00	0,742		1							
	07:00	0,769		1							
	08:00	0,788		1							
	09:00	0,778		1							
	10:00	0,771		1							
	11:00	0,766		1							
	12:00	0,770		1							
	13:00	0,772		1							
	14:00	0,782		1							
	15:00	0,812		1					1		
	16:00	0,866		1					1		
	17:00	0,951		1					1		
	18:00	1,018		1					1		
	19:00	1,050		1					1		
	20:00	1,056		1					1		
	21:00	1,012		1					1		
	22:00	0,926		1					1		
	23:00	0,804		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 11 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 11 Νοεμβρίου 2025	00:00	0,734		1							
	01:00	0,693		1							
	02:00	0,669		1							
	03:00	0,658		1							
	04:00	0,665		1							
	05:00	0,686		1							
	06:00	0,736		1							
	07:00	0,765		1							
	08:00	0,780		1							
	09:00	0,781		1							
	10:00	0,770		1							
	11:00	0,770		1							
	12:00	0,773		1							
	13:00	0,776		1							
	14:00	0,789		1							
	15:00	0,823		1					1		
	16:00	0,876		1					1		
	17:00	0,967		1					1		
	18:00	1,047		1					1		
	19:00	1,080		1					1		
	20:00	1,079		1					1		
	21:00	1,031		1					1		
	22:00	0,937		1					1		
	23:00	0,805		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 12 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 12 Νοεμβρίου 2025	00:00	0,730		1							
	01:00	0,692		1							
	02:00	0,670		1							
	03:00	0,663		1							
	04:00	0,672		1							
	05:00	0,694		1							
	06:00	0,738		1							
	07:00	0,775		1							
	08:00	0,791		1							
	09:00	0,786		1							
	10:00	0,778		1							
	11:00	0,777		1							
	12:00	0,778		1							
	13:00	0,779		1							
	14:00	0,791		1							
	15:00	0,822		1					1		
	16:00	0,877		1					1		
	17:00	0,968		1					1		
	18:00	1,049		1					1		
	19:00	1,086		1					1		
	20:00	1,081		1					1		
	21:00	1,027		1					1		
	22:00	0,922		1					1		
	23:00	0,795		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης