

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 27 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 27 Νοεμβρίου 2025	00:00	0,728							1		
	01:00	0,686							1		
	02:00	0,659							1		
	03:00	0,648							1		
	04:00	0,653							1		
	05:00	0,676							1		
	06:00	0,719							1		
	07:00	0,745							1		
	08:00	0,754							1		
	09:00	0,748							1		
	10:00	0,754							1		
	11:00	0,753							1		
	12:00	0,761							1		
	13:00	0,770							1		
	14:00	0,784							1		
	15:00	0,821							1		
	16:00	0,888	1						1		
	17:00	0,976	1						1		
	18:00	1,034	1						1		
	19:00	1,051	1						1		
	20:00	1,045	1						1		
	21:00	0,991	1						1		
	22:00	0,912	1						1		
	23:00	0,786	1								

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 28 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 28 Νοεμβρίου 2025	00:00	0,723	1								
	01:00	0,677	1								
	02:00	0,648	1								
	03:00	0,635	1								
	04:00	0,636	1								
	05:00	0,654	1								
	06:00	0,697	1								
	07:00	0,728	1								
	08:00	0,769	1								
	09:00	0,796	1								
	10:00	0,785	1								
	11:00	0,780	1								
	12:00	0,794	1								
	13:00	0,850	1								
	14:00	0,873	1						1		
	15:00	0,884	1						1		
	16:00	0,918	1						1		
	17:00	0,986	1						1		
	18:00	1,039	1						1		
	19:00	1,077	1						1		
	20:00	1,079	1						1		
	21:00	1,024	1						1		
	22:00	0,936	1						1		
	23:00	0,806							1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 29 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 29 Νοεμβρίου 2025	00:00	0,743							1		
	01:00	0,692							1		
	02:00	0,657							1		
	03:00	0,640							1		
	04:00	0,642							1		
	05:00	0,660							1		
	06:00	0,706							1		
	07:00	0,746							1		
	08:00	0,785							1		
	09:00	0,824							1		
	10:00	0,863							1		
	11:00	0,819							1		
	12:00	0,889	1						1		
	13:00	0,901	1						1		
	14:00	0,928	1						1		
	15:00	0,950	1						1		
	16:00	0,984	1						1		
	17:00	1,045	1						1		
	18:00	1,095	1						1		
	19:00	1,127	1						1		
	20:00	1,125	1						1		
	21:00	1,070	1						1		
	22:00	0,975	1						1		
	23:00	0,846							1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 30 Νοεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 30 Νοεμβρίου 2025	00:00	0,762							1		
	01:00	0,704							1		
	02:00	0,664							1		
	03:00	0,645							1		
	04:00	0,646							1		
	05:00	0,662							1		
	06:00	0,709							1		
	07:00	0,749							1		
	08:00	0,786							1		
	09:00	0,793							1		
	10:00	0,798							1		
	11:00	0,801							1		
	12:00	0,800							1		
	13:00	0,795							1		
	14:00	0,801							1		
	15:00	0,824							1		
	16:00	0,875	1						1		
	17:00	0,982	1						1		
	18:00	1,034	1						1		
	19:00	1,059	1						1		
	20:00	1,050	1						1		
	21:00	0,998	1						1		
	22:00	0,909	1						1		
	23:00	0,795	1								

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 1 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 1 Δεκεμβρίου 2025	00:00	0,724	1								
	01:00	0,682	1								
	02:00	0,657	1								
	03:00	0,648	1								
	04:00	0,658	1								
	05:00	0,685	1								
	06:00	0,736	1								
	07:00	0,771	1								
	08:00	0,798	1								
	09:00	0,783	1								
	10:00	0,778	1								
	11:00	0,777	1								
	12:00	0,781	1								
	13:00	0,791	1								
	14:00	0,806	1								
	15:00	0,853	1								
	16:00	0,930	1						1		
	17:00	1,037	1						1		
	18:00	1,102	1						1		
	19:00	1,122	1						1		
	20:00	1,114	1						1		
	21:00	1,059	1						1		
	22:00	0,956	1						1		
	23:00	0,830							1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 2 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 2 Δεκεμβρίου 2025	00:00	0,730							1		
	01:00	0,691							1		
	02:00	0,668							1		
	03:00	0,660							1		
	04:00	0,674							1		
	05:00	0,703							1		
	06:00	0,754							1		
	07:00	0,794							1		
	08:00	0,826							1		
	09:00	0,799							1		
	10:00	0,794							1		
	11:00	0,792							1		
	12:00	0,797							1		
	13:00	0,806							1		
	14:00	0,823							1		
	15:00	0,869	1						1		
	16:00	0,949	1						1		
	17:00	1,067	1						1		
	18:00	1,138	1						1		
	19:00	1,158	1						1		
	20:00	1,143	1						1		
	21:00	1,076	1						1		
	22:00	0,968	1						1		
	23:00	0,833	1								

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 3 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 3 Δεκεμβρίου 2025	00:00	0,742	1								
	01:00	0,702	1								
	02:00	0,679	1								
	03:00	0,672	1								
	04:00	0,683	1								
	05:00	0,710	1								
	06:00	0,757	1								
	07:00	0,800	1								
	08:00	0,832	1								
	09:00	0,818	1								
	10:00	0,817	1								
	11:00	0,815	1								
	12:00	0,840	1								
	13:00	0,823	1								
	14:00	0,846	1								
	15:00	0,884	1						1		
	16:00	0,957	1						1		
	17:00	1,058	1						1		
	18:00	1,118	1						1		
	19:00	1,143	1						1		
	20:00	1,134	1						1		
	21:00	1,071	1						1		
	22:00	0,962	1						1		
	23:00	0,822	1								

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης