

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 30 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 30 Οκτωβρίου 2025	00:00	1,183		1		1			
	01:00	1,127		1		1			
	02:00	1,067		1		1			
	03:00	1,067		1		1			
	04:00	1,087		1		1			
	05:00	1,110		1		1			
	06:00	1,173		1		1			
	07:00	1,239		1		1			
	08:00	1,247		1		1			
	09:00	1,254		1		1			
	10:00	1,194		1		1			
	11:00	1,202		1		1			
	12:00	1,243		1		1			
	13:00	1,225		1		1			
	14:00	1,207			1	1			
	15:00	1,177			1	1			
	16:00	1,242			1	1			
	17:00	1,388			1	1			
	18:00	1,587			1	1			
	19:00	1,614			1	1			
	20:00	1,634			1	1			
	21:00	1,619			1	1			
	22:00	1,407			1	1			
	23:00	1,265			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 31 Οκτωβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 31 Οκτωβρίου 2025	00:00	1,175			1	1			
	01:00	1,131			1	1			
	02:00	1,110			1	1			
	03:00	1,090			1	1			
	04:00	1,091			1	1			
	05:00	1,145			1	1			
	06:00	1,183			1	1			
	07:00	1,293				1			1
	08:00	1,302				1			1
	09:00	1,342				1			1
	10:00	1,291				1			1
	11:00	1,296				1			1
	12:00	1,398				1			1
	13:00	1,474				1			1
	14:00	1,408				1			1
	15:00	1,221				1			1
	16:00	1,334				1			1
	17:00	1,481				1			1
	18:00	1,594				1			1
	19:00	1,665				1			1
	20:00	1,672		1		1			
	21:00	1,541		1		1			
	22:00	1,420		1		1			
	23:00	1,332		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 1 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 1 Νοεμβρίου 2025	00:00	1,221		1		1			
	01:00	1,178		1		1			
	02:00	1,121		1		1			
	03:00	1,092		1		1			
	04:00	1,082		1		1			
	05:00	1,104		1		1			
	06:00	1,161		1		1			
	07:00	1,217		1		1			
	08:00	1,313		1		1			
	09:00	1,380		1					1
	10:00	1,406		1					1
	11:00	1,307		1					1
	12:00	1,320		1					1
	13:00	1,404		1					1
	14:00	1,322		1					1
	15:00	1,310		1					1
	16:00	1,317		1					1
	17:00	1,521		1					1
	18:00	1,692		1					1
	19:00	1,715		1	1				
	20:00	1,642		1	1				
	21:00	1,503		1	1				
	22:00	1,352		1	1				
	23:00	1,241		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 2 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 2 Νοεμβρίου 2025	00:00	1,194		1	1				
	01:00	1,145		1	1				
	02:00	1,076		1	1				
	03:00	1,066		1	1				
	04:00	1,076		1	1				
	05:00	1,096		1	1				
	06:00	1,162		1	1				
	07:00	1,205		1	1				
	08:00	1,296		1	1				
	09:00	1,305		1	1				
	10:00	1,391		1	1				
	11:00	1,428		1	1				
	12:00	1,356		1	1				
	13:00	1,295		1	1				
	14:00	1,218		1	1				
	15:00	1,254		1	1				
	16:00	1,320		1	1				
	17:00	1,428		1	1				
	18:00	1,566		1	1				
	19:00	1,577		1	1				
	20:00	1,586		1	1				
	21:00	1,528		1	1				
	22:00	1,360			1		1		
	23:00	1,314			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 3 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 3 Νοεμβρίου 2025	00:00	1,219			1		1		
	01:00	1,145			1		1		
	02:00	1,093			1		1		
	03:00	1,059			1		1		
	04:00	1,095			1		1		
	05:00	1,169			1		1		
	06:00	1,220			1		1		
	07:00	1,231			1		1		
	08:00	1,224			1		1		
	09:00	1,194			1		1		
	10:00	1,162			1		1		
	11:00	1,168			1		1		
	12:00	1,184			1		1		
	13:00	1,211			1		1		
	14:00	1,204			1		1		
	15:00	1,163			1		1		
	16:00	1,285			1		1		
	17:00	1,489			1		1		
	18:00	1,593			1		1		
	19:00	1,704			1		1		
	20:00	1,703			1		1		
	21:00	1,554			1		1		
	22:00	1,421				1	1		
	23:00	1,247				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 4 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 4 Νοεμβρίου 2025	00:00	1,151				1	1		
	01:00	1,130				1	1		
	02:00	1,075				1	1		
	03:00	1,074				1	1		
	04:00	1,104				1	1		
	05:00	1,101				1	1		
	06:00	1,170				1	1		
	07:00	1,332				1	1		
	08:00	1,505				1			1
	09:00	1,410				1			1
	10:00	1,353				1			1
	11:00	1,320				1			1
	12:00	1,478				1			1
	13:00	1,502				1			1
	14:00	1,494				1			1
	15:00	1,403				1	1		
	16:00	1,464				1	1		
	17:00	1,594				1	1		
	18:00	1,664				1	1		
	19:00	1,704				1	1		
	20:00	1,682				1	1		
	21:00	1,531				1	1		
	22:00	1,359				1	1		
	23:00	1,241				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 5 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 5 Νοεμβρίου 2025	00:00	1,138				1	1		
	01:00	1,099				1	1		
	02:00	1,048				1	1		
	03:00	1,060				1	1		
	04:00	1,060				1	1		
	05:00	1,077				1	1		
	06:00	1,181				1	1		
	07:00	1,327				1	1		
	08:00	1,492				1	1		
	09:00	1,635				1	1		
	10:00	1,548				1	1		
	11:00	1,609				1	1		
	12:00	1,705				1	1		
	13:00	1,739			1		1		
	14:00	1,658			1		1		
	15:00	1,622			1		1		
	16:00	1,572			1		1		
	17:00	1,677			1		1		
	18:00	1,732			1		1		
	19:00	1,830			1		1		
	20:00	1,838			1		1		
	21:00	1,484			1	1			
	22:00	1,517			1	1			
	23:00	1,318			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης