

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 18 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 18 Νοεμβρίου 2025	00:00	0,755				1					1
	01:00	0,711				1					
	02:00	0,721				1					
	03:00	0,716				1					
	04:00	0,703				1					
	05:00	0,728				1					
	06:00	0,788				1					
	07:00	0,832				1					
	08:00	1,149				1					1
	09:00	1,258				1					1
	10:00	1,286				1					1
	11:00	1,373				1					1
	12:00	1,374				1					1
	13:00	1,355				1					1
	14:00	1,345				1					1
	15:00	1,269				1					1
	16:00	1,288				1					1
	17:00	1,438				1					1
	18:00	1,506				1					1
	19:00	1,493				1					1
	20:00	1,482				1					1
	21:00	1,390				1					1
	22:00	1,231				1					1
	23:00	0,851				1					1

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 19 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 19 Νοεμβρίου 2025	00:00	0,752				1					1
	01:00	0,726				1					
	02:00	0,722				1					
	03:00	0,716				1					
	04:00	0,711				1					
	05:00	0,715				1					
	06:00	0,788				1					
	07:00	0,870				1					
	08:00	1,035				1					1
	09:00	1,253				1					1
	10:00	1,296				1					1
	11:00	1,325				1					1
	12:00	1,369				1					1
	13:00	1,393				1					1
	14:00	1,328				1					1
	15:00	1,299				1					1
	16:00	1,337				1					1
	17:00	1,448				1					1
	18:00	1,493				1					1
	19:00	1,520				1					1
	20:00	1,493				1					1
	21:00	1,381				1					1
	22:00	1,237				1					1
	23:00	0,846				1					1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 20 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Α Π Ο Λ Ο Γ Ι Σ Μ Ο Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 20 Νοεμβρίου 2025	00:00	0,754				1					
	01:00	0,720				1					
	02:00	0,724				1					
	03:00	0,714				1					
	04:00	0,705				1					
	05:00	0,746				1					
	06:00	0,828				1					
	07:00	0,856				1					
	08:00	1,185				1					1
	09:00	1,318				1					1
	10:00	1,335				1					1
	11:00	1,380				1					1
	12:00	1,395				1					1
	13:00	1,470				1					1
	14:00	1,409				1					1
	15:00	1,335				1					1
	16:00	1,318				1					1
	17:00	1,480				1					1
	18:00	1,527				1					1
	19:00	1,538				1					1
	20:00	1,475				1					1
	21:00	1,375				1					1
	22:00	1,273				1					1
	23:00	0,828				1					1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 21 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Α Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 21 Νοεμβρίου 2025	00:00	0,769				1					1
	01:00	0,735				1					
	02:00	0,722				1					
	03:00	0,718				1					
	04:00	0,734				1					
	05:00	0,760				1					
	06:00	0,807				1					
	07:00	0,825				1					
	08:00	0,972				1					1
	09:00	1,230				1					1
	10:00	1,228				1					1
	11:00	1,227				1					1
	12:00	1,252				1					1
	13:00	1,291				1					1
	14:00	1,218				1					1
	15:00	1,202				1					1
	16:00	1,179				1					1
	17:00	1,366				1					1
	18:00	1,425				1					1
	19:00	1,389				1					1
	20:00	1,439				1					1
	21:00	1,303				1					1
	22:00	1,213				1					1
	23:00	0,832				1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 22 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 22 Νοεμβρίου 2025	00:00	0,777				1					
	01:00	0,717				1					
	02:00	0,718				1					
	03:00	0,707				1					
	04:00	0,711				1					
	05:00	0,725				1					
	06:00	0,775				1					
	07:00	0,759				1					
	08:00	1,009				1					1
	09:00	1,219				1					1
	10:00	1,280				1					1
	11:00	1,271				1					1
	12:00	1,298				1					1
	13:00	1,319				1					1
	14:00	1,316				1					1
	15:00	1,292				1					1
	16:00	1,302				1					1
	17:00	1,389				1					1
	18:00	1,444				1					1
	19:00	1,411				1					1
	20:00	1,405				1					1
	21:00	1,307				1					1
	22:00	1,223				1					1
	23:00	0,806				1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 23 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 23 Νοεμβρίου 2025	00:00	0,758				1					
	01:00	0,719				1					
	02:00	0,722	1								
	03:00	0,702	1								
	04:00	0,695	1								
	05:00	0,713	1								
	06:00	0,766	1								
	07:00	0,748	1								
	08:00	0,995	1								
	09:00	1,209				1					1
	10:00	1,297				1					1
	11:00	1,350				1					1
	12:00	1,370				1					1
	13:00	1,331				1					1
	14:00	1,269				1					1
	15:00	1,250				1					1
	16:00	1,252				1					1
	17:00	1,358				1					1
	18:00	1,391				1					1
	19:00	1,375				1					1
	20:00	1,327				1					1
	21:00	1,291				1					1
	22:00	1,033				1					1
	23:00	0,788				1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 24 Νοεμβρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 24 Νοεμβρίου 2025	00:00	0,729				1					
	01:00	0,690				1					
	02:00	0,703				1					
	03:00	0,685				1					
	04:00	0,692				1					
	05:00	0,704				1					
	06:00	0,794				1					
	07:00	0,799				1					
	08:00	0,987				1					1
	09:00	1,073				1					1
	10:00	1,215				1					1
	11:00	1,273				1					1
	12:00	1,275				1					1
	13:00	1,272				1					1
	14:00	1,286				1					1
	15:00	1,270				1					1
	16:00	1,278				1					1
	17:00	1,393				1					1
	18:00	1,499				1					1
	19:00	1,457				1					1
	20:00	1,432				1					1
	21:00	1,392				1					1
	22:00	1,306				1					1
	23:00	1,177				1					1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης