

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 7 Ιανουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 7 Ιανουαρίου 2026	00:00	80	1	1					
	01:00	75	1	1					
	02:00	72	1	1					
	03:00	70	1	1					
	04:00	69	1	1					
	05:00	71	1	1					
	06:00	73	1	1					
	07:00	78	1	1					
	08:00	84	1	1					
	09:00	87	1	1					
	10:00	88	1	1					
	11:00	88	1	1					
	12:00	87	1	1					
	13:00	86	1	1					
	14:00	87	1	1					
	15:00	90	1	1					
	16:00	96	1	1					
	17:00	108	1	1					
	18:00	123	1	1					
	19:00	134	1	1					
	20:00	131	1	1					
	21:00	123	1	1					
	22:00	115	1	1					
	23:00	100	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 8 Ιανουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 8 Ιανουαρίου 2026	00:00	84	1	1					
	01:00	77	1	1					
	02:00	72	1	1					
	03:00	69	1	1					
	04:00	68	1	1					
	05:00	70	1	1					
	06:00	74	1	1					
	07:00	80	1	1					
	08:00	86	1	1					
	09:00	90	1	1					
	10:00	91	1	1					
	11:00	91	1	1					
	12:00	91	1	1					
	13:00	91	1	1					
	14:00	94	1	1					
	15:00	102	1	1					
	16:00	114	1	1					
	17:00	131	1	1					
	18:00	147	1	1					
	19:00	158	1	1					
	20:00	157	1	1					
	21:00	150	1	1					
	22:00	139	1	1					
	23:00	120	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 9 Ιανουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 9 Ιανουαρίου 2026	00:00	96	1	1					
	01:00	89	1	1					
	02:00	84	1	1					
	03:00	82	1	1					
	04:00	83	1	1					
	05:00	86	1	1					
	06:00	92	1	1					
	07:00	98	1	1					
	08:00	103	1	1					
	09:00	104	1	1					
	10:00	104	1	1					
	11:00	102	1	1					
	12:00	100	1	1					
	13:00	97	1	1					
	14:00	96	1	1					
	15:00	101	1	1					
	16:00	113	1	1					
	17:00	134	1	1					
	18:00	153	1	1					
	19:00	162	1	1					
	20:00	159	1	1					
	21:00	147	1	1					
	22:00	130	1	1					
	23:00	108	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 10 Ιανουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 10 Ιανουαρίου 2026	00:00	93	1	1					
	01:00	87	1	1					
	02:00	84	1	1					
	03:00	84	1	1					
	04:00	86	1	1					
	05:00	89	1	1					
	06:00	94	1	1					
	07:00	99	1	1					
	08:00	104	1	1					
	09:00	105	1	1					
	10:00	105	1	1					
	11:00	104	1	1					
	12:00	103	1	1					
	13:00	101	1	1					
	14:00	100	1	1					
	15:00	101	1	1					
	16:00	107	1	1					
	17:00	123	1	1					
	18:00	137	1	1					
	19:00	144	1	1					
	20:00	140	1	1					
	21:00	128	1	1					
	22:00	112	1	1					
	23:00	94	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 11 Ιανουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 11 Ιανουαρίου 2026	00:00	90	1	1					
	01:00	85	1	1					
	02:00	82	1	1					
	03:00	81	1	1					
	04:00	82	1	1					
	05:00	85	1	1					
	06:00	89	1	1					
	07:00	93	1	1					
	08:00	97	1	1					
	09:00	100	1	1					
	10:00	101	1	1					
	11:00	101	1	1					
	12:00	102	1	1					
	13:00	101	1	1					
	14:00	99	1	1					
	15:00	99	1	1					
	16:00	101	1	1					
	17:00	110	1	1					
	18:00	124	1	1					
	19:00	131	1	1					
	20:00	127	1	1					
	21:00	118	1	1					
	22:00	106	1	1					
	23:00	93	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 12 Ιανουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 12 Ιανουαρίου 2026	00:00	88	1	1					
	01:00	85	1	1					
	02:00	84	1	1					
	03:00	84	1	1					
	04:00	86	1	1					
	05:00	88	1	1					
	06:00	91	1	1					
	07:00	94	1	1					
	08:00	97	1	1					
	09:00	99	1	1					
	10:00	100	1	1					
	11:00	100	1	1					
	12:00	101	1	1					
	13:00	100	1	1					
	14:00	99	1	1					
	15:00	99	1	1					
	16:00	102	1	1					
	17:00	111	1	1					
	18:00	122	1	1					
	19:00	129	1	1					
	20:00	125	1	1					
	21:00	116	1	1					
	22:00	106	1	1					
	23:00	93	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ			Προτεινόμενος ΗΕΠ		Τρίτη, 13 Ιανουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 13 Ιανουαρίου 2026	00:00	87	1	1					
	01:00	83	1	1					
	02:00	80	1	1					
	03:00	78	1	1					
	04:00	78	1	1					
	05:00	80	1	1					
	06:00	82	1	1					
	07:00	85	1	1					
	08:00	89	1	1					
	09:00	92	1	1					
	10:00	94	1	1					
	11:00	96	1	1					
	12:00	96	1	1					
	13:00	95	1	1					
	14:00	93	1	1					
	15:00	93	1	1					
	16:00	95	1	1					
	17:00	103	1	1					
	18:00	113	1	1					
	19:00	121	1	1					
	20:00	120	1	1					
	21:00	113	1	1					
	22:00	103	1	1					
	23:00	91	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης