

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 10 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 10 Δεκεμβρίου 2025	00:00	68	1						
	01:00	64	1						
	02:00	63	1						
	03:00	63	1						
	04:00	64	1						
	05:00	66	1						
	06:00	69	1						
	07:00	72	1						
	08:00	76	1						
	09:00	77	1						
	10:00	77	1						
	11:00	76	1						
	12:00	75	1						
	13:00	74	1						
	14:00	73	1						
	15:00	72	1						
	16:00	73	1						
	17:00	83	1	1					
	18:00	92	1	1					
	19:00	96	1	1					
	20:00	96	1	1					
	21:00	90	1	1					
	22:00	81	1	1					
	23:00	73	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 11 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 11 Δεκεμβρίου 2025	00:00	71	1						
	01:00	67	1						
	02:00	65	1						
	03:00	64	1						
	04:00	65	1						
	05:00	68	1						
	06:00	70	1						
	07:00	72	1						
	08:00	76	1						
	09:00	77	1						
	10:00	77	1						
	11:00	76	1						
	12:00	75	1						
	13:00	74	1						
	14:00	73	1						
	15:00	74	1						
	16:00	76	1						
	17:00	85	1						
	18:00	92	1	1					
	19:00	97	1	1					
	20:00	97	1	1					
	21:00	93	1	1					
	22:00	84	1	1					
	23:00	73	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 12 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 12 Δεκεμβρίου 2025	00:00	71	1						
	01:00	67	1						
	02:00	64	1						
	03:00	63	1						
	04:00	63	1						
	05:00	67	1						
	06:00	70	1						
	07:00	73	1						
	08:00	77	1						
	09:00	77	1						
	10:00	78	1						
	11:00	77	1						
	12:00	77	1						
	13:00	75	1						
	14:00	74	1						
	15:00	73	1						
	16:00	77	1						
	17:00	85	1	1					
	18:00	91	1	1					
	19:00	96	1	1					
	20:00	97	1	1					
	21:00	92	1	1					
	22:00	83	1	1					
	23:00	70	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 13 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 13 Δεκεμβρίου 2025	00:00	70	1						
	01:00	64	1						
	02:00	61	1						
	03:00	59	1						
	04:00	60	1						
	05:00	63	1						
	06:00	67	1						
	07:00	72	1						
	08:00	74	1						
	09:00	74	1						
	10:00	74	1						
	11:00	76	1						
	12:00	76	1						
	13:00	74	1						
	14:00	72	1						
	15:00	72	1						
	16:00	76	1						
	17:00	87	1	1					
	18:00	95	1	1					
	19:00	97	1	1					
	20:00	97	1	1					
	21:00	92	1	1					
	22:00	81	1	1					
	23:00	70	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 14 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 14 Δεκεμβρίου 2025	00:00	68	1						
	01:00	62	1						
	02:00	59	1						
	03:00	58	1						
	04:00	59	1						
	05:00	61	1						
	06:00	64	1						
	07:00	68	1						
	08:00	71	1						
	09:00	74	1						
	10:00	76	1						
	11:00	76	1						
	12:00	75	1						
	13:00	72	1						
	14:00	70	1						
	15:00	71	1						
	16:00	73	1						
	17:00	81	1	1					
	18:00	91	1	1					
	19:00	95	1	1					
	20:00	95	1	1					
	21:00	91	1	1					
	22:00	83	1	1					
	23:00	74	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 15 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 15 Δεκεμβρίου 2025	00:00	66	1						
	01:00	63	1						
	02:00	61	1						
	03:00	62	1						
	04:00	64	1						
	05:00	67	1						
	06:00	70	1						
	07:00	75	1						
	08:00	78	1						
	09:00	78	1						
	10:00	79	1						
	11:00	79	1						
	12:00	78	1						
	13:00	77	1						
	14:00	76	1						
	15:00	76	1						
	16:00	80	1	1					
	17:00	93	1	1					
	18:00	102	1	1					
	19:00	107	1	1					
	20:00	107	1	1					
	21:00	101	1	1					
	22:00	90	1	1					
	23:00	77	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 16 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 16 Δεκεμβρίου 2025	00:00	74	1						
	01:00	70	1						
	02:00	66	1						
	03:00	67	1						
	04:00	69	1						
	05:00	74	1						
	06:00	78	1						
	07:00	81	1	1					
	08:00	84	1	1					
	09:00	85	1	1					
	10:00	86	1	1					
	11:00	85	1	1					
	12:00	84	1	1					
	13:00	82	1	1					
	14:00	82	1	1					
	15:00	83	1	1					
	16:00	87	1	1					
	17:00	99	1	1					
	18:00	108	1	1					
	19:00	113	1	1					
	20:00	113	1	1					
	21:00	108	1	1					
	22:00	95	1	1					
	23:00	81	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης