

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 17 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 17 Δεκεμβρίου 2025	00:00	81	1						
	01:00	77	1						
	02:00	75	1						
	03:00	75	1						
	04:00	76	1						
	05:00	78	1						
	06:00	81	1		1				
	07:00	83	1		1				
	08:00	85	1		1				
	09:00	86	1		1				
	10:00	86	1		1				
	11:00	85	1		1				
	12:00	84	1		1				
	13:00	82	1		1				
	14:00	79	1		1				
	15:00	78	1		1				
	16:00	81	1		1				
	17:00	92	1		1				
	18:00	103	1		1				
	19:00	111	1		1				
	20:00	110	1		1				
	21:00	106	1		1				
	22:00	98	1		1				
	23:00	88	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 18 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 18 Δεκεμβρίου 2025	00:00	79	1						
	01:00	75	1						
	02:00	73	1						
	03:00	72	1						
	04:00	73	1						
	05:00	74	1						
	06:00	76	1						
	07:00	79	1						
	08:00	81	1		1				
	09:00	82	1		1				
	10:00	82	1		1				
	11:00	81	1		1				
	12:00	80	1		1				
	13:00	78	1		1				
	14:00	76	1		1				
	15:00	78	1		1				
	16:00	81	1		1				
	17:00	95	1		1				
	18:00	106	1		1				
	19:00	113	1		1				
	20:00	112	1		1				
	21:00	108	1		1				
	22:00	97	1		1				
	23:00	83	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 19 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 19 Δεκεμβρίου 2025	00:00	75	1						
	01:00	71	1						
	02:00	68	1						
	03:00	67	1						
	04:00	68	1						
	05:00	72	1						
	06:00	76	1						
	07:00	82	1		1				
	08:00	87	1		1				
	09:00	87	1		1				
	10:00	86	1		1				
	11:00	85	1		1				
	12:00	82	1		1				
	13:00	80	1		1				
	14:00	76	1		1				
	15:00	77	1		1				
	16:00	81	1		1				
	17:00	101	1		1				
	18:00	114	1		1				
	19:00	118	1		1				
	20:00	113	1		1				
	21:00	106	1		1				
	22:00	93	1		1				
	23:00	79	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 20 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Α Ρ Ω Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 20 Δεκεμβρίου 2025	00:00	76	1						
	01:00	71	1						
	02:00	68	1						
	03:00	67	1						
	04:00	67	1						
	05:00	70	1						
	06:00	74	1						
	07:00	79	1		1				
	08:00	83	1		1				
	09:00	84	1		1				
	10:00	85	1		1				
	11:00	84	1		1				
	12:00	84	1		1				
	13:00	81	1		1				
	14:00	80	1		1				
	15:00	81	1		1				
	16:00	84	1		1				
	17:00	98	1		1				
	18:00	110	1		1				
	19:00	114	1		1				
	20:00	110	1		1				
	21:00	103	1		1				
	22:00	91	1		1				
	23:00	79	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 21 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Ε Τ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 21 Δεκεμβρίου 2025	00:00	75	1						
	01:00	69	1						
	02:00	65	1						
	03:00	65	1						
	04:00	66	1						
	05:00	68	1						
	06:00	72	1						
	07:00	77	1		1				
	08:00	79	1		1				
	09:00	83	1		1				
	10:00	85	1		1				
	11:00	86	1		1				
	12:00	85	1		1				
	13:00	84	1		1				
	14:00	83	1		1				
	15:00	83	1		1				
	16:00	87	1		1				
	17:00	98	1		1				
	18:00	108	1		1				
	19:00	112	1		1				
	20:00	109	1		1				
	21:00	103	1		1				
	22:00	93	1		1				
	23:00	82	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 22 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 22 Δεκεμβρίου 2025	00:00	74	1						
	01:00	71	1						
	02:00	71	1						
	03:00	72	1						
	04:00	74	1						
	05:00	77	1						
	06:00	80	1		1				
	07:00	83	1		1				
	08:00	86	1		1				
	09:00	88	1		1				
	10:00	89	1		1				
	11:00	89	1		1				
	12:00	89	1		1				
	13:00	88	1		1				
	14:00	86	1		1				
	15:00	86	1		1				
	16:00	90	1		1				
	17:00	102	1		1				
	18:00	113	1		1				
	19:00	118	1		1				
	20:00	113	1		1				
	21:00	106	1		1				
	22:00	95	1		1				
	23:00	82	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 23 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 23 Δεκεμβρίου 2025	00:00	81	1						
	01:00	78	1						
	02:00	77	1						
	03:00	76	1						
	04:00	77	1						
	05:00	78	1		1				
	06:00	81	1		1				
	07:00	83	1		1				
	08:00	86	1		1				
	09:00	88	1		1				
	10:00	90	1		1				
	11:00	90	1		1				
	12:00	90	1		1				
	13:00	89	1		1				
	14:00	88	1		1				
	15:00	88	1		1				
	16:00	91	1		1				
	17:00	101	1		1				
	18:00	112	1		1				
	19:00	117	1		1				
	20:00	114	1		1				
	21:00	107	1		1				
	22:00	97	1		1				
	23:00	83	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης