

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 24 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Ε Τ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 24 Δεκεμβρίου 2025	00:00	68	1						
	01:00	64	1						
	02:00	59	1						
	03:00	58	1						
	04:00	58	1						
	05:00	59	1						
	06:00	56	1						
	07:00	58	1						
	08:00	62	1						
	09:00	66	1						
	10:00	77	1						
	11:00	78	1						
	12:00	77	1						
	13:00	76	1						
	14:00	74	1						
	15:00	73	1						
	16:00	75	1						
	17:00	83	1		1				
	18:00	93	1		1				
	19:00	96	1		1				
	20:00	99	1		1				
	21:00	94	1		1				
	22:00	85	1		1				
	23:00	74	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 25 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 25 Δεκεμβρίου 2025	00:00	65	1						
	01:00	61	1						
	02:00	59	1						
	03:00	58	1						
	04:00	58	1						
	05:00	60	1						
	06:00	63	1						
	07:00	66	1						
	08:00	69	1						
	09:00	71	1						
	10:00	73	1						
	11:00	73	1						
	12:00	72	1						
	13:00	71	1						
	14:00	70	1						
	15:00	71	1						
	16:00	76	1						
	17:00	88	1		1				
	18:00	98	1		1				
	19:00	101	1		1				
	20:00	102	1		1				
	21:00	97	1		1				
	22:00	87	1		1				
	23:00	76	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 26 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 26 Δεκεμβρίου 2025	00:00	67	1						
	01:00	61	1						
	02:00	57	1						
	03:00	55	1						
	04:00	54	1						
	05:00	56	1						
	06:00	60	1						
	07:00	64	1						
	08:00	69	1						
	09:00	72	1						
	10:00	73	1						
	11:00	73	1						
	12:00	72	1						
	13:00	71	1						
	14:00	70	1						
	15:00	72	1						
	16:00	79	1						
	17:00	93	1		1				
	18:00	105	1		1				
	19:00	110	1		1				
	20:00	111	1		1				
	21:00	105	1		1				
	22:00	95	1		1				
	23:00	82	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 27 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ω Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 27 Δεκεμβρίου 2025	00:00	72	1						
	01:00	67	1						
	02:00	64	1						
	03:00	62	1						
	04:00	63	1						
	05:00	66	1						
	06:00	70	1						
	07:00	75	1						
	08:00	78	1						
	09:00	79	1						
	10:00	79	1						
	11:00	78	1						
	12:00	76	1						
	13:00	75	1						
	14:00	77	1						
	15:00	79	1						
	16:00	85	1		1				
	17:00	95	1		1				
	18:00	106	1		1				
	19:00	111	1		1				
	20:00	111	1		1				
	21:00	106	1		1				
	22:00	95	1		1				
	23:00	82	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 28 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Ε Τ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 28 Δεκεμβρίου 2025	00:00	81	1						
	01:00	74	1						
	02:00	69	1						
	03:00	66	1						
	04:00	64	1						
	05:00	66	1						
	06:00	70	1						
	07:00	75	1						
	08:00	79	1		1				
	09:00	80	1		1				
	10:00	81	1		1				
	11:00	80	1		1				
	12:00	79	1		1				
	13:00	77	1		1				
	14:00	77	1		1				
	15:00	79	1		1				
	16:00	85	1		1				
	17:00	97	1		1				
	18:00	105	1		1				
	19:00	110	1		1				
	20:00	108	1		1				
	21:00	102	1		1				
	22:00	92	1		1				
	23:00	80	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 29 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 29 Δεκεμβρίου 2025	00:00	72	1						
	01:00	69	1						
	02:00	68	1						
	03:00	69	1						
	04:00	71	1						
	05:00	74	1						
	06:00	77	1						
	07:00	81	1		1				
	08:00	85	1		1				
	09:00	88	1		1				
	10:00	89	1		1				
	11:00	89	1		1				
	12:00	88	1		1				
	13:00	86	1		1				
	14:00	88	1		1				
	15:00	90	1		1				
	16:00	96	1		1				
	17:00	107	1		1				
	18:00	117	1		1				
	19:00	123	1		1				
	20:00	124	1		1				
	21:00	117	1		1				
	22:00	105	1		1				
	23:00	89	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 30 Δεκεμβρίου 2025				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 30 Δεκεμβρίου 2025	00:00	80	1						
	01:00	76	1						
	02:00	73	1						
	03:00	73	1						
	04:00	75	1						
	05:00	79	1						
	06:00	86	1		1				
	07:00	91	1		1				
	08:00	95	1		1				
	09:00	96	1		1				
	10:00	95	1		1				
	11:00	93	1		1				
	12:00	91	1		1				
	13:00	90	1		1				
	14:00	92	1		1				
	15:00	97	1		1				
	16:00	106	1		1				
	17:00	120	1		1				
	18:00	130	1		1				
	19:00	136	1		1				
	20:00	136	1		1				
	21:00	128	1		1				
	22:00	114	1		1				
	23:00	97	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης