

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Τετάρτη, 17 Δεκεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 17 Δεκεμβρίου 2025	00:00	0,944				1		
	01:00	0,889				1		
	02:00	0,857				1		
	03:00	0,837				1		
	04:00	0,830				1		
	05:00	0,844				1		
	06:00	0,883				1		
	07:00	0,925		1		1		
	08:00	0,950		1		1		
	09:00	0,947		1		1		
	10:00	0,943		1		1		
	11:00	0,928		1		1		
	12:00	0,915		1		1		
	13:00	0,918		1		1		
	14:00	0,929		1		1		
	15:00	0,974		1		1		
	16:00	1,072		1		1		
	17:00	1,219		1		1		
	18:00	1,266		1		1		
	19:00	1,316		1		1		
	20:00	1,339		1		1		
	21:00	1,290		1		1		
	22:00	1,177		1		1		
	23:00	1,079		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Πέμπτη, 18 Δεκεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 18 Δεκεμβρίου 2025	00:00	0,950				1		
	01:00	0,895				1		
	02:00	0,859				1		
	03:00	0,838				1		
	04:00	0,830				1		
	05:00	0,838				1		
	06:00	0,867				1		
	07:00	0,905				1		
	08:00	0,930		1		1		
	09:00	0,943		1		1		
	10:00	0,947		1		1		
	11:00	0,922		1		1		
	12:00	0,912		1		1		
	13:00	0,920		1		1		
	14:00	0,920		1		1		
	15:00	0,990		1		1		
	16:00	1,084		1		1		
	17:00	1,295		1		1		
	18:00	1,392		1		1		
	19:00	1,440		1		1		
	20:00	1,421		1		1		
	21:00	1,334		1		1		
	22:00	1,201		1		1		
	23:00	1,055		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Παρασκευή, 19 Δεκεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 19 Δεκεμβρίου 2025	00:00	0,944				1		
	01:00	0,894				1		
	02:00	0,863				1		
	03:00	0,848				1		
	04:00	0,848				1		
	05:00	0,864				1		
	06:00	0,901				1		
	07:00	0,948				1		
	08:00	0,994		1		1		
	09:00	1,023		1		1		
	10:00	0,998		1		1		
	11:00	0,984		1		1		
	12:00	0,959		1		1		
	13:00	0,934		1		1		
	14:00	0,960		1		1		
	15:00	1,015		1		1		
	16:00	1,104		1		1		
	17:00	1,332		1		1		
	18:00	1,425		1		1		
	19:00	1,410		1		1		
	20:00	1,369		1		1		
	21:00	1,293		1		1		
	22:00	1,188		1		1		
	23:00	1,051		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Σάββατο, 20 Δεκεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Α Ρ Ω Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 20 Δεκεμβρίου 2025	00:00	0,952				1		
	01:00	0,907				1		
	02:00	0,871				1		
	03:00	0,848				1		
	04:00	0,849				1		
	05:00	0,861				1		
	06:00	0,894				1		
	07:00	0,938		1		1		
	08:00	0,990		1		1		
	09:00	1,067		1		1		
	10:00	0,997		1		1		
	11:00	0,987		1		1		
	12:00	1,143		1		1		
	13:00	1,152		1		1		
	14:00	1,153		1		1		
	15:00	1,141		1		1		
	16:00	1,193		1		1		
	17:00	1,329		1		1		
	18:00	1,356		1		1		
	19:00	1,363		1		1		
	20:00	1,337		1		1		
	21:00	1,276		1		1		
	22:00	1,165		1		1		
	23:00	1,030		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Κυριακή, 21 Δεκεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 21 Δεκεμβρίου 2025	00:00	0,967				1		
	01:00	0,915				1		
	02:00	0,882				1		
	03:00	0,864				1		
	04:00	0,857				1		
	05:00	0,867				1		
	06:00	0,894				1		
	07:00	0,936		1		1		
	08:00	0,986		1		1		
	09:00	1,007		1		1		
	10:00	1,016		1		1		
	11:00	1,005		1		1		
	12:00	1,111		1		1		
	13:00	1,135		1		1		
	14:00	1,128		1		1		
	15:00	1,151		1		1		
	16:00	1,157		1		1		
	17:00	1,272		1		1		
	18:00	1,317		1		1		
	19:00	1,320		1		1		
	20:00	1,304		1		1		
	21:00	1,248		1		1		
	22:00	1,165		1		1		
	23:00	1,036		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Δευτέρα, 22 Δεκεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 22 Δεκεμβρίου 2025	00:00	0,954				1		
	01:00	0,904				1		
	02:00	0,876				1		
	03:00	0,865				1		
	04:00	0,868				1		
	05:00	0,887				1		
	06:00	0,923		1		1		
	07:00	0,961		1		1		
	08:00	1,019		1		1		
	09:00	1,070		1		1		
	10:00	1,111		1		1		
	11:00	1,118		1		1		
	12:00	1,130		1		1		
	13:00	1,144		1		1		
	14:00	1,137		1		1		
	15:00	1,137		1		1		
	16:00	1,162		1		1		
	17:00	1,310		1		1		
	18:00	1,358		1		1		
	19:00	1,358		1		1		
	20:00	1,343		1		1		
	21:00	1,284		1		1		
	22:00	1,180		1		1		
	23:00	1,054		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Τρίτη, 23 Δεκεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 23 Δεκεμβρίου 2025	00:00	0,959				1		
	01:00	0,910				1		
	02:00	0,881				1		
	03:00	0,869				1		
	04:00	0,873				1		
	05:00	0,894				1		
	06:00	0,933		1		1		
	07:00	0,985		1		1		
	08:00	1,051		1		1		
	09:00	1,110		1		1		
	10:00	1,156		1		1		
	11:00	1,161		1		1		
	12:00	1,166		1		1		
	13:00	1,157		1		1		
	14:00	1,140		1		1		
	15:00	1,157		1		1		
	16:00	1,199		1		1		
	17:00	1,319		1		1		
	18:00	1,363		1		1		
	19:00	1,381		1		1		
	20:00	1,371		1		1		
	21:00	1,312		1		1		
	22:00	1,199		1		1		
	23:00	1,070		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης