

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Τετάρτη, 31 Δεκεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 31 Δεκεμβρίου 2025	00:00	0,918		1				
	01:00	0,866		1				
	02:00	0,837		1				
	03:00	0,820		1				
	04:00	0,816		1				
	05:00	0,823		1				
	06:00	0,846		1				
	07:00	0,883		1				
	08:00	0,900		1				
	09:00	0,898		1				
	10:00	0,913		1				
	11:00	0,961	1	1				
	12:00	1,037	1	1				
	13:00	1,060	1	1				
	14:00	1,080	1	1				
	15:00	1,087	1	1				
	16:00	1,161	1	1				
	17:00	1,286	1	1				
	18:00	1,346	1	1				
	19:00	1,373	1	1				
	20:00	1,355	1	1				
	21:00	1,292	1	1				
	22:00	1,191	1	1				
	23:00	1,067	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Πέμπτη, 1 Ιανουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η μ ε ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 1 Ιανουαρίου 2026	00:00	0,937		1				
	01:00	0,883		1				
	02:00	0,843		1				
	03:00	0,818		1				
	04:00	0,807		1				
	05:00	0,817		1				
	06:00	0,850		1				
	07:00	0,902		1				
	08:00	0,961	1	1				
	09:00	1,070	1	1				
	10:00	1,114	1	1				
	11:00	1,099	1	1				
	12:00	1,173	1	1				
	13:00	1,225	1	1				
	14:00	1,269	1	1				
	15:00	1,292	1	1				
	16:00	1,448	1	1				
	17:00	1,574	1	1				
	18:00	1,611	1	1				
	19:00	1,604	1	1				
	20:00	1,554	1	1				
	21:00	1,456	1	1				
	22:00	1,319	1	1				
	23:00	1,158	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Παρασκευή, 2 Ιανουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 2 Ιανουαρίου 2026	00:00	1,070	1	1				
	01:00	1,006	1	1				
	02:00	0,958	1	1				
	03:00	0,927	1	1				
	04:00	0,918	1	1				
	05:00	0,930	1	1				
	06:00	0,967	1	1				
	07:00	1,033	1	1				
	08:00	1,110	1	1				
	09:00	1,166	1	1				
	10:00	1,150	1	1				
	11:00	1,163	1	1				
	12:00	1,156	1	1				
	13:00	1,126	1	1				
	14:00	1,158	1	1				
	15:00	1,239	1	1				
	16:00	1,371	1	1				
	17:00	1,569	1	1				
	18:00	1,657	1	1				
	19:00	1,676	1	1				
	20:00	1,613	1	1				
	21:00	1,502	1	1				
	22:00	1,351	1	1				
	23:00	1,180	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Σάββατο, 3 Ιανουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 3 Ιανουαρίου 2026	00:00	1,077	1	1				
	01:00	1,021	1	1				
	02:00	0,981	1	1				
	03:00	0,959	1	1				
	04:00	0,955	1	1				
	05:00	0,965	1	1				
	06:00	0,993	1	1				
	07:00	1,039	1	1				
	08:00	1,095	1	1				
	09:00	1,105	1	1				
	10:00	1,097	1	1				
	11:00	1,083	1	1				
	12:00	1,071	1	1				
	13:00	1,067	1	1				
	14:00	1,088	1	1				
	15:00	1,142	1	1				
	16:00	1,261	1	1				
	17:00	1,458	1	1				
	18:00	1,547	1	1				
	19:00	1,566	1	1				
	20:00	1,537	1	1				
	21:00	1,460	1	1				
	22:00	1,329	1	1				
	23:00	1,167	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Κυριακή, 4 Ιανουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 4 Ιανουαρίου 2026	00:00	1,055	1	1				
	01:00	0,997	1	1				
	02:00	0,955	1	1				
	03:00	0,928	1	1				
	04:00	0,918	1	1				
	05:00	0,925	1	1				
	06:00	0,953	1	1				
	07:00	0,999	1	1				
	08:00	1,059	1	1				
	09:00	1,110	1	1				
	10:00	1,147	1	1				
	11:00	1,137	1	1				
	12:00	1,134	1	1				
	13:00	1,024	1	1				
	14:00	1,049	1	1				
	15:00	1,070	1	1				
	16:00	1,165	1	1				
	17:00	1,306	1	1				
	18:00	1,365	1	1				
	19:00	1,392	1	1				
	20:00	1,394	1	1				
	21:00	1,348	1	1				
	22:00	1,234	1	1				
	23:00	1,092	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Δευτέρα, 5 Ιανουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 5 Ιανουαρίου 2026	00:00	0,986	1	1				
	01:00	0,931	1	1				
	02:00	0,897	1	1				
	03:00	0,881	1	1				
	04:00	0,881	1	1				
	05:00	0,897	1	1				
	06:00	0,930	1	1				
	07:00	0,982	1	1				
	08:00	1,044	1	1				
	09:00	1,096	1	1				
	10:00	1,060	1	1				
	11:00	1,039	1	1				
	12:00	1,031	1	1				
	13:00	1,032	1	1				
	14:00	1,124	1	1				
	15:00	1,141	1	1				
	16:00	1,182	1	1				
	17:00	1,286	1	1				
	18:00	1,362	1	1				
	19:00	1,406	1	1				
	20:00	1,410	1	1				
	21:00	1,363	1	1				
	22:00	1,246	1	1				
	23:00	1,095	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Τρίτη, 6 Ιανουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η μ ε ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 6 Ιανουαρίου 2026	00:00	0,979	1	1				
	01:00	0,926	1	1				
	02:00	0,892	1	1				
	03:00	0,872	1	1				
	04:00	0,867	1	1				
	05:00	0,877	1	1				
	06:00	0,904	1	1				
	07:00	0,952	1	1				
	08:00	1,016	1	1				
	09:00	1,071	1	1				
	10:00	1,103	1	1				
	11:00	1,071	1	1				
	12:00	1,054	1	1				
	13:00	1,052	1	1				
	14:00	1,070	1	1				
	15:00	1,102	1	1				
	16:00	1,164	1	1				
	17:00	1,275	1	1				
	18:00	1,346	1	1				
	19:00	1,375	1	1				
	20:00	1,367	1	1				
	21:00	1,325	1	1				
	22:00	1,235	1	1				
	23:00	1,106	1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης