

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 3 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 3 Δεκεμβρίου 2025	00:00	0,875	1								
	01:00	0,798	1								
	02:00	0,756	1								
	03:00	0,770	1								
	04:00	0,770	1								
	05:00	0,808	1								
	06:00	0,887	1								
	07:00	0,925	1								
	08:00	0,864	1								
	09:00	0,911	1								
	10:00	0,885	1								
	11:00	0,857	1								
	12:00	0,867	1								
	13:00	0,872	1								
	14:00	0,912	1								
	15:00	1,002	1								1
	16:00	1,119	1								1
	17:00	1,278	1								1
	18:00	1,365	1								1
	19:00	1,369	1								1
	20:00	1,292	1								1
	21:00	1,169	1								1
	22:00	1,037	1								1
	23:00	0,940	1								1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 4 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Θ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 4 Δεκεμβρίου 2025	00:00	0,828	1								
	01:00	0,795	1								
	02:00	0,743	1								
	03:00	0,724	1								
	04:00	0,726	1								
	05:00	0,768	1								
	06:00	0,852	1								
	07:00	0,881	1								
	08:00	0,879	1								
	09:00	0,865	1								
	10:00	0,830	1								
	11:00	0,855	1								
	12:00	0,909	1								
	13:00	0,878	1								
	14:00	0,863	1								
	15:00	0,884	1								1
	16:00	1,020	1								1
	17:00	1,201	1								1
	18:00	1,251	1								1
	19:00	1,231	1								1
	20:00	1,198	1								1
	21:00	1,140	1								1
	22:00	0,983	1								1
	23:00	0,909	1								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 5 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 5 Δεκεμβρίου 2025	00:00	0,794	1								
	01:00	0,738	1								
	02:00	0,707	1								
	03:00	0,697	1								
	04:00	0,733	1								
	05:00	0,722	1								
	06:00	0,803	1								
	07:00	0,818	1								
	08:00	0,912	1								
	09:00	0,992	1								1
	10:00	1,089	1								1
	11:00	1,110	1								1
	12:00	1,057	1								1
	13:00	1,077	1								1
	14:00	1,057	1								1
	15:00	1,070	1								1
	16:00	1,163	1								1
	17:00	1,233	1								1
	18:00	1,255	1								1
	19:00	1,244	1								1
	20:00	1,189	1								1
	21:00	1,074	1								1
	22:00	0,993	1								1
	23:00	0,922	1								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 6 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 6 Δεκεμβρίου 2025	00:00	0,857	1								
	01:00	0,803	1								
	02:00	0,743	1								
	03:00	0,709	1								
	04:00	0,744	1								
	05:00	0,744	1								
	06:00	0,815	1								
	07:00	0,827	1								
	08:00	0,843	1								
	09:00	0,819	1						1		
	10:00	0,896	1						1		
	11:00	0,890	1								
	12:00	0,884	1								
	13:00	0,892	1								
	14:00	0,941	1						1		
	15:00	0,961	1						1		
	16:00	1,100	1						1		
	17:00	1,242	1						1		
	18:00	1,275	1						1		
	19:00	1,243	1						1		
	20:00	1,187	1						1		
	21:00	1,103	1						1		
	22:00	0,981	1						1		
	23:00	0,899	1								

Στο διάστημα 09:22 - 09:37 σημειώθηκε γενική διακοπή λόγω κακοκαιρίας.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 7 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 7 Δεκεμβρίου 2025	00:00	0,846	1								
	01:00	0,766	1								
	02:00	0,719	1								
	03:00	0,698	1								
	04:00	0,709	1								
	05:00	0,723	1								
	06:00	0,816	1								
	07:00	0,771	1								
	08:00	0,789	1								
	09:00	0,761	1								
	10:00	0,756	1								
	11:00	0,775	1								
	12:00	0,815	1								
	13:00	0,836	1								
	14:00	0,822	1								
	15:00	0,986	1								1
	16:00	1,093	1								1
	17:00	1,172	1								1
	18:00	1,236	1								1
	19:00	1,222	1								1
	20:00	1,179	1								1
	21:00	1,108	1								1
	22:00	0,984	1								1
	23:00	0,881	1								

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 8 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 8 Δεκεμβρίου 2025	00:00	0,769	1								
	01:00	0,729	1								
	02:00	0,701	1								
	03:00	0,693	1								
	04:00	0,711	1								
	05:00	0,739	1								
	06:00	0,834	1								
	07:00	0,863	1								
	08:00	0,819	1								
	09:00	0,794	1								
	10:00	0,800	1								
	11:00	0,855	1								
	12:00	0,896	1								
	13:00	0,966	1						1		
	14:00	0,982	1						1		
	15:00	1,044	1						1		
	16:00	1,174	1						1		
	17:00	1,350	1						1		
	18:00	1,391	1						1		
	19:00	1,367	1						1		
	20:00	1,325	1						1		
	21:00	1,237	1						1		
	22:00	1,106	1						1		
	23:00	0,998	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 9 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 9 Δεκεμβρίου 2025	00:00	0,889	1								
	01:00	0,814	1								
	02:00	0,776	1								
	03:00	0,772	1								
	04:00	0,781	1								
	05:00	0,801	1								
	06:00	0,880	1								
	07:00	0,905	1								
	08:00	0,873	1								
	09:00	0,947	1						1		
	10:00	0,976	1						1		
	11:00	0,967	1						1		
	12:00	0,925	1						1		
	13:00	0,986	1						1		
	14:00	1,031	1						1		
	15:00	1,128	1						1		
	16:00	1,213	1						1		
	17:00	1,403	1						1		
	18:00	1,454	1						1		
	19:00	1,426	1						1		
	20:00	1,335	1						1		
	21:00	1,213	1						1		
	22:00	1,092	1						1		
	23:00	0,999	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης