

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 10 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Θ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 10 Δεκεμβρίου 2025	00:00	0,883	1								
	01:00	0,814	1								
	02:00	0,774	1								
	03:00	0,784	1								
	04:00	0,829	1								
	05:00	0,816	1								
	06:00	0,928	1								
	07:00	0,892	1						1		
	08:00	0,864	1						1		
	09:00	0,910	1						1		
	10:00	0,845	1						1		
	11:00	0,864	1								
	12:00	0,891	1								
	13:00	0,925	1								
	14:00	0,873	1						1		
	15:00	0,885	1						1		
	16:00	1,012	1						1		
	17:00	1,259	1						1		
	18:00	1,392	1						1		
	19:00	1,421	1						1		
	20:00	1,375	1						1		
	21:00	1,247	1						1		
	22:00	1,126	1						1		
	23:00	0,973	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 11 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 11 Δεκεμβρίου 2025	00:00	0,848	1						1		
	01:00	0,800	1								
	02:00	0,782	1								
	03:00	0,814	1								
	04:00	0,800	1								
	05:00	0,793	1								
	06:00	0,882	1								
	07:00	0,877	1								
	08:00	0,846	1								
	09:00	0,867	1								
	10:00	0,834	1								
	11:00	0,795	1								
	12:00	0,802	1								
	13:00	0,789	1								
	14:00	0,808	1								
	15:00	0,885	1								
	16:00	1,044	1						1		
	17:00	1,291	1						1		
	18:00	1,385	1						1		
	19:00	1,331	1						1		
	20:00	1,268	1						1		
	21:00	1,182	1						1		
	22:00	1,056	1						1		
	23:00	0,965	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 12 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 12 Δεκεμβρίου 2025	00:00	0,840	1						1		
	01:00	0,788							1		
	02:00	0,747							1		
	03:00	0,753							1		
	04:00	0,776							1		
	05:00	0,808							1		
	06:00	0,886							1		
	07:00	0,842							1		
	08:00	0,844							1		
	09:00	0,875							1		
	10:00	0,841							1		
	11:00	0,880							1		
	12:00	0,828							1		
	13:00	0,907	1						1		
	14:00	0,850	1						1		
	15:00	0,970	1						1		
	16:00	1,129	1						1		
	17:00	1,308	1						1		
	18:00	1,373	1						1		
	19:00	1,342	1						1		
	20:00	1,330	1						1		
	21:00	1,220	1						1		
	22:00	1,164	1						1		
	23:00	1,057	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 13 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Θ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 13 Δεκεμβρίου 2025	00:00	0,899	1						1		
	01:00	0,836	1						1		
	02:00	0,778	1								
	03:00	0,773	1								
	04:00	0,797	1								
	05:00	0,795	1								
	06:00	0,890	1								
	07:00	0,850	1								
	08:00	0,873	1								
	09:00	0,848	1								
	10:00	0,821	1								
	11:00	0,823	1								
	12:00	0,841	1								
	13:00	0,831	1								
	14:00	0,905	1								
	15:00	1,007	1						1		
	16:00	1,155	1						1		
	17:00	1,396	1						1		
	18:00	1,506	1						1		
	19:00	1,459	1						1		
	20:00	1,351	1						1		
	21:00	1,246	1						1		
	22:00	1,150	1						1		
	23:00	1,030	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 14 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Θ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 14 Δεκεμβρίου 2025	00:00	0,893	1						1		
	01:00	0,842	1						1		
	02:00	0,819	1								
	03:00	0,818	1								
	04:00	0,804	1								
	05:00	0,822	1								
	06:00	0,887	1								
	07:00	0,846	1								
	08:00	0,839	1								
	09:00	0,829	1								
	10:00	0,794	1								
	11:00	0,815	1								
	12:00	0,933	1								
	13:00	0,915	1								
	14:00	0,975	1						1		
	15:00	1,018	1						1		
	16:00	1,070	1						1		
	17:00	1,195	1						1		
	18:00	1,298	1						1		
	19:00	1,241	1						1		
	20:00	1,275	1						1		
	21:00	1,235	1						1		
	22:00	1,125	1						1		
	23:00	1,004	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 15 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Θ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 15 Δεκεμβρίου 2025	00:00	0,864	1						1		
	01:00	0,795							1		
	02:00	0,768							1		
	03:00	0,770							1		
	04:00	0,793							1		
	05:00	0,805							1		
	06:00	0,904							1		
	07:00	0,924							1		
	08:00	0,894							1		
	09:00	0,868							1		
	10:00	0,809							1		
	11:00	0,813							1		
	12:00	0,774							1		
	13:00	0,782							1		
	14:00	0,791							1		
	15:00	0,909	1						1		
	16:00	1,031	1						1		
	17:00	1,279	1						1		
	18:00	1,337	1						1		
	19:00	1,345	1						1		
	20:00	1,322	1						1		
	21:00	1,249	1						1		
	22:00	1,118	1						1		
	23:00	0,981	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 16 Δεκεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 16 Δεκεμβρίου 2025	00:00	0,870	1						1		
	01:00	0,809							1		
	02:00	0,768							1		
	03:00	0,751							1		
	04:00	0,798							1		
	05:00	0,819							1		
	06:00	0,922							1		
	07:00	0,883							1		
	08:00	0,862							1		
	09:00	0,901							1		
	10:00	0,840							1		
	11:00	0,839							1		
	12:00	0,850							1		
	13:00	0,843							1		
	14:00	0,890							1		
	15:00	0,990	1						1		
	16:00	1,132	1						1		
	17:00	1,333	1						1		
	18:00	1,502	1						1		
	19:00	1,462	1						1		
	20:00	1,394	1						1		
	21:00	1,249	1						1		
	22:00	1,129	1						1		
	23:00	0,987	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης